

HENNEPIN COUNTY

MINNESOTA

PUBLIC SWIMMING POOL CHEMISTRY REQUIREMENTS

Disinfectant	Swimming & Wading Pools	Spa Pools
Free Chlorine	1.0 - 10.0 ppm	2.0 - 10.0 ppm
Bromine	2.0 - 20.0 ppm	4.0 - 20.0 ppm

pH: 7.2 - 7.8	Combined chlorine: 0.5 ppm maximum
Alkalinity: 50 ppm minimum	Cyanuric acid: 100 ppm maximum
Water clarity: Bottom drain must be clearly visible	Temperature: 104°F maximum

Hennepin County Public Health

1011 1st Street South Suite 215 Hopkins, MN 55343

612-543-5200

www.hennepin.us/pools

[Minnesota Pool Code](#)

