

Murrieta Valley Unified School District 41870 McAlby Court Murrieta, CA 92562

DISTRICT BID ADDENDUM NO. 2

Date: January 13, 2023

To:All BiddersFrom:Nadia Zeien, Director of PurchasingProject:Lisa J Mails LED Lighting Conversion Project

The attached Addendum is issued for the purposes of amending certain requirements of the bid and hereby made part of and incorporated in full force as part of the Contract Documents. Unless hereinafter specifically noted or specified otherwise, all work shall confirm to the applicable provisions of the Contract Documents.

BID ADDENDUM NO. 2 DESCRIPTION:

Item 1: Pre-Bid Clarification (Request for Information) – Questions and Responses:

Question #1:

- In scope of work #3. Bugeye style lights to be installed above all exterior doors in rooms designated for LED lighting conversion. Fixture type is on #4. ELM-LED-803
 - a. Are these going inside the room and removing or repositioning the Exit sign?
 - b. Are these going on the exterior wall above door?

District Response:

a. The District does not want any exit signs removed or repositioned.

b. The bugeye style lights are to be ceiling mounted near the exterior door (approximately within 3 feet) utilizing a T-bar style bracket with a junction box. If a room has 2 exterior doors, the bugeye lights are to be mounted by the one with the exit sign.

Question #2:

2. I am requesting the substitution of RMJ-5T-DV-B as it is obsolete and no longer available, the replacement model is RMJS-8T-DV-B.

District Response:

Please utilize model RMJS-8T-DV-B for the Power Pack.

Question #3:

3. The PICO-RF-434 W LED is not a valid part number but seems to be a description that can describe several different items. We would like to encourage the district to please review the Lutron Pico wireless control document to select the correct part.

District Response:

Please utilize PJ2-2BRL-GWH-LO1 for the controller.

Question #4:

- 4. In materials to be used #3. Retro kit (1 each per room)
 - a. VEKT2x4L-840 Retro kit
 - b. 36W 2x4 LED Retrofit kit 0-10 4000K (or equivalent approved by the District)

Are these two different types of fixtures? Or is it just one fixture with the description of the fixture the District is requesting.

District Response:

It is only one fixture; item B is a description of the fixture the District is requesting.

Question #5:

5. What is the estimated project budget?

District Response:

\$150,000

Question #6:

6. When is the District going to review and approve Quality Bidder applications that the District requested?

District Response:

These are reviewed on a daily basis.

Question #7:

7. Is there (1) bug eye emergency light going in every room? Please clarify SOW with emergency egress lights.

District Response:

Reference Response #1

Each room designated for conversion will have (1) bug eye emergency light installed near (approximately within 3 feet) the exterior door.

Item 2: Pre-Bid Conference (Job Walk Sign in Sheet)

ATTACHMENTS:

Pre-Bid Conference (Job Walk Sign in Sheet)

END OF DISTRICT BID ADDENDUM NO. 2



PRE-BID JOB WALK SIGN-IN SHEET 1/9/2023 Murrieta Valley Unified School District

Lisa J. Mails Led Lighti	ing Conversion Project	BID NO. 2023-01-01202023	
	NAME (Please Print)	SIGNATURE	EMAIL (Please Print)
Precision Electric	MelanieBisher	Opphante	estimating @PECSD.com
MM Energy & Lighting	Manuel Martine Rodrigue		mmartinez@mmeandl.com
ALLEGIANLE ELECTRIC	ANTHONY CENTRINAL	- A	ACENTANNI QALLEBIANCEELEL. COM
Building Resource	as Victor Chew	1-14	Vchewe Brco.com
Optima Energy	Anthony Borthaglia	UB	Young@OPMRG.com
Smart City Electrick	STOUR Mike Sanloval	Jula	INFOSMARTCHY Dichou. com
SC Data & Pare	Michael Beatry	the	mikeb@ bcdatupower.com
INTER PACIFIC INC	EVAN ILAN	Lp	elcas Binter-profic. com
Saturn dutric	matt Relinson	Ilto	Mutte SaturAclectric, con
Allegionce electric	Michael Glanay	alus	MGlancy Palles: ance elec com
	1	0	

PRE-BID JOB WALK SIGN-IN SHEET



1/9/2023 Murrieta Valley Unified School District

Lisa J. Mails Led Lighting Conversion Project

BID NO. 2023-01-01202023

COMPANY NAME	NAME (Please Print)	SIGNATURE	EMAIL (Please Print)
M. Brey Elector.	Marco Rodranez	MARE	marco@mbreyelectric.com
BAILER ELECT	JOHN DUBE	45/de	JDUBER BALLOR-ELECTRIC. COM
RETRO TELEWOOLSHELD		1 st	brad 6 retrotekes com
ENDELOS ENERGY /	JUSTIN TREADWAD	D'V	JTREADWAYCENDELOSENERGY. COM