

# **Addendum No. 1**

Date: November 30, 2022

Bay District Schools

Callaway Storm Repairs 2022

400 Fox Ave N, Panama City, Florida 32404

## **Overview**

The changes and/or additions/deletions to the plans and specifications described in this addendum are hereby made part of same and are incorporated in full as part of the Contract Documents. The Bidder shall acknowledge receipt of this addendum on the bid form submitted with their bid. Failure to the bidder to acknowledge this addendum may disqualify their bid. This addendum provides a brief description of items that have been modified.

## **This document consists of the following:**

- 1) Questions and Answers
- 2) Clarifications
- 3) Revised Misc. Items Notes (attached as separate document)

### **Questions and Answers:**

#### **RFI#1**

**Question:** What kind of testing needs to be accounted for?

**Answer:** Both fill dirt placed in pond bottom and storm pipe trenches need to be tested. Testing qualification is compact to 95% modified proctor modified dry density (12" lifts)

#### **RFI#2**

**Question:** Does the Schedule of Values need to be placed in the bid documents?

**Answer:** Yes.

#### **RFI#3**

**Question:** Will a bid bond need to be provided?

**Answer:** No bonds are required on this project.

### **Clarifications:**

- 1) On the Misc. Items Notes document, there is zero vegetation to be removed between DS23 & DS24. The red arrow has been removed and documents updated.
- 2) The quantities provided in the Schedule of Values are estimates only. Bidding contractor shall modify quantities as needed to cover their cost. No change orders will be given based on adjustment of quantities.
- 3) This addendum will go in the Supplements section of the Bid Proposal Form.
- 4) **Bid date and time has not changed.**