

Smyrna School District Central Plant

Certificate of Necessity

Smyrna, Delaware

Gipe Associates, Inc.
Project: 18047
August 09, 2019



Gipe Associates, Inc.
CONSULTING ENGINEERS

SMYRNA
School District

Mechanical / Electrical Engineer
8719 Brooks Drive
Easton, MD 21601
410.822.8688

CONTENTS

1 Executive Summary.....	2
1.1 Property Information and General MEP systems Condition.....	2
1.2 Anticipated Lifecycle Replacement.....	2
1.3 Cost Estimates.....	2
2 Scope and Methodology	3
2.1 Scope.....	3
2.2 Methodology.....	3
2.3 Condition Assessment Priority Definitions	3
3 Mechanical and Plumbing Systems.....	4
3.1 Heating, Ventilating and Air Conditioning (HVAC).....	4
3.2 Domestic Water Plumbing Systems.....	9
4 Electrical Systems.....	10
4.1 Electrical Service	10
4.2 Emergency Power	10
4.3 Lighting Systems.....	11
4.4 Power	11
4.5 Special Systems	12
4.6 Fire Alarm System	12
Appendix A – Facility Photographs	
Appendix B – Cost Estimates	

1 EXECUTIVE SUMMARY

1.1 Property Information and General MEP systems Condition

The Central Plant Building is located at 600 Duck Creek Parkway, Smyrna, DE. The building houses the central heating and cooling equipment that serves the Smyrna High School and Middle School buildings. The plant was constructed in 2009 which also includes the Smyrna District Maintenance offices and workshops.

CENTRAL PLANT BUILDING INFORMATION	
Address	600 Duck Creek Parkway, Smyrna, DE
Year Constructed	2009
Building Area	10,000 SQ-FT
Building Type	Central Heating and Cooling Plant, Maintenance Offices, Maintenance Shop, Vehicle Bay
Buildings Served	Smyrna High School and Middle School
System Types	Central 4-pipe Plant with boilers and chillers
Survey Date	11-Jul-18
Point of Contact	Scott Holmes

The central plant MEP systems are in good shape overall and appear to be well-maintained. The two significant short-term recommendations are repairing the Cooling Tower (CT-1) and designing a solution to increase chilled water flow rates available to the Middle School.

1.2 Anticipated Lifecycle Replacement

ANTICIPATED LIFECYCLE REPLACEMENT	
Priority	System / Equipment / Component / Repair
Immediate	Cooling Tower (CT-1) Repair, Primary Pump Evaluation, Chiller Overhaul Rebuild
Short-Term	N/A
Mid-Term	N/A
Long-Term	Boilers, Cooling Towers, Pumps, Air Handling Units, Unit Heaters, Fans, Air Separators, Expansion Tanks, Chemical Treatment System, Controls, Plumbing Systems, Switchboard, Panelboards, Generator, Automatic Transfer Switch (ATS), Receptacles, Wiring, Disconnect Switches, Interior and Exterior Lighting, Special Systems, and Fire Alarm

1.3 Cost Estimates

COST ESTIMATE		
#	Description	Estimated Project Cost
1	Cooling Tower (CT-1) Repair Allowance	\$ 16,500.00
2	Primary Chilled Water Pump System Survey and Evaluation	\$ 38,500.00
3	Chiller 10 Year Overhaul Rebuild	\$ 985,000.00
Total		\$ 1,035,000.00

2 SCOPE AND METHODOLOGY

2.1 Scope

The scope of this report is to assess the condition of existing MEP systems and provide the Smyrna School District a means to prioritize upgrades.

2.2 Methodology

Gipe Associates has made assessments and recommendations based on (4) main factors which include:

- Onsite surveys of equipment by visual inspection
- Review of the existing MEP drawings provided by the Smyrna School District
- Interviews with Maintenance Staff to identify chronic system issues, regular maintenance schedules and historical system operation
- American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) Service Life Database (<https://xp20.ashrae.org/publicdatabase/>)

From these sources, judgements are made to assess equipment condition and determine the expected useful life remaining for MEP systems for this geographical location and use type. Condition assessments have been grouped in order of priority as defined in the next section.

2.3 Condition Assessment Priority Definitions

Code	Priority	Description
P-01	Immediate	Items that are currently overdue or that will be required within the next year (FY19). Equipment condition is either non-operational, in poor condition or not meeting performance needs.
P-02	Short-Term	Items that will be required within the next 2-3 years (FY20-FY22). Equipment condition is fair, signs of wear but still satisfactory as-is, additional maintenance and repair may be required as it continues to age.
P-03	Mid-Term	Items that will be required within the next 4-5 years (FY23-FY25). Equipment condition is good, performing satisfactory and expected to reach its estimated service life with regularly scheduled maintenance.
P-04	Long-Term	Items that will be required 5-10 years in the future (FY26+). Equipment condition is good – excellent, and has many years of useful service life remaining.

The next section tabulates all major equipment, capacities and condition assessments with a priority code.

3 MECHANICAL AND PLUMBING SYSTEMS

Overall, the mechanical/plumbing systems and equipment appear to be well maintained and functioning adequately. Interviews with maintenance staff reported that the only performance issue attributed to the central plant is limited primary pumping capability which tends to starve the Middle School chilled water during the cooling season.

Currently, there are no plans to expand the High School or Middle school. Even so, plant capacity is sufficient to tolerate future increases in occupant density once the pumping issues are solved.

All equipment is original from the 2009 construction and has been maintained by in-house staff. All service records, engineering drawings and installation manuals have been maintained and filed on-site.

3.1 Heating, Ventilating and Air Conditioning (HVAC)

CENTRAL HEATING SYSTEM		
System or Unit Type	Service Life Estimate (years)	
Boiler(s), Hot Water		25
P-04	Quantity	3
	Capacity	10,083 MBH Input each
	Performance Efficiency	82%
	Fuel	Dual: Natural Gas and #2 Oil
	Plant Heating Capacity	25,107 MBH Output
	Location	Central Plant
	Service	High School and Middle School




Figure #1: Central Hydronic Heating Plant

P-01

Figure #2: Central Chilled Water Plant

HYDRONIC DISTRIBUTION (4-PIPE SYSTEM)		
System or Unit Type		Service Life Estimate (years)
Pump(s), Base-mounted		20
P-04	Quantity	2
	Capacity	40 HP each
	Control	Variable speed, 2-way control valves
	Location	Central Plant Mechanical Room
	Service	Heating Water Primary Circulation
	Nameplate Date	2009
P-04	Quantity	3 each
	Capacity	7.5 HP
	Control	Constant speed
	Location	Central Plant Mechanical Room
	Service	Boiler Water Circulation
	Nameplate Date	2009
P-01	Quantity	2 each
	Capacity	100 HP
	Control	Variable speed, 2-way control valves
	Location	Central Plant Mechanical Room
	Service	Chilled Water Primary Circulation
	Nameplate Date	2009
P-04	Quantity	3 each
	Capacity	25 HP
	Control	Constant speed
	Location	Central Plant Mechanical Room
	Service	Condenser Water Circulation
	Nameplate Date	2009
Pump(s), Inline		18
P-04	Quantity	2
	Capacity	3 HP each
	Control	Constant speed
	Location	Central Plant Mechanical Room
	Service	Heating Water Secondary Circulation
	Nameplate Date	2009
P-04	Quantity	2
	Capacity	1/3 HP each
	Control	Constant speed
	Location	Central Plant Mechanical Room
	Service	Chilled Water Secondary Circulation – Maint. Office
	Nameplate Date	2009

AIR DISTRIBUTION SYSTEMS		
System or Unit Type		Service Life Estimate (years)
Air Handling Unit(s), Constant Volume		24
P-04	Quantity	3
	Capacity	1,800; 3,100; 7,000 cfm
	Location	Ceiling Hung
	Service	Chiller Plant, Maintenance Shop, Office
	Nameplate Date	2009

SUPPLEMENTAL SYSTEMS		
System or Unit Type		Service Life Estimate (years)
Unit Heater, Hot Water		20
P-04	Quantity	6
	Capacity	100 - 135 MBH
	Service	Central Plant Building
	Nameplate Date	2009

VENTILATION SYSTEMS		
System or Unit Type		Service Life Estimate (years)
Fan, Centrifugal		20
P-04	Quantity	2
	Capacity	350; 1,390 CFM
	Location	Roof
	Service	Bathroom, Welding Hood
	Nameplate Date	2009
Fan, Axial		20
P-04	Quantity	3
	Capacity	4,000; 4,850; 4,850 CFM
	Location	Sidewall - Central Plant
	Service	Central Plant
	Nameplate Date	2009

CONTROL SYSTEM		
System or Unit Type		Service Life Estimate (years)
Controls, Direct Digital (DDC)		25
P-04	Location	Central BAS located in Central Plant Office
	Service	All Major Equipment Control Panels
	Nameplate Date	2009

Planned Improvements

The following items have been identified by the maintenance staff as approved projects that will be completed in the near term:

- Chiller refurbishment
- Upgraded BAS front end software (Allerton Compass)

Deferred Maintenance and Replacement

The following items have been identified either during the survey effort or by the maintenance staff as items that require immediate repair or replacement:

- Cooling Tower Repair – CT-1 intake screen is damaged and leaking tower water.



Photograph 1: Cooling Tower Damage

- Primary Chilled Water Pumping – Maintenance staff has identified chilled water capacity limitation issues at the Middle School. It is believed the primary pumps are undersized at the central plant. A study is required to look at the chilled water system holistically to confirm the issue and determine the best solution but it will likely require upgrading pumps (or pump components) and integrating a new control scheme. This will require a chilled water survey be performed by a Test and Balance Engineer.
- The (3) water cooled chillers are due for a manufacturer recommended overhaul rebuild. To complete this task, supplemental modifications to the chiller plant will be required.

Anticipated Lifecycle Replacement

The following list summarizes all major mechanical equipment in fair – excellent condition that will eventually require replacement, refurbishment or repair once they age past their estimated useful life.

- Boilers
- Chillers
- Cooling Towers
- Pumps

- Air Handling Units
- Unit Heaters
- Exhaust Fans
- Air Separators
- Expansion Tanks
- Chemical Treatment System

3.2 Domestic Water Plumbing Systems

PLUMBING SYSTEMS		
Plumbing System		Description
P-04	Water Supply Piping	Copper/Galvanized Steel (4" Service)
	Waste/Sewer Piping	Cast Iron
	Vent Piping	Cast Iron/Copper
	Fire Protection	Wet Pipe Sprinkler System (4" Service)
	Water Meter Location	Maintenance Room

DOMESTIC WATER HEATER		
System or Unit Type		Service Life Estimate (years)
Domestic Hot Water Heater, natural gas		15
P-04	Quantity	1
	Input Capacity	65 MBH
	Storage Capacity	65 Gallons
	Expansion Tank?	Yes
	Location	Weld Shop
	Service	Central Plant Bathroom and Break Room
	Nameplate Date	2009

PLUMBING FIXTURES		
Plumbing Fixture		Flush Rating / Flow Rate
P-04	Water Closet	1.6 GPF
	Urinal	1.0 GPF
	Lavatory	2.2 GPM
	Eyewash	4.0 GPM
	Shower	2.5 GPM

Planned Improvements

There are no planned improvements for the plumbing system.

Deferred Maintenance

There are no deferred maintenance items for the plumbing system.

Anticipated Lifecycle Replacement

The following list summarizes all major plumbing equipment in fair – excellent condition that will eventually require replacement, refurbishment or repair once they age past their estimated useful life.

- Water Heater
- Expansion Tank
- Thermostatic Mixing Valve
- Plumbing Fixtures
- Piping Systems and valves

4 ELECTRICAL SYSTEMS

4.1 Electrical Service

Equipment			
Overhead Conductors		Underground Conductors	X
P-04	Transformer	(1) 750kVA @ 480V – Customer Owned	
	Utility Company	Town of Smyrna	
	Service Size	(1) 1,600A @ 480V	
	Meter	Primary Meter	
	Location	Mounted on side of Primary Metering Station at back of high school property	
	Main Service Ground	Yes	
	Main Switchboard	(1) CPMPP – 1600A	Main Distribution Panelboard
	Manufacturer	Square D	Installation Date 5/2010

Equipment Type		
Panelboard(s)		
P-04	Type	Distribution – HCP, Branch Panelboards – NF or NQ
	Manufacturer	Square D

There are no immediate or significant repairs that need to be made to the electrical service or panelboard(s) in the building. The building has a 1,600A, 277/480V, three phase switchboard located in the main electrical room and panelboards throughout the building including in the main electrical room, mechanical space, shop area and vehicle bay spaces. The switchboard and panelboards throughout the building are manufactured by Square D and were installed in 2010.

4.2 Emergency Power

Equipment Type		
Generator Equipment		
P	Gen - Manufacturer	Kohler

P-04	Size	350kW
	Fuel Type	Diesel
	ATS (Manufacturer)	Kohler – (1) 60A Life Safety, (1) 400A Standby

The generator is located in a courtyard next to the Chiller plant and serves the high school in addition to Chiller Plant. The generator was installed in 2009 and has a 400A breaker that serves as a load bank so that the generator can be regularly tested under load. The generator is installed in a weather-proof enclosure and sits on a concrete pad with a diesel tank under the same.

4.3 Lighting Systems

Equipment Type		
Lighting Systems		
P-04	Interior Lighting	Type: Fluorescent, T8, T5; Metal Halide (MH) in Mechanical Shop
P-04	Exterior Lighting	Type: Wall mounted - MH, parking lot poles with MH lamp
P-04	Emergency Lighting	Type: Light fixtures throughout the building are fed from emergency circuit.
P-04	Illuminated Exit Signs	Yes
Switches		
P-04	Lighting Switches (MH)	46" to center of switch
P-04	Lighting Switches (MH) ADA Compliant	Yes

4.4 Power

Equipment Type		
Power		
P-04	GFCI receptacles at required locations	Yes
P-04	Duplex receptacles (Grounding or no)	Grounding
P-04	Duplex receptacles at HVAC equipment	Yes
P-04	Building Wire	Copper
P-04	Step-down transformer	
P-04	Interior disconnects	

4.5 Special Systems

Equipment Type		
Special Systems		
P-04	Telephone Entrance	MDF Room
	Cable TV Service	No
	Fiber/Data on site	Yes
	Data racks (Location or spare capacity)	MDF Room – Yes spare capacity
	Data Cabling	CAT 5E
	CCTV	Yes
	Security (Manufacturer, location)	Honeywell
	Intercom (Aiphone)	No
	Card Reader(s)	Yes

While the lighting systems are not in immediate need of replacement, as part of general improvements to the building, changing from fluorescent and metal halide lighting to LED lighting would result in energy savings and reduced cooling load. Also installing lighting controls such as occupancy sensors in the classrooms throughout the building could increase energy savings as the current building does not have an automatic means to turn off the lights in that space when that space is unoccupied. If occupancy sensors are installed in spaces that have an electrical panel, then the national electrical code (NEC) requires that a switch be provided to bypass the automatic control. The current lighting controls do not comply with the current edition of ASHRAE 90.1. Routine and periodic maintenance of the lighting system is recommended.

There are no immediate or significant repairs that need to be made to the building receptacles or building specialty systems. While the majority of the building receptacles are in good condition, there are two outlets in the shop space that are showing signs of rust and will probably need to be replaced within the next couple of years.

4.6 Fire Alarm System

Equipment Type			
Fire Alarm System			
P-04	Item	Yes	No
	Horns or Bells		X
	Strobe Lights	X	
	Voice Evacuation	X	
	Battery Back-up	X	
	Automatic Dialer	X	
	Smoke Detectors	X	
	Outdoor Bell	X	
	Duct Detectors	X	
	Smoke Dampers	X	
	Manual Stations at Exit	X	
	ADA compliant	X	
	Location of FACP	MDF Room	
	Layout Code Compliant	Yes	
	Fire Alarm (Addressable or Analog)	Addressable	

P-04	Manufacturer	Gamewell by Honeywell
	Date of Installation	2010
	Annunciator	
	Remote Annunciator	Yes
	Annunciator (Graphic or Alphanumeric)	Alphanumeric
	Annunciator Location	Front Lobby

There are no immediate or significant repairs that need to be made to the building fire alarm system. Routine and periodic testing and maintenance of the fire alarm system is recommended.

Planned Improvements

There are no planned improvements for the electrical system at the Chiller Plant.

Deferred Maintenance

There are no deferred maintenance items for the electrical system at the Chiller Plant.

General Improvements

- Replace interior and exterior lighting with LED fixtures
- Provide lighting controls throughout the building to automatically turn lights off in spaces that are empty.

Anticipated Lifecycle Replacement

The following list summarizes all major equipment that is currently in fair – excellent condition that will eventually need replacement:

- Switchboard(s)
- Panelboard(s)
- Step-down Transformers
- Generator
- Automatic Transfer Switch (ATS)
- Lighting
- Receptacles
- Fire Alarm Panel
- Security System
- Video Cameras

APPENDIX A

FACILITY PHOTOGRAPHS



Photo #1 Cooling Tower (CT-1) intake Damage and Leak



Photo #2 Condenser pumps



Photo #3 Boilers



Photo #4 Cooling Towers



Photo #5 Fuel Oil Pump Set



Photo #6 Primary Chilled Water Pumps



Photo #7 Primary Heating Water Pumps



Photo #8 Typical Boiler Pump



Photo #9 Typical Chiller



Photo #1 Typical Recessed Fluorescent 2'x4' Light Fixtures



Photo #2 Typical Motor Control Center (MCC)



Photo #3 Typical Exit Sign and Wireless Access Point



Photo #4 Typical Disconnect Switch



Photo #5 Receptacles in mechanical shop with evidence of rusting.



Photo #6 Main Switchboard CPMPP

Appendix A

Central Plant (CP) Electrical Photos



Photo #7 Typical Surface Mounted Fluorescent Strip Light




Photo #8 Typical Shop Lighting



Photo #9 Automatic Transfer Switches



Photo #10 Fire Alarm Control Panel



Photo #11 Remote Annunciator Panel

APPENDIX B

COST ESTIMATE



Gipe Associates, Inc.

CONSULTING ENGINEERS

Mechanical | Electrical | Plumbing

8719 BROOKS DRIVE

EASTON, MARYLAND

PHONE: 410-822-8688

FAX: 410-822-6306

CONSTRUCTION COST ESTIMATE

PROJECT: SMYRNA CENTRAL PLANT

GAI PROJECT NO: 18047

DATE: 07/27/18

PREPARED BY:

GENERAL PROJECT INFORMATION

PROJECT SQUARE FOOTAGE: 1

FACILITY TYPE: EDUCATION - CLASSROOMS

OF FLOORS: 2

ARCHITECT: FEARN-CLENDANIEL

BASIS FOR ESTIMATE: CERT. OF NECESSITY

SUMMARY: PRELIMINARY ESTIMATE

1 - COOLING TOWER REPAIR

QUANTITY		MATERIAL		LABOR		TOTAL COST
NO. OF UNITS	UNIT OF MEASURE	PER UNIT	TOTAL	PER UNIT	TOTAL	

BASE BID COST ESTIMATE

COOLING TOWER REPAIR ALLOWANCE	1.0	LS	\$ 7,500.00	\$ 7,500.00	\$ 7,500.00	\$ 7,500.00	\$ 15,000.00
--------------------------------	-----	----	-------------	-------------	-------------	-------------	--------------

COST ESTIMATE SUMMARY

DESCRIPTION	MATERIAL	LABOR	TOTAL
BASE BID TOTAL COST	\$ 7,500.00	\$ 7,500.00	\$ 15,000.00
TOTAL BASE BID:	\$ 7,500.00	\$ 7,500.00	\$ 15,000.00
TOTAL BASE BID COST PER SQUARE FOOT:	\$7500.00 PER S.F.	\$7500.00 PER S.F.	\$15000.00 PER S.F.

GRAND TOTAL COST ESTIMATE SUMMARY

ADDITIONAL PROJECT COST ITEM DESCRIPTION (APPLIES TO BASE BID ONLY)	PERCENTAGE (%)	% X TOTAL BASE BID	REMARKS
CONTRACTOR OVERHEAD	0.0%	\$ -	
CONTRACTOR PROFIT	0.0%	\$ -	
GENERAL CONDITIONS	0.0%	\$ -	
BUILDER'S RISK INSURANCE	0.0%	\$ -	
PERMIT FEES	0.0%	\$ -	
CONTRACTOR INSURANCE	0.0%	\$ -	
PAYMENT BOND	0.0%	\$ -	
PERFORMANCE BOND	0.0%	\$ -	
TOTAL ADDITIONAL PROJECT COST ITEMS		\$ -	
GRAND TOTAL CONSTRUCTION COST (BASE BID + ADDITIONAL PROJECT COSTS)		\$ 15,000.00	



Gipe Associates, Inc.

CONSULTING ENGINEERS

Mechanical | Electrical | Plumbing

8719 BROOKS DRIVE

EASTON, MARYLAND

PHONE: 410-822-8688

FAX: 410-822-6306

CONSTRUCTION COST ESTIMATE

PROJECT: SMYRNA CENTRAL PLANT

GAI PROJECT NO: 18047

DATE: 07/27/18

PREPARED BY:

GENERAL PROJECT INFORMATION

PROJECT SQUARE FOOTAGE: 1

FACILITY TYPE: EDUCATION - CLASSROOMS

OF FLOORS: 2

ARCHITECT: FEARN-CLENDANIEL

BASIS FOR ESTIMATE: CERT. OF NECESSITY

SUMMARY: PRELIMINARY ESTIMATE

2 - CHILLED WATER PUMP STUDY

QUANTITY		MATERIAL		LABOR		TOTAL COST
NO. OF UNITS	UNIT OF MEASURE	PER UNIT	TOTAL	PER UNIT	TOTAL	

BASE BID COST ESTIMATE

PRETESTING AND BALANCING OF CHILLED WATER SYSTEM	1.0	LS		\$ -	\$ 25,000.00	\$ 25,000.00	\$ 25,000.00
CHILLED WATER PUMP EVALUATION	1.0	LS		\$ -	\$ 10,000.00	\$ 10,000.00	\$ 10,000.00

COST ESTIMATE SUMMARY

DESCRIPTION	MATERIAL		LABOR		TOTAL
BASE BID TOTAL COST	\$ -		\$ 35,000.00		\$ 35,000.00
TOTAL BASE BID:	\$ -		\$ 35,000.00		\$ 35,000.00
TOTAL BASE BID COST PER SQUARE FOOT:	\$0.00 PER S.F.		\$35000.00 PER S.F.		\$35000.00 PER S.F.

GRAND TOTAL COST ESTIMATE SUMMARY

ADDITIONAL PROJECT COST ITEM DESCRIPTION (APPLIES TO BASE BID ONLY)	PERCENTAGE (%)	% X TOTAL BASE BID	REMARKS
CONTRACTOR OVERHEAD	0.0%	\$ -	
CONTRACTOR PROFIT	0.0%	\$ -	
GENERAL CONDITIONS	0.0%	\$ -	
BUILDER'S RISK INSURANCE	0.0%	\$ -	
PERMIT FEES	0.0%	\$ -	
CONTRACTOR INSURANCE	0.0%	\$ -	
PAYMENT BOND	0.0%	\$ -	
PERFORMANCE BOND	0.0%	\$ -	
TOTAL ADDITIONAL PROJECT COST ITEMS		\$ -	
GRAND TOTAL CONSTRUCTION COST (BASE BID + ADDITIONAL PROJECT COSTS)		\$ 35,000.00	