

Forsyth County Schools Cooling Towers

Equipment Item Number	Description	Location	Model Number	Serial Number	Manufacturer Name	Area Number	Date Placed in Service	Notes
00156	COOLING TOWER	Coal Mountain ES - 03	at18-69b	964002m	EVAPCO	ONE TOWER ONLY FOR SCHOOL - 131	6/1/1996	Condition - USED NOTES: 1-3B 148 BELT
26086	COOLING TOWER	Alliance Academy for Innovation - 57	UT-26-2G17	16-802612	EVAPCO		5/1/2018	
07871	COOLING TOWER	Big Creek ES - 01	ict 4 712	4-104030	EVAPCO	mechanical room CT1 - 165	3/1/2004	Condition - GOOD NOTES: heat exchanger-alfa laval 30100-70846; FILTERS: N/A; BELTS: N/A; MOTOR: emerson; RPM: 1175; HP: 3; FRAME SIZE: 213t; PHASE: 3; VOLTAGE: 230/460;
19508	COOLING TOWER	Brandywine ES - 48	UT 19-511	15-720938	EVAPCO	158- outside- CT-1	8/4/2016	Electronic fill valve, motor-weg 460v,3ph, 15hp, 1765rpm, 254T frame. Belt 1- 3B173. VFD-V-CT-1 S-Flex-m/n B07D07, type-SFD212JG4Y, power converter- ATV212HD11N4, 460v,3ph.
17615	COOLING TOWER	Brookwood ES - 47	at19-114	a-333772	EVAPCO	boiler - cooling tower	2/23/2009	Condition - NEW NOTES: N/A; FILTERS: N/A; BELTS: 4b154; MOTOR: u.s. motors; RPM: 1760; HP: 10; FRAME SIZE: 215; PHASE: 3; VOLTAGE: 480;
02487	COOLING TOWER	Chestatee ES - 02	ab61001c	159117-001-00	MARLEY	Cooling Tower CT-1 - 263	8/15/2001	Condition - USED NOTES: Marley Cooling Tower CT-1
02661	COOLING TOWER	Chestatee ES - 02	159118-001-00	av61031c	MARLEY	Cooling tower CT-2 - 429	8/15/2000	Condition - GOOD NOTES: FILTER INFO: n/a; BELT INFO: [2] bp120; MOTOR INFO: marathon ; RPM: 1725; HP: 10; FRAME SIZE: 215t; PHASE: 3; VOLTAGE: 460;  Cooling Tower - Marley CT-2
08430	COOLING TOWER	Cumming ES - 04	at-19-712	m014742	EVAPCO	outside - na	1/1/2002	Condition - GOOD NOTES: N/A; FILTERS: N/A; BELTS: 4b 158; MOTOR: emerson; RPM: 1770; HP: 20; FRAME SIZE: 256t; PHASE: 3; VOLTAGE: 460;
38057	HVAC Cooling Tower	Denmark HS - 51	UT 29-4i21	16-792652	EVAPCO	1314 Boiler room outside	7/15/2018	Cooling tower 2x motors weg 3hp 208/230/460 1175rpm 3 phase frame size 254/6t Te1df0x0n Belt # 4b180
22228	COOLING TOWER	DeSana MS - 49	AT19-512L	15-722838	EVAPCO	1228 outside mech.- CT-1	8/4/2016	Motor- Baldor,10hp,1760rpm, 460v,3ph. Drive- ABB ACH550-VDR-015A-4, ser. 2153600680. Belt- 4B158, electronic fill.
16038	COOLING TOWER	Haw Creek ES - 42	p2-1009-031	uc32970601	BALTIMORE AIR COOLER	boiler - outside	2/26/2009	Codition - NEW
13208	COOLING TOWER	Johns Creek ES - 36	15250	U064841101	BALTIMORE AIR COOLER	boiler room - @1425	7/1/2007	Condition - NEW NOTES: Baltimore Air Coil ; FILTERS: n/a; BELTS: 3R-B133; MOTOR: n/a; RPM: n/a; HP: n/a; FRAME SIZE: n/a; PHASE: 3; VOLTAGE: 460;
19202	COOLING TOWER	Kelly Mill ES - 44	AT19-114	10-405062	EVAPCO	OUTSIDE 158; MECH 158	3/5/2012	MOTOR: 4S MOTORS; 10HP, 1760 RPM, 215T FR.; 460 VOLTS, 3PH BELT=4B-154 NEW
18147	COOLING TOWER	Lakeside MS - 43	pt2-0612a-31	u082871701	BALTIMORE AIR COOLER	outside - outside boiler room	3/12/2009	Condition - NEW NOTES: N/A; FILTERS: N/A; BELTS: 2b173; MOTOR: emerson; RPM: 1760; HP: 10; FRAME SIZE: 215; PHASE: 3; VOLTAGE: 480;
15681	COOLING TOWER	Lambert HS - 41	pt2-0709a-3j2	u083315801	BALTIMORE AIR COOLER	cooling tower - cooling tower yard	7/1/2009	Condition - NEW NOTES: N/A; FILTERS: N/A; BELTS: 2-2b140; MOTOR: lesson; RPM: 1750; HP: 15; FRAME SIZE: 284t; PHASE: 3; VOLTAGE: 480;
00173	COOLING TOWER	Liberty MS - 29	at 19-712	m015374	EVAPCO	cooling tower	1/1/2002	Condition - GOOD NOTES: N/A; FILTERS: N/A; BELTS: [1] 4b-158; MOTOR: baldor; RPM: 1765; HP: 20; FRAME SIZE: 256tc; PHASE: 3; VOLTAGE: 460;
11141	COOLING TOWER	Little Mill MS - 34	at 19-99	5-275598	EVAPCO	ct-1 - outside mechanical room 1230	6/7/2007	Condition - NEW NOTES: N/A; FILTERS: N/A; BELTS: n/a; MOTOR: emmerson; RPM: 1775; HP: 20; FRAME SIZE: 256t; PHASE: 3; VOLTAGE: 460;
06149	COOLING TOWER	Mashburn ES - 05	ict 4-66	t001523	EVAPCO	mechanical - 241	1/1/2000	Codition - GOOD

Forsyth County Schools Cooling Towers

06600	COOLING TOWER	Matt ES - 28	AT 19-712	M005350	EVAPCO	mechanical -CT 1 -584	1/1/2002	Condition - GOOD NOTES: mechanical -CT 1
06116	COOLING TOWER	North Forsyth HS - 16	ICT 4-76	T002153	EVAPCO	mechanical/cooling tower CT-1 - 220	8/15/2001	Condition - GOOD NOTES: FILTER INFO: n/a; BELT INFO: n/a; MOTOR INFO: emerson; RPM: 1160; HP: 3; FRAME SIZE: 213t; PHASE: 3; VOLTAGE: 460; cooling tower CT-1
11316	COOLING TOWER	North Forsyth HS - 16	at19-56	6-302325	EVAPCO	cooling tower/ct-1 837	6/29/2007	Codition - NEW
16874	COOLING TOWER	North Forsyth HS - 16	UT19-59L	15-760086	EVAPCO	183	5/1/2016	
08520	COOLING TOWER	Otwell MS - 09	a140 f-20	258449	BALTIMORE AIR COOLER	boiler room - 606	1/1/2002	Codition - GOOD
11514	COOLING TOWER	Piney Grove MS - 38	n/a	not applicable	BALTIMORE AIR COOLER	mechanical room - out side 1230	7/1/2007	Condition - NEW NOTES: no model or serial numbers. tag had been removed; FILTERS: N/A; BELTS: N/A; MOTOR: N/A; RPM: N/A; HP: N/A; FRAME SIZE: N/A; PHASE: 3; VOLTAGE: 460;
38841	COOLING TOWERS	Pooles Mill ES - 39	UT. 19-3J11	19-862611	EVAPCO	OUTSIDE 158	1/1/2020	460 3PH BELT 3B180
08699	COOLING TOWER	Riverwatch MS - 30	34I2a-Im	u038430601	BALTIMORE AIR COOLER		1/1/2005	Codition - GOOD
02227	COOLING TOWER	Sawnee ES, Building 1 - 07 1	at 19-78	m015520	EVAPCO	outside room 194 mechanical/cooling tower - 194	1/1/2000	Condition - GOOD NOTES: FILTER INFO: n/a; BELT INFO: 3b 144; MOTOR INFO: emerson; RPM: 1760; HP: 10; FRAME SIZE: 215t; PHASE: 3; VOLTAGE: 230/460;
01458	COOLING TOWER	Sharon ES - 12	at 19-912	m025534	EVAPCO	COOLING TOWER CT-1 - Outside 1198	1/1/2002	Condition - GOOD NOTES: COOLING TOWER CT-1 already tagged 01459; Motor US Electric, 30HP, 190/360: 1465 rpm, 3ph, belt 4BX158
07755	COOLING TOWER	Shiloh Point ES - 32	NC 2503884-A1	NC 88305G1CB-05	MARLEY	CT-1	1/1/2006	Condition - NEW NOTES: Cooling tower -1 MODEL AND SERIAL THE FIRST TIME WAS NC-2503884-A1 NC88305 BOTH TOGETHER IN THE SERIAL FIELD. SECOND TIME THE MODEL AND SERIAL WAS COLLECTED WAS AS IT IS IN THE FIELDS CURRENTLY. APPLIED THERMAL RESOURCES M(NC8305) S(250384)
08491	COOLING TOWER	Silver City ES - 35	15245	u054072701	BALTIMORE AIR COOLER	outside CT-1 - 158	6/1/2006	Condition - NEW NOTES: baltimore aircoil ct-1; FILTERS: N/A; BELTS: 3r-b128; MOTOR: delta; RPM: 1775; HP: 15; FRAME SIZE: 254t; PHASE: 3; VOLTAGE: 460;
00991	COOLING TOWER	South Forsyth HS - 10	ict 4-69	4-104036	EVAPCO	Cooling Tower #1 @451	1/1/1996	Condition - GOOD NOTES: FILTER INFO: n/a; BELT INFO: n/a; MOTOR INFO: GE (2); RPM: 1175; HP: 2; FRAME SIZE: 134T; PHASE: 3; VOLTAGE: 230/460;
10070	COOLING TOWER	West Forsyth HS - 33	15325-2	u053822801	BALTIMORE AIR COOLER	ct-1 - 1717	4/1/2007	Codition - NEW
15321	COOLING TOWER	Whitlow ES - 37	pt2-1009a-211	u082314401	BALTIMORE AIR COOLER	cooling tower - 158	8/1/2008	Condition - NEW NOTES: N/A; FILTERS: N/A; BELTS: 2r-b136; MOTOR: emerson; RPM: 1775; HP: 15; FRAME SIZE: 254t; PHASE: 3; VOLTAGE: 480;