

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Bellerose Avenue Elementary
May 3, 2016

Sample Location	Source	First Draw May 3, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Kitchen Prep Sink	S	3.29
2. Cafeteria	WF	ND
3. Room 14	WF	2.51
4. Room 12	WF	ND
5. Room 11	WF	3.47
6. Room 10	WF	1.38
7. Room 9	WF	ND
8. Room 8	WF	ND
9. Room 7	WF	ND
10. Room 6	WF	1.17
11. Room 5	WF	1.47
12. Room 4A	WF	5.32
13. Room 2	WF	2.11
14. Room 1	WF	5.49
15. Hallway by Gym	WF	2.17
16. 3 rd Grade Hallway	WF	2.64
17. 4 th /5 th Grade Hallway	WF	1.40

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

S = Sink

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Dickinson Avenue Elementary
April 29, 2016

Sample Location	Source	First Draw April 29, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Room F1	WF	4.14
2. Room F2	WF	76.9
3. Room F4	S	6.85
4. Room F3	WF	20.8
5. Room F6	WF	14.5
6. Room F5	WF	6.03
7. Room D3	WF	10.6
8. Room D4	WF	2.00
9. Room E4	WF	8.01
10. Room E3	WF	2.85
11. Room E1	WF	3.83
12. Room E2	WF	3.36
13. Gym Lobby	WF	4.09
14. Room C3	WF	3.13
15. Room C2	WF	5.84
16. Room C4	WF	6.26
17. Room C1	WF	1.59
18. Room B1	WF	9.37
19. Room B2	WF	2.87
20. Room A1	WF	6.46
21. Room A4	WF	3.00
22. Room A2	WF	1.88
23. Room A3	WF	4.58
24. Room K7	WF	ND
25. Room K8	WF	2.54
26. Hallway by Room K2	WF	1.35
27. Hallway by General Office	WF	ND
28. Library	WF	7.63

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

S = Sink

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
East Northport Middle School
May 3, 2016

Sample Location	Source	First Draw May 3, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. WF by Music Office	WF	ND
2. WF by Faculty Ladies Room	WF	1.44
3. WF by Principal Office	WF	13.4
4. WF Boy's Locker Room	WF	ND
5. WF Boy's Locker Room Entry	WF	19.8
6. WF by Art South Room	WF	3.08
7. WF by Girl's Locker Room	WF	ND
8. WF by Room B114	WF	2.18
9. WF "B" Wing Hallway	WF	6.99
10. WF by North Cafeteria	WF	ND
11. WF 2 nd FL by Room G202	WF	ND
12. WF 2 nd FL "H" Wing Hallway	WF	1.48
13. WF North Cafeteria	WF	ND
14. WF South Cafeteria	WF	ND

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Fifth Avenue Elementary
May 3, 2016

Sample Location	Source	First Draw May 3, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. W.F. Room A-12	WF	3.34
2. W.F. Room A-10	WF	2.90
3. W.F. Room A-7	WF	3.97
4. W.F. Room A-8	WF	1.74
5. W.F. Room A-5	WF	3.72
6. W.F. Room A-6	WF	1.48
7. W.F. Room A-3	WF	2.63
8. W.F. Room A-4	WF	4.94
9. W.F. Room A-1	WF	4.40
10. W.F. All Purpose Room	WF	ND
11. W.F. by Room M-20	WF	ND
12. W.F. by Room C-4	WF	4.81
13. W.F. Room C9	WF	9.24
14. W.F. Room C12	WF	9.92
15. W.F. Room C11	WF	4.70
16. W.F. Room C13	WF	8.10
17. W.F. Computer Room	WF	ND
18. W.F. Music Room	WF	ND

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Laurel Avenue School
April 28, 2016

Sample Location	Source	First Draw April 28, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Hall by Rm. A207	WF	9.26
2. Hall by Rm. A201	WF	3.04
3. Hall by Rm. A121	WF	1.80
4. Hall by Rm. A108	WF	2.08
5. Hall by Rm. A111	WF	2.70
6. Hall by Rm. C101	WF	3.29
7. "C" Hall by BR's	WF	3.20
8. Hall by Rm. C115	WF	ND

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Northport High School
April 28, 2016

Sample Location	Source	First Draw April 28, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Cafeteria Left	WF	ND
2. Lower "H" Hall-West	WF	1.43
3. Lower "H" Hall-East	WF	ND
4. Lower "K" Hall-Rm K101	WF	ND
5. Lower "L" Hall-Rm L133	WF	2.25
6. Lower "L" Hall-Rm L121	WF	3.30
7. Lower "L" Hall-Rm L116	WF	3.24
8. Lower "S" Hall-Rm S124	WF	2.59
9. Lower "S" Hall-Rm S115	WF	44.3
10. Upper "S" Hall-Rm S211	WF	ND
11. Upper "L" Hall-Rm L216	WF	1.74
12. Upper "L" Hall-Rm L230A	WF	ND
13. Upper "K" Hall-Rm K202	WF	1.07
14. Upper "H" Hall-Rm H212	WF	ND
15. Upper "H" Hall-Rm H206	WF	ND
16. Hall-Landing by Library	WF	ND
17. Small Cafeteria	WF	ND
18. PE Hall-by Gym	WF	1.24
19. Boys Locker Rm-East	WF	7.45
20. PE Hall-Weight Room	WF	ND
21. Music Hall-Rm A116	WF	ND
22. Hallway by Rm A142	WF	ND
23. Hallway by Rm A111	WF	ND
24. Hallway by Rm A136	WF	ND

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Northport Middle School
May 3, 2016

Sample Location	Source	First Draw May 3, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. WF by Rm H-61	WF	ND
2. Cafeteria	WF	ND
3. Downstairs by Gym-Boys Side	WF	ND
4. Downstairs by Gym-Girls Side	WF	3.09
5. WF by Main Office	WF	2.33
6. WF by Rm N-102 (right)	WF	ND
7. WF by Rm N-102 (left)	WF	ND
8. WF by N-Wing Entrance Hall	WF	1.40
9. WF by Rm K-70	WF	ND
10. WF by Rm L-80	WF	1.44
11. Room M-88	WF	ND
12. Room M-87	WF	ND
13. Room M-89	WF	ND
14. Room M-90	WF	ND
15. Room M-92	WF	ND
16. Room M-91	WF	1.32
17. Intersection G-Wing and Main Hall	WF	ND

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Norwood Avenue Elementary
April 29, 2016

Sample Location	Source	First Draw April 29, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. All Purpose Rm	WF	ND
2. W.F. by Rm 5	WF	2.33
3. Room 5	WF	3.05
4. Room 4	WF	ND
5. Room 1	WF	8.61
6. Kindergarden A	WF	12.3
7. Kindergarden B	WF	2.99
8. C1/C2	WF	13.2
9. Room 2	WF	2.32
10. Room 3	WF	3.27
11. Room 6	WF	3.00
12. Room 27	WF	23.5
13. W.F. by Staff Rm	WF	ND
14. W.F. by Rm 18	WF	3.35
15. W.F. by Rm 17	WF	1.01
16. W.F. by Rm 28	WF	2.91
17. W.F. by Rm 10	WF	ND
18. W.F. by Rm 9	WF	1.68
19. Room 21	WF	4.88
20. Room 22	WF	6.46
21. Room 23	WF	2.71
22. Room 24	WF	3.60
23. Room 25	WF	30.9
24. Room 26	WF	3.07

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Ocean Avenue Elementary
April 29, 2016

Sample Location	Source	First Draw April 29, 2016
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. W.F. by Gym	WF	21.0
2. W.F. by Stage	WF	ND
3. W.F. by Library	WF	ND
4. Room 107	WF	7.39
5. Room 106	WF	11.2
6. Room 210	WF	5.69
7. Room 208	WF	5.61
8. Room 207	WF	11.3
9. Room 209	WF	5.78
10. W.F. by Room 203	WF	ND
11. W.F. by Room 204	WF	ND
12. Room 9	WF	13.9
13. Room 8	WF	6.90
14. Room 1	WF	4.09
15. Room 2	WF	4.12
16. Room 3	WF	322
17. Room 4	WF	1,120
18. Room 5	WF	2.45
19. Room 6	WF	4.75
20. Basement Music Room	WF	3.94

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain

Table 1
Lead in Water Analytical Results Summary
Northport-East Northport UFSD
Pulaski Road Elementary
April 28, 2016

Sample Location	Source	First Draw April 28, 2016
Lead (in micrograms per liter (ug/L) or ppb)		
1. Room A-1	WF	1.45
2. Room A-4	WF	1.17
3. Room A-3	WF	1.98
4. Room A-6	WF	2.43
5. Room A-5	WF	13.2
6. Room A-7	WF	3.21
7. Room A-8	WF	3.69
8. Room A-10	WF	1.98
9. Room B-5	WF	10.4
10. Room B-6	WF	11.2
11. Room B-3	WF	5.22
12. Room B-4	WF	3.59
13. Room B-1	WF	5.22
14. Room B-2	WF	4.00
15. W.F. by Room M-20	WF	3.32
16. W.F. by Room M-26	WF	ND
17. Room C1A	WF	185
18. Room C-6	WF	20.6
19. Room C-5	WF	195
20. Room C-10	WF	2.93
21. Room C-9	WF	2.74
22. Room C-12	WF	2.50
23. Room C-14	WF	2.59
24. Room C-13	WF	3.14
25. Room C-12	WF	ND
26. All Purpose Rm	WF	ND

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

WF = Water Fountain