



Microbac Laboratories, Inc., Newton

CERTIFICATE OF ANALYSIS

1HI0527

Osage County R-1 School District

Project Name: Mo Schools Lead Testing

Lyle Best
614 S. Poplar
Chamois, MO 65024

Project / PO Number: N/A
Received: 09/09/2024
Reported: 09/18/2024

Analytical Testing Parameters

Client Sample ID: 01-008 SW Sink
Sample Matrix: Drinking Water
Lab Sample ID: 1HI0527-01

Collected By: EB
Collection Date: 08/13/2024 9:05

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		09/10/24 1553	09/11/24 1653	RVV

Client Sample ID: 01-009 NE Sink
Sample Matrix: Drinking Water
Lab Sample ID: 1HI0527-02

Collected By: EB
Collection Date: 08/13/2024 9:09

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		09/10/24 1553	09/11/24 1659	RVV

Client Sample ID: 01-010 SE Sink
Sample Matrix: Drinking Water
Lab Sample ID: 1HI0527-03

Collected By: EB
Collection Date: 08/13/2024 9:11

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.4	0.4	ppb	2		09/10/24 1553	09/11/24 1714	RVV

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Sue Thompson

Sue Thompson
Client Services Manager
09/18/24 07:18



LABORATORIES, INC.

600 East 17th Street S
Newton, IA 50208
641-792-8451



Page 2 of 2
Printed: 8/25/2023 2:15:25PM
www.keystonelabs.com

SITE INFORMATION

Sampler:

Project:

Mo Schools Lead Testing
PWSID# Mo Schools Lead Testing

SPECIAL INSTRUCTIONS

None

Turn Around Time

☐ Standard ☐ RUSH, need by ___/___/___

REPORT

Lyle Best
Osage County R-1 School District
614 S. Poplar
Chamois, MO 65024

Lyle Best
Osage County R-1 School District
614 S. Poplar
Chamois, MO 65024

LAB USE ONLY

Work Order

1410527

Temperature

20.6

Turn-Cooler:

☒ Custody Seal
☒ Containers Intact
☒ COC/Labels Agree
☒ Preservation Confirmed
☒ Received on-site

Number

Sample Identification / Client ID

Matrix

Sample Type

Date

Time

Number of Containers

Analyses

Lab Sample Number

01-008

SW Sink

Drink Wtr

GRAB

8/13/24

9:05 AM

1

pb-t-200.8

1

01-009

NE Sink

Drink Wtr

GRAB

8/13/24

9:05 AM

1

pb-t-200.8

2

01-010

SE Sink

Drink Wtr

GRAB

8/13/24

9:11 AM

1

pb-t-200.8

3

Relinquished By

Date/Time

Relinquished By

Date/Time

Remarks:

Valid Bacteria Sample Types

Received By

Date/Time

Received for Lab By

Date/Time

Original - Lab Copy

Yellow - Sampler Copy

RT Routine
SP Special
NC New Line Ext (ONLY)
RL Replacement

RP-UP Repeat Up
RP-DN Repeat Down
RP-OR Repeat Original
RP-OT Repeat Other