

ELEVATED LEAD-IN-WATER NOTICE

November 21st, 2022

EIS Job No. 2022063

Prepared For:

**Reedsport School District
C/O Michael Schoppe
100 Ranch Rd.
Reedsport, OR 97467
Douglas County**

Prepared By:

**Environmental Inspection Services
Matthew C. Spear, Environmental Professional
11981 Fargo Road
Aurora, Oregon 97002
Cell: (503) 680-6398
E-mail: charles_a_spear@yahoo.com**




TABLE OF CONTENTS

DESCRIPTION

PAGE NO.

1.0 EXECUTIVE SUMMARY.....	1-2
-----------------------------------	------------

APPENDIXES

LEAD ANALYTICAL TEST RESULTS.	APPENDIX 1.0
SAMPLE TABLE.....	APPENDIX 2.0
SAMPLE LOCATIONS.....	APPENDIX 3.0

1.0 EXECUTIVE SUMMARY

Elevated Lead-in-Water Notice

November 21st, 2022

Sampling Location(s):

(Reedsport Community Charter School)
2260 Longwood Dr.
Reedsport, OR 97467
Douglas County

Reedsport School District
C/O Michael Schoppe

Dear Mr. Michael Schoppe,

Environmental Inspection Services conducted a comprehensive lead-in-water re-test episode at the subject Reedsport School District (RSD) buildings on Sunday, November 6th, 2022. The drinking water samples were received by Alexin Analytical Laboratory on Monday, November 7th, 2022, and analytical test results were reported to EIS on Wednesday, November 18th, 2022. Four elevated-lead in-drinking water considerations were noted for the tested faucets and fountains of the subject buildings at the following fixtures:

Sample NO.	Location	Lead Concentration (PPB)
20010100 - 084BF22A	Bathroom Under Stage	21
20010100 - 097BF22A	Girls Locker Bathroom	16
20010100 - 103DW22A	Team Room	52
20010100 - 113CF22A	Classroom (See Map)	44

The EPA Maximum Contaminant Limit (MCL) for lead in public drinking water Systems is 15 parts per billion (ppb). The EPA action limit of 15 parts per billion (ppb) was utilized as the action limit for this water sampling and testing episode. This initial first-draw drinking water sampling episode was conducted immediately following the stagnation of eight (8) hours.

A unique sample location code was assigned for each drinking water outlet sample. The attached alphanumeric sequence code was assigned for each sample. Example - the sampling code for sample No. 003 was as follows:
19000000-003BF22B - (A Water sample collected from district 1900, Building No. 0000, sample No. 098, bathroom faucet (BF), the year 2022, re-test: B.



In the opinion of EIS, we recommend that all fixtures that were initially tested over the 15-ppb action limit be replaced, or immediately disconnected until the recommended further testing occurs. Thank you for this opportunity to be of service. If there are questions concerning the lead-in-water analytical test results, contact EIS at (503) 680-6398.

Respectfully submitted,
Matthew C. Spear
Environmental Professional

A handwritten signature in black ink that reads "Matthew C. Spear". The signature is written in a cursive style with a large, stylized "M" and "S".

APPENDIXES

LEAD ANALYTICAL TEST RESULTS.	APPENDIX 1.0
SAMPLE TABLE.....	APPENDIX 2.0
SAMPLE LOCATIONS.....	APPENDIX 3.0

APPENDIX 1.0

LEAD ANALYTICAL TEST RESULTS



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-01	Sample Name: 20010100 - 074KF22A Sampled: 11/6/22 14:05 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	11/15/22 15:54
2312001-02	Sample Name: 20010100 - 075KF22A Sampled: 11/6/22 14:07 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-03	Sample Name: 20010100 - 076KF22A Sampled: 11/6/22 14:10 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/15/22 15:54
2312001-04	Sample Name: 20010100 - 077KF22A Sampled: 11/6/22 14:13 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/15/22 15:54
2312001-05	Sample Name: 20010100 - 078BF22A Sampled: 11/6/22 14:16 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	11/15/22 15:54
2312001-06	Sample Name: 20010100 - 079BF22A Sampled: 11/6/22 14:19 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-07	Sample Name: 20010100 - 080BF22A Sampled: 11/6/22 14:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-08	Sample Name: 20010100 - 081BF22A Sampled: 11/6/22 14:22 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-09	Sample Name: 20010100 - 082BF22A Sampled: 11/6/22 14:24 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-10	Sample Name: 20010100 - 083BF22A Sampled: 11/6/22 14:25 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	13	ppb	1	15 ppb	11/15/22 15:54



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-11	Sample Name: 20010100 - 084BF22A Sampled: 11/6/22 14:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	21	ppb	2	15 ppb	11/15/22 15:54 MCLE
2312001-12	Sample Name: 20010100 - 085DW22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/15/22 15:54
2312001-13	Sample Name: 20010100 - 086DW22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/15/22 15:54
2312001-14	Sample Name: 20010100 - 087BF22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-15	Sample Name: 20010100 - 088BF22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	11/15/22 15:54
2312001-16	Sample Name: 20010100 - 089BF22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/15/22 15:54
2312001-17	Sample Name: 20010100 - 090BF22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/15/22 15:54
2312001-18	Sample Name: 20010100 - 091BF22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/15/22 15:54
2312001-19	Sample Name: 20010100 - 092BF22A Sampled: 11/6/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/15/22 15:54
2312001-20	Sample Name: 20010100 - 093BF22A Sampled: 11/6/22 14:35 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/15/22 15:54



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-21	Sample Name: 20010100 - 094BF22A Sampled: 11/6/22 14:36 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-22	Sample Name: 20010100 - 095BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/15/22 15:54
2312001-23	Sample Name: 20010100 - 096BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/15/22 15:54
2312001-24	Sample Name: 20010100 - 097BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	16	ppb	1	15 ppb	11/15/22 15:54 MCLE
2312001-25	Sample Name: 20010100 - 098BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/15/22 15:54
2312001-26	Sample Name: 20010100 - 099BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/15/22 15:54
2312001-27	Sample Name: 20010100 - 100BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-28	Sample Name: 20010100 - 101DW22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	11/17/22 16:15
2312001-29	Sample Name: 20010100 - 102BF22A Sampled: 11/6/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	11/17/22 16:15
2312001-30	Sample Name: 20010100 - 103DW22A Sampled: 11/6/22 15:15 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	52	ppb	4	15 ppb	11/17/22 16:15 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-31	Sample Name: 20010100 - 104DW22A Sampled: 11/6/22 15:16 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-32	Sample Name: 20010100 - 105CF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	11/17/22 16:15
2312001-33	Sample Name: 20010100 - 106BF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15
2312001-34	Sample Name: 20010100 - 107BF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/17/22 16:15
2312001-35	Sample Name: 20010100 - 108BF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15
2312001-36	Sample Name: 20010100 - 109BF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-37	Sample Name: 20010100 - 110BF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-38	Sample Name: 20010100 - 111BF22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-39	Sample Name: 20010100 - 112DW22A Sampled: 11/6/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	11/17/22 16:15
2312001-40	Sample Name: 20010100 - 113CF22A Sampled: 11/6/22 15:25 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	44	ppb	4	15 ppb	11/17/22 16:15 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-41	Sample Name: 20010100 - 114CF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/17/22 16:15
2312001-42	Sample Name: 20010100 - 115BF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-43	Sample Name: 20010100 - 116SF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15
2312001-44	Sample Name: 20010100 - 117BF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	11/17/22 16:15
2312001-45	Sample Name: 20010100 - 118CF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	11/17/22 16:15
2312001-46	Sample Name: 20010100 - 119CF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-47	Sample Name: 20010100 - 120CF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/17/22 16:15
2312001-48	Sample Name: 20010100 - 121CF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15
2312001-49	Sample Name: 20010100 - 122CF22A Sampled: 11/6/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	11/17/22 16:15
2312001-50	Sample Name: 20010100 - 123CF22A Sampled: 11/6/22 15:40 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	13	ppb	1	15 ppb	11/17/22 16:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-51	Sample Name: 20010100 - 124DW22A Sampled: 11/6/22 15:45 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	11/17/22 16:15
2312001-52	Sample Name: 20010100 - 125DW22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-53	Sample Name: 20010100 - 126DW22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-54	Sample Name: 20010100 - 127BF22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-55	Sample Name: 20010100 - 128BF22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-56	Sample Name: 20010100 - 129BF22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-57	Sample Name: 20010100 - 130BF22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-58	Sample Name: 20010100 - 131DW22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-59	Sample Name: 20010100 - 132DW22A Sampled: 11/6/22 15:50 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	11/17/22 16:15
2312001-60	Sample Name: 20010100 - 133DW22A Sampled: 11/6/22 15:55 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

C L I E N T Environmental Inspection Services

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-61	Sample Name: 20010100 - 134BF22A Sampled: 11/6/22 15:56 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-62	Sample Name: 20010100 - 135BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-63	Sample Name: 20010100 - 136BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-64	Sample Name: 20010100 - 137BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15
2312001-65	Sample Name: 20010100 - 138BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-66	Sample Name: 20010100 - 139BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-67	Sample Name: 20010100 - 140BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-68	Sample Name: 20010100 - 141BF22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	11/17/22 16:15
2312001-69	Sample Name: 20010100 - 142DW22A Sampled: 11/6/22 16:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15
2312001-70	Sample Name: 20010100 - 143CF22A Sampled: 11/6/22 16:05 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	11/17/22 16:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/18/2022
Received: 11/07/2022
Sampled By: Mathew Spear
Work Order: 2312001

**C
L
I
E
N
T** **Environmental Inspection Services**

Attn: Mathew Spear
430 N. 1st Street
Carlton OR, 97111
Phone: (503) 680-6398

Project: RSD LIW

Project # : -

Sample Type : Grab

Sampling Location: RCCS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2312001-71	Sample Name: 20010100 - 144CF22A Sampled: 11/6/22 16:06 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-72	Sample Name: 20010100 - 145CF22A Sampled: 11/6/22 16:07 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15
2312001-73	Sample Name: 20010100 - 146SF22A Sampled: 11/6/22 16:09 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	11/17/22 16:15

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director

APPENDIX 2.0

SAMPLE TABLE

[illegible]

[illegible]

Environmental Inspection Services	Lead School	-	Alexin Analytical Laboratories, Inc.	20010100 - 143CF22A	2312001-70
Environmental Inspection Services	Lead School	-	Alexin Analytical Laboratories, Inc.	20010100 - 144CF22A	2312001-71
Environmental Inspection Services	Lead School	-	Alexin Analytical Laboratories, Inc.	20010100 - 145CF22A	2312001-72
Environmental Inspection Services	Lead School	-	Alexin Analytical Laboratories, Inc.	20010100 - 146SF22A	2312001-73

APPENDIX 3.0

SAMPLE LOCATIONS