



Kelly Walsh High School

Operation and Maintenance Manuals

Division 26 – Electrical – Volume II

Project: Kelly Walsh High School
3500 East 12th street
Casper, Wyoming 82609
(307) 253-2000

Owner: Natrona County School District
1038 North Glenn Road
Casper, Wyoming 82601
(307) 253-5317

Electrical Contractor: Casper Electric

Construction Manager: Sampson Construction
2701 Westland Court, Suite A
Cheyenne, Wyoming 82001
(307) 426-4050

Architect: RB+B Architect's
315 E. Mountain Avenue Suite 100
Fort Collins, Colorado 80524-2913
(970) 484-0117

Commissioning Authority: Beaudin Ganze Consulting Engineers
1626 Cole Boulevard, Suite 300
Lakewood, Colorado 80401
(303) 278-3820 Ext. 5407

Electrical Engineer: Engineering Design Associates
1607 CY Avenue
Casper, WY 82604
(307) 266-5033

October, 2015


**SHORT-CIRCUIT,
OVERCURRENT DEVICE COORDINATION, &
ARC FLASH HAZARD ANALYSES****Kelly Walsh HS
Casper, WY**Prepared by
Christopher Bowden
Elizabeth Kersh, P.E.
Schneider Electric Engineering Services, LLC
Wyoming Firm No. E-1081

Job Number Q2C: 34765053	-	July 14, 2014
	Rev. 1	-
	Rev. 2	-
	Rev. 3	-

ELECTRICAL CONTRACTOR**Casper Electric****DISTRIBUTOR****Crescent Elec Sup****SQUARE D FIELD ENGINEER****Christopher Bowden / Denver, CO**

This document has been authorized for release by the engineer whose seal and signature are hereto affixed. Altering this document is unlawful unless performed by or under the direction of a licensed professional engineer. Any changes shall be described and the engineer authorizing such alterations shall seal, sign, and date the revised document.

FILE: 34765053_Kelly Walsh HS



DISCLAIMER

The following report was prepared by the Power System Engineering group of Schneider Electric Engineering Services, LLC (SEES) utilizing industry-accepted standards and practices along with the proprietary methodologies and analysis tools of SEES. Data used in this analysis was acquired by Power System Engineering and provided by others, through onsite discovery, published information, equipment nameplates, manufacturer ratings, testing, analysis, or other means. SEES assumes no responsibility for inaccuracies in data provided by others. The study is intended for use by qualified individuals to facilitate the installation, operation, maintenance, and safety of the electrical power system depicted. Modification of equipment, changes to system configuration, adjustment of protective device settings, or failure to properly maintain equipment may invalidate these results.

The stylized trademarks “Square D” and “Schneider Electric” and any other trademarks and trade names that are the property of Schneider Electric USA, Inc are used by permission.

TABLE OF CONTENTS

1	EXECUTIVE SUMMARY	4
1.1	Overview	4
1.2	Revision History	4
1.3	Study Highlights	5
1.3.1	Short-Circuit Results	5
1.3.2	Coordination Results	5
1.3.3	Arc Flash Results	6
2	INTRODUCTION	7
3	SYSTEM FINDINGS	8
3.1	Electrical System Description	8
3.2	Study Analysis	8
3.2.1	Short-Circuit	8
3.2.2	Coordination	8
3.2.3	Arc Flash	10
4	SHORT-CIRCUIT ANALYSIS	11
4.1	General Procedure	11
4.2	Data Used in the Calculations	13
4.2.1	Power Company Data	13
4.2.2	Generator Data	13
4.2.3	Cable Data	13
4.2.4	Transformer Data	13
4.2.5	Assumptions and Estimates	14
4.2.6	Motor Contribution To Short-Circuit Current	14
4.3	Short-Circuit Analysis Results and Recommendations	15
4.4	Short-Circuit Evaluation Tables	17
5	OVERCURRENT DEVICE COORDINATION ANALYSIS	21
5.1	General Procedure	21
5.2	Specific Procedure	22

5.2.1	Short-Circuit Current Considerations	22
5.2.2	Molded Case Breaker Coordination.....	22
5.2.3	Low-Voltage Ground Fault Relay Settings.....	24
5.2.4	Transformer Protective Devices	25
5.2.5	Cable Protection.....	26
5.2.6	Selective Coordination and the National Electric Code	26
5.2.7	Assumptions and Estimates	27
5.3	Analysis of Results and Recommendations.....	28
5.3.1	TCC Plot Remarks	28
5.4	Overcurrent Device Setting Tables.....	32
5.5	Time-Current Coordination Graphs - Recommended Settings.....	38
6	ARC FLASH HAZARD ANALYSIS	67
6.1	General Procedure	67
6.2	Specific Procedure	68
6.3	AF Hazard Analysis Results and Recommendations.....	70
6.3.1	Arc Flash Hazard Table Headings Guide and PPE Table.....	71
6.3.2	Arc Flash Hazard Analysis Table – Recommended Settings	74
6.4	Power System Engineering Arc Flash Labeling Practice	78
6.4.1	Arc Flash Information Labels	78
6.4.2	General Safety Labels	80
APPENDIX A: ABBREVIATIONS AND TRADEMARKS.....		82
APPENDIX B: SHORT CIRCUIT INPUT TABULATIONS		84
APPENDIX C: SHORT CIRCUIT OUTPUT TABULATIONS		101
APPENDIX D: REFERENCES		121
APPENDIX E: SYSTEM STUDY ONE-LINE DIAGRAM.....		153

1 EXECUTIVE SUMMARY

1.1 Overview

This report documents the results of a Power System Engineering analysis for the Kelly Walsh HS in Casper, WY. The objective of this section is to briefly summarize the results of the analysis and highlight key issues and findings in the electrical distribution equipment. For items addressed by equipment, conductor, or device settings changes, the power system study results may need to be re-evaluated in a revision to this study. The full analysis can be found in the main body of the report.

The scope of this study is limited to that equipment shown on the study one-line diagram located in the back of the report. Unless specifically required by job specifications, branch circuit utilization equipment, as defined per NEC Article 100, was not included in this study (this may consist of small equipment, 100A and less, such as: safety switches, industrial control panels, and enclosed starters/drives).


1.2 Revision History

This section will document revision history after the initial study has been submitted. Subsequent revision numbers are each listed on the front cover of the report and are explained below by indicating the following details: date of issue, reason for revision, and who initiated the revision. When necessary, engineer's comments and/or pertinent emails will be referred to in the references section of the report.

1.3 Study Highlights

1.3.1 Short-Circuit Results

Of the device locations evaluated for adequacy to interrupt or withstand the maximum three-phase short-circuit current to which they could be subjected, none were identified to be INADEQUATE.




Graph of equipment short-circuit capability

1.3.2 Coordination Results

Setting recommendations have been made for the adjustable devices, to ensure optimum selectivity, reduce arc flash, or protect equipment. Overall, the coordination study showed that acceptable levels of selectivity were achieved among devices in the system except as shown on TCC-12 E1B1, TCC-13 E1B1, TCC-21 MDPH2, TCC-22 E2B1, TCC-23 E2B1, EMER TCC-01 and EMER TCC-02.

1.3.3 Arc Flash Results

Equipment locations were analyzed to determine the level of arc flash incident energy to which a worker might be exposed during an arc flash event. The majority of locations were determined to be category 0 (lowest). The highest category for which personal protective equipment may be used is category 4. It is not recommended work be performed live for equipment with the “Over 40 cal./cm²” designation (seven locations).



Graph of arc flash hazard category occurrence

2 INTRODUCTION

This report has the following components:

- ☒ Studies were performed using Power*Tools for Windows Software, version 7.0.3.3 Build 1.
- ☒ The system short-circuit analysis evaluates the adequacy of the distribution equipment shown on the enclosed one-line diagrams to withstand or to interrupt the calculated maximum available short-circuit current at its location.
- ☒ The overcurrent device time-current coordination analysis determines the suggested settings and, where appropriate, the ampere ratings and types for the electrical power system protective devices to achieve the desired system protection and electrical service continuity goals.
- ☒ The flash hazard analysis establishes the arc flash boundary around electrical equipment within which a worker exposed to an arcing fault would expect to receive 2nd degree burns if not adequately protected. The analysis also determines the incident energy levels at specific working distances from equipment, which can be used to select appropriate personal protective equipment (PPE) to be worn when working within the arc flash boundary.
- ☒ This report supersedes and invalidates results from any prior study for the scope of equipment being reviewed.
- ☒ Electrical system changes within the facility or in the utility system can have a significant impact on the results of this power system analysis, which is a “snapshot” of as-found system conditions. As such, it is recommended that this analysis be re-evaluated on a regular basis, not to exceed 5 years, to account for electrical system changes. NFPA 70B and 70E address the issue of equipment maintenance and failure to properly maintain equipment may invalidate these results
- ☒ A “REFERENCES” section near the end of the report cites who supplied information or how the data was obtained. The majority of this data is filed with the project and has not been reproduced in this report. Abbreviations and trademarks referenced throughout this report are also listed in an appendix.

3 SYSTEM FINDINGS

3.1 Electrical System Description

UTC_MDPH1 and UTC_MDPH2 are fed by 1,500 kVA utility transformers.

200 kW Generator feeds two ATS's in the event power is lost to the normal service. The two ATS's; feeds panels E1B1 and E2B.

3.2 Study Analysis

Refer to each of the following sections for details. If issues are addressed by equipment, conductor, or device settings changes, the power system study results may need to be re-evaluated in a revision to this study.

3.2.1 Short-Circuit

The results of the short-circuit analysis show that the equipment considered in the study is adequately rated for the projected fault current levels.

3.2.2 Coordination

Recommendations for equipment changes can result in equipment which is larger in ampacity and/or physical footprint, may require changes to other parts of the electrical design (e.g., cable and conduit sizing), and could also impact the architectural design. For Square D distribution equipment, examples are NF panel to an I-Line panel, or a smaller I-Line to a larger I-Line. Recommendations are made for reasons such as coordination issues, protection violations, or transformer magnetic inrush concerns. When selective coordination, according to NEC 700, is required, further analysis beyond the scope of this study will be necessary as well as possible equipment construction or design changes.

Many protective devices are adjustable and were set for optimum operation. The coordination study showed for the most part, acceptable levels of selectivity were achieved among devices in the system except as shown on TCC-12 E1B1, TCC-13 E1B1, TCC-21 MDPH2, TCC-22 E2B1, TCC-23 E2B1, EMER TCC-01 and EMER TCC-02.

Based on the current system configuration the emergency system does not selectively coordinate to .1 seconds. The devices have been optimized to provide the highest level of selectivity possible for the equipment and system design. Where improved selectivity is required, breaker types need to be evaluated per selectivity tables, published in the current revision of the Schneider Electric data bulletin 0100DB0501, and other system design changes may need to be considered.

TCC-12 E1B1:

Time-current coordination graph shows device numbers 303-01 and 303-02 as well as other devices. The equipment designations for the installed devices are: MDPH1 and E1B1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 303-01, ED thermal magnetic to JD LI 3.2.

TCC-13 E1B1:

Time-current coordination graph shows device numbers 306-01 and 306-02 as well as other devices. The equipment designations for the installed devices are: E1BL1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 306-01, QOB thermal magnetic to JD LI 3.2 and 306-02, QOB thermal magnetic to HD LI 3.2

TCC-21 MDPH2:

Time-current coordination graph shows device numbers 308-01 E2B1 MCB and 308-04 as well as other devices. The equipment designations for the installed devices are: E2B1. As shown by the graph, these devices do not selectively coordinate well. DPB2_L1E device has been adjusted to obtain the highest level of selectivity possible for the protection level required. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 308-01 E2B1 MCB, JG thermal magnetic to JG LI 3.2 and 308-04, EG thermal magnetic to HG LI 3.2.

TCC-22 E2B1:

Time-current coordination graph shows device numbers 313-04 and 316-03 as well as other devices. The equipment designations for the installed devices are: E2B1 and E2B2. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 313-01, ED thermal magnetic to HD LI 3.2.

TCC-23 E2B1:

Time-current coordination graph shows device numbers 308-02 and 309-02 as well as other devices. The equipment designations for the installed devices are: E2B1 and E2BL1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 308-02, EG thermal magnetic to HG LI 3.2.

TCC-23 E2B1:

Time-current coordination graph shows device numbers 309-01 E2BL1 MCB and 309-02 as well as other devices. The equipment designations for the installed devices are: E2B1. As shown by the graph, these devices do not selectively coordinate well. 309-01 E2BL1 MCB device has been adjusted to obtain the highest level of selectivity possible for the protection level required. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 309-01 E2BL1 MCB, JD thermal magnetic to JD LI 3.2.

TCC-23 E2B1:

Time-current coordination graph shows device numbers 309-02 and 310-02 as well as other devices. The equipment designations for the installed devices are: E2BL1 and E2BL2. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 309-02, QO-VH thermal magnetic to HD LI 3.2 and 310-02, QOB to EDB thermal magnetic.

EMER TCC-01:

Time-current coordination graph shows device numbers 300-02 GEN SEC_ATS_E1B1 and 303-03 as well as other devices. The equipment designations for the installed devices are: GEN SEC and E1B1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 300-02 GEN SEC_ATS_E1B1, JGE thermal magnetic to FDE 310+ LS.

EMER TCC-02:

Reference selective coordination comment on time-current coordination graph **TCC-21 MDPH2:**

The breakers in the system should be set to the recommended levels found in the Overcurrent Device Setting Tables section.

3.2.3 Arc Flash

The results of the arc flash analysis show both the calculated arc flash incident energy (AFIE) and arc flash boundary distances at each bus under study.

Overly conservative available fault current values should not be used solely for an arc flash analysis. Therefore, three arc flash fault current scenarios were considered. The first consisted of a high utility source 80,000 Amps at 13.2kV, based on maximum fault current. The second considered a minimum utility source 1,531Amps at 13.2kV, available fault current assumed. The third was a generator source for equipment fed by the emergency generator. All arc flash scenarios were considered with motor loads turned off and on to find the worst case. The results of all the scenarios were combined into one composite table showing the worst case results for each piece of equipment evaluated.

It is recognized that recommendations in this report may not be implemented simultaneously. It is Customer's responsibility to apply and update labels as recommendations are implemented or as conditions change.

There were seven locations where the arc flash incident energy level is greater than 40 cal/cm² which is considered the upper limit defined by NFPA 70E. Flash hazard levels at (100 UTC_MDPH1, 101 MDPH1, 108 SDPL1, 200 UTC2_MDPH2, 201 MDPH2, 213 SDPH21 and 229 SDPH22) exceeded 40 cal/cm², and this equipment is reported as "Dangerous" in the Flash Hazard Table. The arcing fault current must be cleared by the upstream utility transformer primary fuse. Equipment protected by a transformer primary overcurrent device generally results in long trip delay times which cannot be adjusted lower because of the load and/or transformer inrush, or due to limitations or non-adjustability of the protective device. Knowing the actual device information for this project is not likely to result in any improvement at this equipment location.

- Work should not be performed on 100 UTC_MDPH1 and 200 UTC2_MDPH2 without first opening and locking out power on the primary side of the Utilities service transformer.
- Work should not be performed on 101 MDPH1, 108 SDPL1, 201 MDPH2, 213 SDPH21 and 229 SDPH22 without first opening and locking out power on the protective device that feeds each equipment.

The arc flash hazard analysis and recommended PPE levels are no substitutes for safe work practices. As stated in NFPA 70E, burn injuries can occur even when adequate PPE is employed, and the recommended PPE may provide little or no protection against arc blast and its effects. Protection from arc flash can best be provided by working only on circuits or equipment that have been placed in an electrically safe work condition. Work should not be performed on or near equipment listed "Dangerous" unless it has been placed in an electrically safe work condition.

4 SHORT-CIRCUIT ANALYSIS

4.1 General Procedure

An electrical system short-circuit analysis is used for the following:

- 1) To compare the calculated maximum fault current with the interrupting ratings of overcurrent protective devices such as fuses and circuit breakers.
- 2) To investigate applicable short-circuit series ratings and the protection of electrical equipment by current-limiting devices.
- 3) To verify the adequacy of other equipment, such as switches and equipment bussing, to withstand the effects of the calculated maximum fault current levels.
- 4) To assist in the selection and/or determination of settings for relays, fuses and circuit breakers.
- 5) To provide input (along with device trip characteristics) to an arc flash hazard analysis.

This analysis was made utilizing SKM Power Tools software. The software was programmed to calculate the maximum available three-phase, RMS symmetrical, short-circuit amperes at each piece of equipment in the system. The calculation procedures are based on recommendations included in ANSI/IEEE standards C37.13, C37.010, and C37.5.

The AFAULT module of the Power*Tools software simulates a bolted three-phase fault at each point of consideration in the system and calculates the maximum available short-circuit current at that point without any reduction due to current-limiting overcurrent devices which may be present. (However, the effects of current-limiting devices are considered when determining the adequacy of the equipment.) The calculated short-circuit values are RMS symmetrical amperes and are comparable with the RMS symmetrical short-circuit ratings of electrical equipment.

Electrical distribution equipment must be able to withstand and/or interrupt the most severe fault duty that it may be subjected to at its location in the system. In particular, NEC Section 110.9

requires circuit breakers to have a rating sufficient for interrupting the maximum available fault current present at their line side terminals. For locations where calculated fault currents exceed the ratings of the equipment, recommendations for corrective actions are provided.

Equipment short-circuit withstand and interrupting ratings are expressed in symmetrical RMS current. However, fault currents are not purely symmetrical in practice, as system inductance introduces a degree of asymmetry for at least the first few cycles of a fault. The magnitude and duration of this asymmetrical component depends on several factors, including characteristics of system components (conductors, transformers, and loads) and the exact point on the current waveform that the fault begins—the level of asymmetry even differs from phase to phase in a three-phase system. Because of the uncertainty in asymmetry for a given fault event, the capability of devices to interrupt asymmetrical fault current is based on the maximum possible asymmetrical fault current level at the point of application. The more inductive the circuit, as measured by the calculated system X/R ratio, the more asymmetrical the fault current can be. If the calculated X/R level exceeds a certain level, then the increased asymmetrical duty must be taken into account when breaker ratings are assessed.

Low-voltage circuit breakers and fuses are tested to establish their interrupting ratings based on a circuit with a fixed X/R ratio, as defined in the various product standards (UL and ANSI). For example, an ANSI low-voltage power circuit breaker is tested in a circuit with an X/R ratio of 6.591. If such a breaker is applied at a system bus with a calculated X/R ratio of 6.591 or less and the calculated RMS symmetrical fault current is within the symmetrical interrupting rating of the breaker, then it is assumed that the breaker is also able to interrupt and withstand the asymmetrical current resulting from a fault at that location. If a low voltage breaker is applied at a location with an X/R ratio greater than that of the design test circuit, the calculated fault current must be multiplied by an adjustment factor that accounts for this. This resultant “fault duty,” which is greater than the calculated fault current, is then compared to the breaker’s interrupting rating in order to determine if the breaker is adequately rated. Different classes of low-voltage breakers have different test X/R values, and each type has its own set of multiplication factors. Design test circuit power factors and associated X/R ratios are as shown in **Table 1**. The SKM low-voltage short-circuit output report shows the calculated fault duty levels calculated at each bus, and when these values differ from the calculated short-circuit current levels, they are used in the device evaluation tables. See IEEE 1015-1997, *IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems*, for additional details.

Table 1: Summary of Test Power Factor and X/R Values for LV Devices.

Device	pf	X/R Ratio
Power circuit breaker, unfused	0.15	6.591
Power circuit breaker, fused	0.20	4.899
Molded case breaker, interrupting rating greater than 20000 A	0.15-0.20	6.591-4.899
Molded case breaker, interrupting rating 10001 to 20000 A	0.25-0.30	3.9-3.18
Molded case breaker, interrupting rating 10000 A and less	0.45-0.50	2.0-1.732

For power circuit breakers, the power factors are taken from ANSI/IEEE C37.13. For molded case breakers, the power factors are taken from NEMA standard AB1. Since the NEMA standard specifies a range of test circuit power factors, the highest value (lowest X/R ratio) is used to determine the multiplying factor. This produces the most conservative (largest) factor.

The included one-line diagram is a simplified version of the system drawings, showing only those parts of the electrical system under consideration. The various circuit locations on the diagram

have been labeled with bus identification numbers so input data could be supplied to the computer and the computer output could be readily interpreted.

4.2 Data Used in the Calculations

4.2.1 Power Company Data

The maximum available three-phase short-circuit current at the 1,500 KVA service point was calculated to be 34,594A at 480V. An X/R ratio of 8 was assumed for this current. This short-circuit current was obtained from an infinite-source calculation and determined the starting point for the short-circuit analysis. No minimum or alternate switching levels were given.

4.2.2 Generator Data

It has been determined that the 200kW generator has a subtransient reactance of 15% with an 80% PF and an estimated X/R ratio of 12.40 at 480V. The calculated maximum available bolted three-phase RMS symmetrical short-circuit current at the point of common coupling to the system (i.e. ATS) is considerably higher from the normal source compared to the generator source. The "Short Circuit Evaluation Table" is based on the higher source calculations. Therefore, all equipment determined to be adequate under normal utility supply conditions will also be adequate when the generator is in operation.

4.2.3 Cable Data

The "FEEDER INPUT DATA" computer printouts list the conductor (cable and/or busway) data used for each circuit segment. Included are lengths, number per phase, size, conductor material, cable insulation type, conduit material and resistance and reactance values. Also, conductor lengths, number per phase, and size and conductor material are recorded on the one-line diagram.

Resistance values are based on 25 degrees Celsius (room temperature) rather than the full load temperature usually shown in descriptive literature since short-circuits can occur when the circuit is initially energized or lightly loaded as well as when fully loaded. The resistance and reactance values are typical values obtained from a study of data from various conductor manufacturers. Values are tabulated according to whether several single conductors or one multiple conductor is used and whether the conduit is steel, aluminum or plastic.

4.2.4 Transformer Data

Schneider Electric nameplate transformer percent impedance and typical X/R ratio values were used for all the low voltage transformers. The exact R and X component values used are shown on the "TRANSFORMER INPUT DATA" printouts.

4.2.5 Assumptions and Estimates

Some assumptions, or estimates, were required and may affect the results of this study. In general, assumptions, or estimates, are needed because of limited access, safety concerns in obtaining equipment nameplate data, or lack of documentation. Significant differences between the assumptions, or estimates, listed here and actual values will require that this power system analysis be revised.

The following assumptions, or estimates, were made for the reasons given above:

- Where motor loads were not given, motors sized per NEC table 430.15 were used in this analysis. MDPH1 and MDPH2 motor loads are sized per 25% of the utility transformers kVA
- Transformer MD/G X/R was assumed.
- Utility fuse type and size was assumed.

4.2.6 Motor Contribution To Short-Circuit Current

Motor contribution to the short-circuit current is taken into account in this short-circuit analysis. During the first few cycles of a fault, running motors act as generators and produce a current which will combine with the source short-circuit current flowing to the fault as illustrated in **Figure 1**. Sources may be, but are not limited to, the Power Company, local generators, or both.




Figure 1: Example motor contribution.

Connected motors shown on the study one-line were assumed to be running at the time of the fault. Motors fed by adjustable speed drives equipped with bypass contactors were considered to contribute to system fault currents as well. However, motors fed by drives without bypass contactors were not considered since they do not contribute to fault current. Redundant motors shown on the study one-line were also assumed to be running at the time of the fault unless operating controls prohibit these conditions.

A motor's contribution to a fault *at its terminals* is equal to the full-load ampere (FLA) rating of the motor divided by its per-unit subtransient reactance, similar to the contribution from a generator. However, at the upstream switchboard, panelboard, or motor-control center, the fault contribution from the individual motors is reduced by the impedance of the motor branch circuit conductors. Since data on motor subtransient reactances and branch-circuit conductor lengths is often difficult to obtain, assumptions regarding the motors' subtransient reactances are typically made when the system model is built.

For calculation of low-voltage fault duty, the contribution from induction motors and synchronous motors in the system are considered. For small induction motors (less than 50 hp) where the impedance of the installation (i.e., motor and conductor) is not known, an equivalent subtransient reactance of 0.25 pu, resulting in a fault contribution of 4 times rated current, is assumed. Larger motors (50 hp and above) have an assumed subtransient reactance of 0.2 pu, resulting in a fault contribution of 5 times rated current. This is consistent with recommendations in IEEE Std. 141, *IEEE Recommended Practice for Electric Power Distribution for Industrial Plants* (the IEEE Red Book).

If applicable, multiplying factors are adjusted per Table 7 of ANSI/IEEE C37.010, *IEEE Application Guide for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis* for medium/high voltage fault duty. The table also shows contributions from induction motors less than 50 hp to be neglected.

The motor short-circuit contribution is determined and included in the computer short-circuit analysis so that the results should represent the highest short-circuit current to which the equipment might be subjected.

Unless otherwise indicated in the "CONTRIBUTION DATA" computer printouts, some motor loads are modeled as lumped induction motors connected directly to the low voltage buses using the recommended subtransient reactance values from C37.010, C37.13, and IEEE Std. 141. These modeled values appear on the "CONTRIBUTION DATA" and the "FAULT REPORT" computer printouts.

4.3 Short-Circuit Analysis Results and Recommendations

After making the calculations, the distribution equipment was checked to determine its adequacy to interrupt or withstand the effects of the calculated maximum short-circuit current at its location. For some solidly-grounded systems, like close-coupled unit substations and generator gear, it is possible the bolted three-phase fault current is not the maximum fault current. The power systems engineer performing the study considered applicable buses and has reported bolted line-to-ground fault current when required. The results are listed in the "SHORT-CIRCUIT EVALUATION TABLE".

Short-circuit case description(s): The Short circuit analysis is based upon the actual/maximum available fault current being provided to the system.

Listed in the tables are the calculated short-circuit currents at each piece of equipment and the ratings of the lowest rated device in the equipment enclosure. Comparing the two sets of values shows that all of the equipment examined is either adequate by itself or when used in series with another circuit breaker or protected by a line side current-limiting fuse or circuit breaker.

If applicable, equipment using series ratings that are shown in the short-circuit evaluation table must meet field labeling requirements per NEC Sections 110.22 and 240.86(B). There are two types of markings which must be present; the first requires series combination ratings to be marked on equipment by the manufacturer. The second equipment marking must be readily visible and state the following:

CAUTION – SERIES COMBINATION SYSTEM RATED _____ AMPERES.
IDENTIFIED REPLACEMENT COMPONENTS REQUIRED.

This labeling serves as a warning to those who may install new breakers or replace existing breakers at the given location in the future, alerting them to the fact that a specific device type must be used in order to ensure that the series rating is maintained.

Input data and short-circuit output data pages are included in separate appendices.

4.4 Short-Circuit Evaluation Tables



POWER SYSTEM ENGINEERING

SHORT-CIRCUIT
EVALUATION TABLE

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
100	UTC_MDPH1	480.0	NW-H	100,000	37,875	8.108			Adequate	
101	MDPH1	480.0	JG	35,000	34,667	6.462			Adequate	
102	H1L1	480.0	EDB(1P)	18,000	27,263	2.761	LG	35,000	Adequate	
103	H1L2	480.0	EDB(1P)	18,000	16,148	1.039	HG	35,000	Adequate	
104	H1L3	480.0	EDB(1P)	18,000	15,160	1.340	JG	35,000	Adequate	
105	H1L4	480.0	EDB(1P)	18,000	16,748	1.583	LG	35,000	Adequate	
106	MD/G	208.0	THQB	10,000	7,936	2.272			Adequate	
107	G/GA	208.0	QOB-VH	22,000	6,864	2.021			Adequate	
108	SDPL1	208.0	FH(3P)	65,000	23,911	4.898			Adequate	
109	L1M1	208.0	QOB	10,000	2,688	0.670			Adequate	
110	L1L1	208.0	QOB(1P)/15-30A	10,000	17,385	2.570	LD	25,000	Adequate	
111	L1L2	208.0	QOB(1P)/15-30A	10,000	14,738	2.145	LG	65,000	Adequate	
112	L1L3	208.0	QOB(1P)/15-30A	10,000	10,956	1.164	LD	25,000	Adequate	
113	L1L31	208.0	QOB(1P)/15-30A	10,000	9,241	0.984	QOB-VH	22,000	Adequate	
114	L1L4	208.0	QOB(1P)/15-30A	10,000	5,335	0.909	QG	65,000	Adequate	
115	L1L5	208.0	QOB(1P)/15-30A	10,000	5,422	1.112	QG	65,000	Adequate	
116	L1L6	208.0	QOB(1P)/15-30A	10,000	7,102	0.630	QG	65,000	Adequate	
117	L1B1	208.0	QOB(1P)/15-30A	10,000	13,179	1.037	QG	65,000	Adequate	
118	L1B2	208.0	QOB(1P)/15-30A	10,000	2,534	0.353	QG	65,000	Adequate	
119	H1B1	480.0	EDB(1P)	18,000	15,630	0.782	EGB	35,000	Adequate	
200	UTC2_MDPH2	480.0	NW-H	100,000	35,170	7.161			Adequate	
201	MDPH2	480.0	JG	35,000	33,669	6.439			Adequate	
202	SDPL2	208.0	LG	65,000	16,266	3.330			Adequate	
203	L2M1	208.0	FH(3P)	65,000	12,232	2.242			Adequate	
204	L2M11	208.0	QOB(1P)/15-30A	10,000	10,145	1.906	LG	65,000	Adequate	
205	L2M2	208.0	QOB(1P)/15-30A	10,000	10,481	1.466	LG	65,000	Adequate	
206	L2M21	208.0	QOB(1P)/15-30A	10,000	6,695	0.705	HD	25,000	Adequate	
207	L2B2	208.0	QOB(1P)/15-30A	10,000	8,773	1.351	QG	65,000	Adequate	
208	L2B1	208.0	QOB(1P)/15-30A	10,000	10,105	0.988	QG	65,000	Adequate	
209	H2M1	480.0	EDB(1P)	18,000	19,068	1.703	JG	35,000	Adequate	
210	H2M2	480.0	EDB(1P)	18,000	20,652	1.717	LG	35,000	Adequate	
211	H2B2	480.0	EDB(1P)	18,000	29,137	3.802	LG	35,000	Adequate	
212	H2B1	480.0	EGB	35,000	13,489	0.583			Adequate	
213	SDPH21	480.0	FH(3P)	25,000	17,799	1.716			Adequate	
214	H21B1	480.0	EDB	18,000	11,096	0.733			Adequate	



POWER SYSTEM ENGINEERING

SHORT-CIRCUIT
EVALUATION TABLE

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
215	H21M1	480.0	EDB	18,000	9,258	0.682			Adequate	
216	H21U1	480.0	EDB	18,000	7,290	0.560			Adequate	
217	SDPL21	208.0	FH(3P)	65,000	13,877	2.387			Adequate	
218	L21U1	208.0	QOB(1P)/15-30A	10,000	6,532	0.859	QG	65,000	Adequate	
219	L21U2	208.0	QOB(1P)/15-30A	10,000	3,446	0.602	QG	65,000	Adequate	
220	L21U3	208.0	QOB(1P)/15-30A	10,000	5,557	0.770	QG	65,000	Adequate	
221	L21U4	208.0	QOB(1P)/15-30A	10,000	3,811	0.629	QG	65,000	Adequate	
222	L21U5	208.0	QOB(1P)/15-30A	10,000	6,931	0.899	QG	65,000	Adequate	
223	L21M1	208.0	QOB(1P)/15-30A	10,000	4,445	0.949	QG	65,000	Adequate	
224	L21M11	208.0	QOB(1P)/15-30A	10,000	3,905	0.816	QG	65,000	Adequate	
225	L21M2	208.0	QOB(1P)/15-30A	10,000	6,532	0.859	QG	65,000	Adequate	
226	L21M3	208.0	QOB(1P)/15-30A	10,000	5,113	1.002	QG	65,000	Adequate	
227	L21M4	208.0	QOB(1P)/15-30A	10,000	8,450	1.070	QG	65,000	Adequate	
228	L21B1	208.0	QOB-VH	22,000	10,685	1.131			Adequate	
229	SDPH22	480.0	FH(3P)	25,000	15,945	2.154			Adequate	
230	H22B1	480.0	EDB	18,000	12,178	1.072			Adequate	
231	H22M1	480.0	EDB	18,000	4,595	0.372			Adequate	
232	H22U1	480.0	EDB	18,000	8,900	0.888			Adequate	
233	SDPL22	208.0	FH(3P)	65,000	13,565	2.658			Adequate	
234	L22U1	208.0	QOB(1P)/15-30A	10,000	6,166	0.858	QG	65,000	Adequate	
235	L22U2	208.0	QOB(1P)/15-30A	10,000	5,554	0.798	QG	65,000	Adequate	
236	L22U3	208.0	QOB(1P)/15-30A	10,000	4,437	0.698	QG	65,000	Adequate	
237	L22U4	208.0	QOB(1P)/15-30A	10,000	5,845	0.826	QG	65,000	Adequate	
238	L22U5	208.0	QOB(1P)/15-30A	10,000	5,290	0.773	QG	65,000	Adequate	
239	L22M1	208.0	QOB(1P)/15-30A	10,000	6,166	0.858	QG	65,000	Adequate	
240	L22M2	208.0	QOB(1P)/15-30A	10,000	5,290	0.773	QG	65,000	Adequate	
241	L22M3	208.0	QOB(1P)/15-30A	10,000	5,290	0.773	QG	65,000	Adequate	
242	L22M4	208.0	QOB(1P)/15-30A	10,000	5,049	0.751	QG	65,000	Adequate	
243	L22M5	208.0	QOB(1P)/15-30A	10,000	5,787	1.101	QG	65,000	Adequate	
244	L22M6	208.0	QOB(1P)/15-30A	10,000	4,624	0.714	QG	65,000	Adequate	
245	L22B1	208.0	QOB	10,000	6,612	0.622			Adequate	
300	GEN SEC	480.0	SCCR35	35,000	2,325	12.400			Adequate	
301	ATS_E1B1	480.0	SCCR50	50,000	12,790	0.648			Adequate	
302	ATS_E2B1	480.0	SCCR50	50,000	22,152	1.597			Adequate	



POWER SYSTEM ENGINEERING

**SHORT-CIRCUIT
EVALUATION TABLE**

**KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502**

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
303	E1B1	480.0	EDB	18,000	10,773	0.564			Adequate	
304	E1L1	480.0	EDB	18,000	3,143	0.201			Adequate	
305	E1L2	480.0	EDB	18,000	2,885	0.296			Adequate	
306	E1BL1	208.0	QOB	10,000	1,787	0.783			Adequate	
307	E1BL2	208.0	QOB	10,000	1,618	0.705			Adequate	
308	E2B1	480.0	EGB	35,000	19,271	1.302			Adequate	
309	E2BL1	208.0	QOB	10,000	2,981	1.100			Adequate	
310	E2BL2	208.0	QOB	10,000	1,491	0.730			Adequate	
311	E2BL3	208.0	QOB	10,000	1,005	0.573			Adequate	
312	E2M1	480.0	EDB(1P)	18,000	3,716	0.222	EGB	35,000	Adequate	
313	E2B2	480.0	EDB(1P)	18,000	2,924	0.351	EGB	35,000	Adequate	
314	E2M3	480.0	EDB	18,000	1,911	0.250			Adequate	
315	E2U1	480.0	EDB	18,000	1,758	0.236			Adequate	
316	E2B3	480.0	EDB	18,000	1,786	0.295			Adequate	
317	E2M2	480.0	EDB	18,000	1,137	0.212			Adequate	
318	E2U2	480.0	EDB	18,000	1,080	0.205			Adequate	

5 OVERCURRENT DEVICE COORDINATION ANALYSIS

5.1 General Procedure

An overcurrent device time-current coordination analysis is an organized effort to determine the settings and, where appropriate, the ampere ratings and types for the over-current protective devices in an electrical system. The objective of the coordination analysis is to effect a time-current coordination among the devices, thereby achieving the desired system protection and electrical service continuity goals.

Maximum protection requires that the overcurrent protective devices be rated, selected, and adjusted to allow the normal load currents to flow while instantaneously opening the circuit when abnormal currents flow.

However, maximum service continuity requires that the overcurrent protective devices be rated, selected, and adjusted so that only the overcurrent protective device nearest the fault opens and isolates the faulted circuit from the system, permitting the rest of the system to remain in operation. Protective devices farther from the fault location should therefore essentially act as backup protection for the devices nearer to the fault, allowing the fault to be cleared with a minimum of disruption to the system. This is referred to as “coordination” between the protective devices. This may allow longer duration faults when the fault point is nearer the service entrance; however, such faults are not as common, and setting the protective devices to operate in this manner is generally more desirable than deenergizing most or all of the system for a fault near one of the loads.

Selecting and setting the overcurrent devices is a procedure where the time-current characteristic curves of the various devices in series are compared with one another on a log-log graph. This procedure should take into account boundaries defined by load currents, short-circuit currents, and ANSI and NEC requirements.

Coordination usually will be obtained when the log-log plots of time-current characteristics show sufficient clear space or no overlap between the curves for the protective devices operating in series. Coordination will often stop short of complete selectivity when an acceptable compromise is reached between the various boundaries imposed on the selecting and setting procedure.

The CAPTOR module of the SKM Power*Tools software was used to complete the device coordination analysis. As shown on the one-line diagram, each overcurrent protective device or motor under consideration by the program has been assigned an identification number so that the computer output could be readily interpreted.

5.2 Specific Procedure

5.2.1 Short-Circuit Current Considerations

All protective device characteristic curves shown on the time-current graphs end at the calculated maximum short-circuit current at that device.

5.2.2 Molded Case Breaker Coordination

A molded case circuit breaker will trip with no intentional time delay for short-circuit currents above its instantaneous trip setting. Because of this, molded case breakers in series can only be selectively coordinated with each other if there is sufficient impedance between them so that the maximum available short-circuit current at the downstream breaker is less than the instantaneous trip setting of the upstream breaker. In **Figure 2**, breaker “C” illustrates this principle.




Figure 2: Example molded case breaker coordination.

There is enough cable impedance to limit the maximum available short-circuit current at “C” to less than the instantaneous trip setting of either “A” or “B”. When molded case breakers are in series without sufficient impedance between them to permit complete coordination, e.g., a panel main breaker and one of the branch devices in the panel, the time-current curves will overlap in the high-current instantaneous trip region. This is illustrated by the overlap between the curves for

devices “A” and “B” in **Figure 2**. Most molded case breakers exhibit some degree of current limitation that will often result in selective operation in the overlap region. Time-current coordination curves included in this report do not match the results from the latest edition of the Schneider Electric data bulletin 0100DB0501. The software used to generate the curves is incapable of accounting for the dynamic impedance the system has when two or more devices in series “see” a fault. The data bulletin takes the dynamic impedance introduced by the downstream device into account. Greater separation between the instantaneous settings may increase the likelihood that the two devices will operate selectively. The potential lack of coordination is generally not considered critical and can be avoided only by adopting a different and, in general, less economically practical design especially when the following are considered:

- Most faults occur in equipment such as motors, lighting panels, and process control panels which typically are located at the end of branch circuits, significantly reducing fault level and thereby reducing or eliminating the possibility of non-selective operation.
- Lower magnitude arcing faults in rotating machinery and lighting panels are statistically more common than bolted three-phase faults.
- Ground faults are more common than three-phase faults.
- Maximum fault current is a random event depending on point-on-wave of the fault occurrence and other factors.
- The device cutoff points on time-current coordination graphs are based on bolted fault current levels which correspond to zero impedance. Typical fault current impedance is usually greater than zero so the actual fault current seen by overcurrent devices can be less than what is shown on the time-current coordination graphs.

Recommended breaker trip settings are given in the "OVERCURRENT DEVICE SETTING TABLE – LV CIRCUIT BREAKERS". In addition, an illustration of the actual magnetic trip adjustment dials for Schneider Electric circuit breakers is included in the REFERENCES section to aid the setting process.

5.2.3 Low-Voltage Ground Fault Relay Settings

The main ground fault time setting was chosen to coordinate with the appropriate load side devices. The ground fault current pickup setting has been shown set both at minimum and at maximum.

Best equipment protection is achieved by a minimum current setting but best coordination with load side protective devices is achieved by a maximum current setting. However, it should be noted even with the ground fault current pickup set maximum, coordination with downstream breakers does not exist for any ground fault current exceeding this maximum pickup setting but less than the magnetic setting of the load side breaker. This is unavoidable because the load side protective devices are not equipped with ground fault protection. **Figure 3** illustrates this.




Figure 3: Example ground fault coordination (current scale X 10).

As shown in **Figure 3**, the main ground fault device A set at minimum does not coordinate with feeder breaker B for ground fault currents in the range of 140A - 1,310A as indicated. Even with

A set at maximum, it will not coordinate with breaker B for ground fault currents in the range of 425A - 1,310A as indicated.

All ground fault settings are tabulated in the appropriate overcurrent device setting tables.

5.2.4 Transformer Protective Devices

If in the project scope, medium- and/or low-voltage transformer primary overcurrent protective devices were checked for compliance with NEC Article 450. Also, medium voltage protective devices, primary, secondary and secondary feeder, were evaluated with respect to the applicable ANSI/IEEE Through Fault Guides (C57.12.59 for dry and cast resin type and C57.109 for liquid immersed type) and the Appendix for ANSI/IEEE C37.91. Transformer standards define low-voltage transformers as having a primary voltage less than or equal to 600V. Transformer full load currents and magnetizing inrush currents were also considered.

If a transformer is subject to a through fault, thermal damage occurs to conductors and insulation due to resistive heating. Mechanical damage occurs to windings and structural components due to large magnetic forces associated with the fault current. In general, smaller transformers are assigned a single damage characteristic that accounts for both thermal and mechanical damage. Larger transformers are assigned a two-part characteristic with a thermal characteristic and a more restrictive mechanical characteristic. For the most conservative protection, the thermal-mechanical limits should be used. In many cases, it may be acceptable to use only the thermal characteristic, especially if the transformer is not subject to frequent through faults. Transformers connected to overhead secondary feeders should be considered to be subject to frequent through faults.

To evaluate through fault protection according to the ANSI Guides, the applicable curve was plotted representing a transformer's projected damage threshold for the cumulative effects of through faults. However, this ANSI through fault curve must be reduced for certain unbalanced secondary faults, because even though full short-circuit current is flowing in one or more secondary windings, the primary overcurrent device experiences less current.

Secondary line-to-neutral faults on delta-wye connected transformers produce only 0.577 of the maximum 3-phase fault current in the primary overcurrent device while one secondary winding experiences the full short-circuit current as illustrated in **Figure 4** below. Therefore, to account for this fault condition, the ANSI through fault curve has been adjusted by a factor of 0.577. Both curves (three phase line-to-line and single phase line-to-neutral) are plotted on the time-current graphs.




Figure 4: Delta-Wye 3-PH and L-N fault current per unit values.

Since the through fault curves represent a transformer's projected damage threshold for the cumulative mechanical and thermal effects of through faults, all applicable primary and secondary

overcurrent devices were checked to ensure interruption before these through fault curves were reached.

Further, to avoid nuisance interruptions, the primary overcurrent devices were also checked to ensure they will carry the transformers rated full load and equivalent magnetic inrush currents which are plotted on the time-current graphs.

Because of the restrictions mentioned above, coordination between the transformer primary and secondary main devices may not exist for any transformers examined as shown by the overlapping of their characteristics on the time-current graphs. However, this is judged acceptable, because the opening of either device results in the same extent of service interruption.

5.2.5 Cable Protection

Feeder overcurrent protective devices were reviewed to verify the protection of their load side cables as shown on the one-line diagram in accordance with NEC Article 240. If the adjustable low-voltage protective devices are set as suggested in this report, then the cables reviewed will be properly protected.

It is not possible to damage the phase conductor during short-circuits below the AIC rating of the breaker protecting the phase conductor when a low-voltage phase conductor is properly sized per NEC 240. UL tests to verify the short-circuit rating of a circuit breaker are performed considering 75°C cable. The corresponding phase conductor is sized according to the NEC and must pass the fault tests without compromising its integrity. Therefore, the ICEA cable withstand curves have not been included on the time-current coordination graphs.

5.2.6 Selective Coordination and the National Electric Code

In some situations, even though individual devices are not coordinated, the system may still be considered to be well-coordinated. For example, where two devices are in series with no loads connected between them, operation of either/both devices interrupts power to the exact same portion of the power system. The system may be considered to be coordinated even though the two devices, strictly speaking, do not coordinate with one another.

Selective coordination, while always desirable, is not required by the NEC except in certain situations:

- In health-care facilities, per NEC 517.17(C): “Ground-fault protection for operation of the service and feeder disconnecting means shall be fully selective such that the feeder device, but not the service device, shall open on ground faults on the load side of the feeder device.”
- In elevator circuits when more than one elevator motor is fed by a single feeder. See NEC 620.62.
- In emergency and legally-required standby power systems (including those in hospitals and other health-care facilities where so required), per NEC 700.27 and NEC 701.27.

- In critical operations power systems (COPS) such as, but not limited to, power systems, HVAC, fire alarm, security, communications, and signaling; refer NEC 708.54. Generally, these are facilities or parts of facilities that require continuous operation for reasons of public safety, emergency management, national security, or business continuity.

The requirements for selective coordination in emergency and legally-required standby systems, call for each overcurrent device to be “selectively coordinated with all supply side overcurrent protective devices.” This requirement can be problematic for system designers because it recognizes only device coordination and not system coordination. Special consideration of selective coordination (beyond the traditional coordination study) must be given when the system is initially designed, since for both fusible and circuit-breaker based systems, designs that are otherwise NEC compliant may not meet the selective coordination requirements of the NEC.

Time-current coordination curves included in this report do not match the results from the latest edition of the Schneider Electric data bulletin 0100DB0501. The software used to generate the curves is incapable of accounting for the dynamic impedance the system has when two or more devices in series “see” a fault. The data bulletin takes the dynamic impedance introduced by the downstream device into account.

Compliance with NEC articles 517.17 (Health Care Facilities), 700.27 (Emergency Systems), 701.27 (Legally Required Standby Systems), and 708.54 (Critical Operations Power Systems) may require interpretation and approval by the local authority having jurisdiction. The most common interpretations related to the extent of selective coordination have been either 0.1 seconds or total selectivity.

5.2.7 Assumptions and Estimates

Some assumptions, or estimates, were required and may affect the results of this study. In general, assumptions, or estimates, are needed because of limited access, safety concerns in obtaining equipment nameplate data, or lack of documentation. Significant differences between the assumptions, or estimates, listed here and actual values will require that this power system analysis be revised.

The following assumptions, or estimates, were made for the reasons given above:

1. MD/G low-voltage transformer the X/R and magnetic inrush was assumed.

5.3 Analysis of Results and Recommendations

The basic results of an overcurrent device coordination analysis are the time-current coordination graphs which are plotted to illustrate the degree of coordination achieved in the system. 28 graphs are included in this report. Settings for devices which have adjustable characteristics are summarized in the appropriate overcurrent device setting tables. Smaller devices with fixed time-current characteristics are not shown on the graphs unless they directly affect the setting of an adjustable upstream device.

It is assumed the impedance ground return path for the equipment grounding conductors (EGCs) and conduit for equipment rated 600V and less exhibit very low impedance levels—generally much less than 0.25 ohms for circuits 50A and larger; and can be in that range when larger sized EGCs are used. Although design and installation standards are intended to provide a ground return path with suitably low impedance, failure to maintain the ground return path with suitably low impedance will affect the ability for ground fault relays to operate as designed and intended. This impedance is not to be confused with the resistance to remote earth of a grounding electrode system, which is often specified in the 3-5 ohm range and does not impact whether ground fault devices operate properly. IEEE Std 1100 (Emerald Book) provides recommended maximum impedance values for EGCs and IEEE 81 provides test methods for measuring resistance to remote earth of a grounding electrode system. Field measurements may result in additional engineering and field work to correct the grounding system. Field testing and analysis are outside of the scope of work for this project.

To generate the time-current graphs, a computer program was used which allows the power system engineer to determine optimum coordination, after first insuring that loading and protection requirements are satisfied. The engineer's objective is to determine the best coordination for the entire system. This approach necessitates tradeoffs in selectivity for some parts of the system to achieve maximum coordination in more critical areas. Regions in which coordination has been sacrificed are as previously discussed involving transformer primary and secondary main devices, high current regions of molded case breakers, etc.

5.3.1 TCC Plot Remarks

The following comments refer to the graphs shown in the Time Current Coordination Graphs section of this report.

TCC-01 MDPH1:

Time-current coordination graph shows device numbers 101-08 MDPH1_XFMR_SDPL1 and 108-01 SDPL1 MCB as well as other devices. The equipment designations for the installed devices are: MDPH1 and SDPL1 As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-01 MDPH1:

Time-current coordination graph shows device numbers 108-04 SDPL1_L1L2 and 111-01 L1L2 MCB as well as other devices. The equipment designations for the installed devices are: SDPL1 and L1L2. As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-05 MDPH1:

Time-current coordination graph shows device numbers 101-05 and 103-02 as well as other devices. The equipment designations for the installed devices are: MDPH1 and H1L1. As shown by the graphs, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination.

TCC-06 SDPL1:

Time-current coordination graph shows device numbers 108-03 SDPL1_L1L1 and 110-01 L1L1 MCB as well as other devices. The equipment designations for the installed devices are: SDPL1 and L1L1. As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-07 SDPL1:

Time-current coordination graph shows device numbers 108-05 SDPL1_L1L3 and 112-01 L1L3 MCB as well as other devices. The equipment designations for the installed devices are: SDPL1 and L1L3. As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-07 SDPL1:

Time-current coordination graph shows device numbers 112-02 and 113-02 as well as other devices. The equipment designations for the installed devices are: L1L3 and L1L31. As shown by the graphs, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination.

TCC-10 SDPL1:

Time-current coordination graph shows device numbers 108-10 and 118-02 as well as other devices. The equipment designations for the installed devices are: SDPL1 and L1B2. As shown by the graphs, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination.

TCC-11 SDPL1:

Time-current coordination graph shows device numbers 101-09 and 119-01 as well as other devices. The equipment designations for the installed devices are: SDPL1 and H1B1. As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-12 E1B1:

Time-current coordination graph shows device numbers 303-01 and 303-02 as well as other devices. The equipment designations for the installed devices are: MDPH1 and E1B1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 303-01, ED thermal magnetic to JD LI 3.2.

TCC-13 E1B1:

Time-current coordination graph shows device numbers 306-01 and 306-02 as well as other devices. The equipment designations for the installed devices are: E1BL1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 306-01, QOB thermal magnetic to JD LI 3.2 and 306-02, QOB thermal magnetic to HD LI 3.2.

TCC-14 MDPH2:

Time-current coordination graph shows device numbers 229-02 SDPH22_SDPL22 and 233-01 SDPL22 MCB as well as other devices. The equipment designations for the installed devices are: SDPH22 and SDPL22. As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-15 SDPL21:

Time-current coordination graph shows device numbers 217-07 and 223-02 as well as other devices. The equipment designations for the installed devices are: SDPL21 and L21M1. As shown by the graphs, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination.

TCC-20 SDPL2:

Time-current coordination graph shows device numbers 205-02 and 206-01 as well as other devices. The equipment designations for the installed devices are: L2M2 and L2M21. As shown by the graph, these devices overlap. However, these devices are in series and the loss of selectivity is acceptable as operation of either device affects the same portion of the system and full coordination is not required. This allows better coordination between these devices and the ones upstream and downstream.

TCC-21 MDPH2:

Time-current coordination graph shows device numbers 308-01 E2B1 MCB and 308-04 as well as other devices. The equipment designations for the installed devices are: E2B1. As shown by the graph, these devices do not selectively coordinate well. DPB2_L1E device has been adjusted to obtain the highest level of selectivity possible for the protection level required. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 308-01 E2B1 MCB, JG thermal magnetic to JG LI 3.2 and 308-04, EG thermal magnetic to HG LI 3.2.

TCC-22 E2B1:

Time-current coordination graph shows device numbers 313-04 and 316-03 as well as other devices. The equipment designations for the installed devices are: E2B1 and E2B2. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 313-01, ED thermal magnetic to HD LI 3.2.

TCC-23 E2B1:

Time-current coordination graph shows device numbers 308-02 and 309-02 as well as other devices. The equipment designations for the installed devices are: E2B1 and E2BL1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 308-02, EG thermal magnetic to HG LI 3.2.

TCC-23 E2B1:

Time-current coordination graph shows device numbers 309-01 E2BL1 MCB and 309-02 as well as other devices. The equipment designations for the installed devices are: E2B1. As shown by the graph, these devices do not selectively coordinate well. 309-01 E2BL1 MCB device has been adjusted to obtain the highest level of selectivity possible for the protection level required. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 309-01 E2BL1 MCB, JD thermal magnetic to JD LI 3.2.

TCC-23 E2B1:

Time-current coordination graph shows device numbers 309-02 and 310-02 as well as other devices. The equipment designations for the installed devices are: E2BL1 and E2BL2. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 309-02, QO-VH thermal magnetic to HD LI 3.2 and 310-02, QOB to EDB thermal magnetic.

TCC-24 MDPH1:

Time-current coordination graph shows device numbers 101-07 MDPH1_H1L4 and 105-02 H1L4_XFMR_MD/G as well as other devices. The equipment designations for the installed devices are: MDPH1 and H1L4. As shown by the graph, these devices do not coordinate well. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

TCC-25 MDPH1:

Time-current coordination graph shows device numbers 106-03 MD/G_G/GA and 107-02 as well as other devices. The equipment designations for the installed devices are: MD/G and G/GA. As shown by the graph, these devices do not selectively coordinate well. 106-03 MD/G_G/GA device has been adjusted to obtain the highest level of selectivity possible for the protection level required.

EMER TCC-01:

Time-current coordination graph shows device numbers 300-02 GEN SEC_ATS_E1B1 and 303-03 as well as other devices. The equipment designations for the installed devices are: GEN SEC and E1B1. As shown by the graph, these devices do not coordinate well; however, these are fixed devices and cannot be adjusted to improve coordination. If improving selective coordination is required for this particular circuit and we recommend to upgrading device 300-02 GEN SEC_ATS_E1B1, JGE thermal magnetic to FDE 310+ LS.

EMER TCC-02:

Reference selective coordination comment on time-current coordination graph **TCC-21 MDPH2:**

5.4 Overcurrent Device Setting Tables



POWER SYSTEM ENGINEERING

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

DEVICE		DESCRIPTION			SETTINGS						
BUS NUMBER & NAME	DEVICE NUMBER & NAME	MANUFACTURER & TYPE	BUS VOLTAGE	FRAME SENSOR PLUG	LONG TIME		SHORT TIME		INST	GROUND	
					PICKUP	DELAY	PICKUP	DELAY (I ² T)		PICKUP	DELAY (I ² T)
100 UTC_MDPH1	100-02 UTC_MDPH1	SQUARE D Masterpact NW, 5.0 & 6.0 A/P/H LSI, 400-6000AS, UL	480.0V	3000.0A 3000.0A	1	8	5 (15000A)	0.1 (I ² t Off)	15 (45000A)	D (800A)	0.2 (I ² t Off)
101 MDPH1	101-02 MDPH1_ACC-3	SQUARE D JG 150-250A	480.0V	250.0A 175.0A					LO (875A)		
101 MDPH1	101-03 MDPH1_ACC-2	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	480.0V	600.0A 600.0A 600.0A	450 (450A)	16 sec			5 (3000A)		
101 MDPH1	101-04 MDPH1_H1L1	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	480.0V	400.0A 400.0A 400.0A	400 (400A)	16 sec			4 (1600A)		
101 MDPH1	101-06 MDPH1_H1L3	SQUARE D JG 150-250A	480.0V	250.0A 225.0A					LO (1125A)		
101 MDPH1	101-07 MDPH1_H1L4	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	480.0V	600.0A 600.0A 600.0A	500 (500A)	16 sec			8 (4800A)		
101 MDPH1	101-08 MDPH1_XFMR_SDPL1	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	480.0V	1200.0A 1000.0A	1	Fixed			10 (10000A)		
102 H1L1	102-02 H1L1 FEEDER	SQUARE D JG 150-250A	480.0V	250.0A 200.0A					LO (1000A)		
105 H1L4	105-02 H1L4_XFMR_MD/G	SQUARE D LA (10/04) 125-400A, 2-3 poles	480.0V	400.0A 300.0A					HI (3000A)		



POWER SYSTEM ENGINEERING

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

DEVICE		DESCRIPTION			SETTINGS						
BUS NUMBER & NAME	DEVICE NUMBER & NAME	MANUFACTURER & TYPE	BUS VOLTAGE	FRAME SENSOR PLUG	LONG TIME		SHORT TIME		INST	GROUND	
					PICKUP	DELAY	PICKUP	DELAY (I ² T)		PICKUP	DELAY (I ² T)
106 MD/G	106-02 MD/G Feeder	GE TJK 125-600A	208.0V	400.0A 400.0A					HI (4000A)		
106 MD/G	106-03 MD/G_G/GA	GE TFJ 70-225A	208.0V	225.0A 200.0A					HI (2000A)		
108 SDPL1	108-01 SDPL1 MCB	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	208.0V	2500.0A 2000.0A	1	Fixed			5 (10000A)		
108 SDPL1	108-03 SDPL1_L1L1	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	208.0V	600.0A 600.0A 600.0A	600 (600A)	2 sec			8 (4800A)		
108 SDPL1	108-04 SDPL1_L1L2	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	208.0V	600.0A 600.0A 600.0A	600 (600A)	8 sec			8 (4800A)		
108 SDPL1	108-05 SDPL1_L1L3	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	208.0V	400.0A 400.0A 400.0A	400 (400A)	2 sec			8 (3200A)		
110 L1L1	110-01 L1L1 MCB	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	208.0V	600.0A 600.0A 600.0A	600 (600A)	2 sec			8 (4800A)		
111 L1L2	111-01 L1L2 MCB	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	208.0V	600.0A 600.0A 600.0A	600 (600A)	8 sec			8 (4800A)		
112 L1L3	112-01 L1L3 MCB	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	208.0V	400.0A 400.0A 400.0A	400 (400A)	2 sec			8 (3200A)		



POWER SYSTEM ENGINEERING

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

DEVICE		DESCRIPTION			SETTINGS						
BUS NUMBER & NAME	DEVICE NUMBER & NAME	MANUFACTURER & TYPE	BUS VOLTAGE	FRAME SENSOR PLUG	LONG TIME		SHORT TIME		INST	GROUND	
					PICKUP	DELAY	PICKUP	DELAY (I ² T)		PICKUP	DELAY (I ² T)
200 UTC2_MDPH2	200-02 UTC2_MDPH2	SQUARE D Masterpact NW, 5.0 & 6.0 A/P/H LSI, 400-6000AS, UL	480.0V	3000.0A 3000.0A	1	8	5 (15000A)	0.1 (I ² t Off)	15 (45000A)	D (800A)	0.2 (I ² t Off)
201 MDPH2	201-03 MDPH2_XFMR_SDPL2	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	480.0V	600.0A 600.0A 600.0A	600 (600A)	8 sec			11 (6600A)		
201 MDPH2	201-04 MDPH2_ACC-1	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	480.0V	600.0A 600.0A 600.0A	450 (450A)	16 sec			8 (4800A)		
201 MDPH2	201-05 MDPH2_H2M1	SQUARE D JG 150-250A	480.0V	250.0A 225.0A					LO (1125A)		
201 MDPH2	201-06 MDPH2_H2M2	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	480.0V	400.0A 400.0A 400.0A	400 (400A)	0.5 sec			3 (1200A)		
201 MDPH2	201-07 MDPH2_H2B2	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	480.0V	400.0A 400.0A 400.0A	400 (400A)	0.5 sec			3 (1200A)		
201 MDPH2	201-09 MDPH2_SDPH21	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	480.0V	1200.0A 1000.0A	1	Fixed			8 (8000A)		
201 MDPH2	201-10 MDPH2_SDPH22	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	480.0V	1200.0A 1000.0A	1	Fixed			10 (10000A)		
202 SDPL2	202-01 SDPL2 MCB	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	208.0V	1200.0A 1200.0A	1	Fixed			4 (4800A)		



POWER SYSTEM ENGINEERING

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

DEVICE		DESCRIPTION			SETTINGS						
BUS NUMBER & NAME	DEVICE NUMBER & NAME	MANUFACTURER & TYPE	BUS VOLTAGE	FRAME SENSOR PLUG	LONG TIME		SHORT TIME		INST	GROUND	
					PICKUP	DELAY	PICKUP	DELAY (I ² T)		PICKUP	DELAY (I ² T)
202 SDPL2	202-02 SDPL2_L2M1	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	208.0V	600.0A 600.0A 600.0A	600 (600A)	1 sec			5 (3000A)		
202 SDPL2	202-03 SDPL2_L2M2	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	208.0V	400.0A 400.0A 400.0A	400 (400A)	8 sec			8 (3200A)		
203 L2M1	203-02 L2M1_L2M11	SQUARE D PowerPact L-Frame, 3.3 LI, 400AS	208.0V	400.0A 400.0A 400.0A	300 (300A)	0.5 sec			4 (1600A)		
213 SDPH21	213-02 SDPH21_SDPL21	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	480.0V	600.0A 600.0A 600.0A	600 (600A)	8 sec			11 (6600A)		
217 SDPL21	217-01 SDPL21 MCB	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	208.0V	1200.0A 1200.0A	1	Fixed			4 (4800A)		
229 SDPH22	229-02 SDPH22_SDPL22	SQUARE D PowerPact L-Frame, 3.3 LI, 600AS	480.0V	600.0A 600.0A 600.0A	600 (600A)	8 sec			11 (6600A)		
233 SDPL22	233-01 SDPL22 MCB	SQUARE D Powerpact R/P-Frame, 1.0I LI, 250-2500A, UL	208.0V	1200.0A 1200.0A	1	Fixed			4 (4800A)		
300 GEN SEC	300-02 GEN SEC_ATS_E1B1 REC	CUTLER-HAMMER FDE/FDCE/HFDE, 310+ LS, 80-225AS, I2T	480.0V	225.0A 160.0A 125.0A	F (125) (125A)	7	12 (1500A)	Fixed (I ² t Off)	Fixed (1920A)		
300 GEN SEC	300-02 GEN SEC_ATS_E1B1	CUTLER-HAMMER JG, Series G 80-250A, Adj. Mag, IEC	480.0V	100.0A 100.0A					10X (1000A)		





POWER SYSTEM ENGINEERING

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502

DEVICE		DESCRIPTION			SETTINGS						
BUS NUMBER & NAME	DEVICE NUMBER & NAME	MANUFACTURER & TYPE	BUS VOLTAGE	FRAME SENSOR PLUG	LONG TIME		SHORT TIME		INST	GROUND	
					PICKUP	DELAY	PICKUP	DELAY (I ² T)		PICKUP	DELAY (I ² T)
300 GEN SEC	300-03 GEN SEC_ATS_E2B1	CUTLER-HAMMER JG, Series G 80-250A, Adj. Mag, IEC	480.0V	250.0A 225.0A					10X (2250A)		
308 E2B1	308-01 E2B1 MCB REC	SQUARE D PowerPact J-Frame, 3.2 LI, 70-250A	480.0V	250.0A 250.0A 250.0A	150 (150A)	16 sec			10 (2500A)		
308 E2B1	308-01 E2B1 MCB	SQUARE D JG 150-250A	480.0V	250.0A 150.0A					HI (1500A)		
308 E2B1	308-02 REC	SQUARE D PowerPact H-Frame, 3.2 LI, 100AS	480.0V	150.0A 100.0A 100.0A	100 (100A)	8 sec			12 (1200A)		
309 E2BL1	309-01 E2BL1 MCB	SQUARE D JD 150-250A	208.0V	250.0A 200.0A					HI (2000A)		
313 E2B2	313-04 REC	SQUARE D PowerPact H-Frame, 3.2 LI, 150AS	480.0V	150.0A 150.0A 150.0A	60 (60A)	4 sec			12 (1800A)		

5.5 Time-Current Coordination Graphs - Recommended Settings





TCC: GROUND 1



Current Scale x 10



Reference Voltage: 480
39 of 155



July 21, 2014



CURRENT IN AMPERES













































CURRENT IN AMPERES























































6 ARC FLASH HAZARD ANALYSIS

6.1 General Procedure

Over the past two decades, the electrical industry has begun to recognize arc flash as a safety hazard for personnel working near exposed, energized conductors. Ralph Lee is credited with raising the awareness of this hazard in a technical paper entitled “The Other Electrical Hazard: Electric Arc Blast Burns,” *IEEE Transactions on Industry Applications*, Vol. 1A-18, No. 3, May-June 1982. Lee’s paper presented a theoretical model for calculating the distance-energy relationship for electrical arc exposure. The hazard was later further quantified through controlled testing on 600V systems which included the effect of an enclosure in reflecting heat from the arc toward the opening of the enclosure. Curve fitting was applied to the test data and the resulting algorithms were published in a technical paper by R. L. Doughty, T. E. Neal, and H. L. Floyd, entitled “Predicting Incident Energy to Better Manage the Electric Arc Hazard on 600V Power Distribution Systems,” *Proceedings of the IEEE Petroleum and Chemicals Industry Conference*, Paper No. 98-36, 1998. These models provide the basis for performing flash hazard analysis per NFPA 70E-2012, *Standard for Electrical Safety in the Workplace*.

IEEE Std. 1584-2002, *IEEE Guide for Performing Arc-Flash Hazard Calculations*, presents a more comprehensive methodology for arc flash hazard analysis. This standard, based on extensive testing carried out on low-voltage and medium-voltage systems (to 15kV), is applicable to a wider range of systems than previous calculation methods. For systems above 15kV, where sufficient test data is not yet available, IEEE 1584 relies on the Lee method for calculation of arcing energy levels. The results presented in this report are based solely on the IEEE 1584 calculation procedures. IEEE 1584 is applicable only to three-phase arcing faults (though single-phase or phase-phase arcing faults are generally expected to quickly escalate to three-phase faults), and it does not consider the effects of arc blast or other by-products of an arcing fault (sound levels, molten metal droplets, toxic vapors, and so on).

NFPA 70B and 70E address the issue of equipment maintenance and its potential effect on the arc flash boundary and the selection of personal protective equipment. The results of this study assume that protective devices considered are in working order and will operate within their specified tolerances to clear faults from the system. Non-functioning overcurrent protective devices can allow arcing faults to persist for much longer than normal, producing a very significant arc flash hazard beyond the results of the calculations presented in this report. Failure to properly maintain equipment per manufacturers' requirements and intervals may invalidate these results. Protection from arc flash hazards can best be provided by working only on circuits or equipment that have been placed in an electrically safe work condition.

The results of the arc flash analysis show both the calculated arc flash incident energy (AFIE) and arc flash boundary distances at each bus under study. In some locations, more than one value for AFIE levels and/or the arc flash boundary are given (e.g., one for the main section and one for the feeder sections of a switchgear lineup) to reflect different zones of protection for a given piece of equipment. Equipment warning labels or safety programs should take these variations in energy levels and arc flash boundaries into account.

For buses that represent low-voltage switchboards, panelboards, or motor control centers, the values shown in the Arc Flash Hazard Analysis – Summary Tables assume that the fault is cleared by the upstream protective device, even if the equipment contains a main overcurrent protective device. This assumption is intended to produce conservative results and therefore cover the case where faults originating in such equipment may propagate to the line side of the local main. See the Arc Flash Specific Procedure for additional details regarding the analysis procedure.

Additional discussion of buses with incident energy greater than 40 cal/cm² is given in the Arc Flash Analysis of Results, if applicable. Note that while PPE with arc ratings of up to 112 cal/cm² is commercially available, NFPA 70E-2012 does not define protective clothing classes or intend for work to be performed at locations having incident energies above 40 cal/cm² (Category 4). Due to the increased risk of non-burn injuries (e.g., concussions, hearing damage, or other internal injuries) at such high-energy locations, *Power Systems Engineering does not recommend energized work at any location with an available AFIE greater than 40 cal/cm².*

The arc flash hazard analysis and recommended PPE levels are no substitutes for safe work practices. As stated in 130.7(A), Informational Note No. 1 of NFPA 70E-2012, burn injuries can occur even when adequate PPE is employed, and the recommended PPE may provide little or no protection against arc blast and its effects. Protection from arc flash can best be provided by working only on circuits or equipment that have been placed in an electrically safe work condition.

6.2 Specific Procedure

SKM Power*Tools software includes an Arc Flash Hazard Analysis study module that contains equations based on both NFPA 70E and IEEE 1584. Calculations presented in this report are based on the IEEE 1584 calculation procedure. The program calculates the three-phase arcing fault current at each bus in the system based on the available three-phase bolted fault current determined during the short-circuit analysis and the equations in IEEE 1584. The duration of the arc is determined from the time-current characteristics of the applicable phase overcurrent devices and the calculated arc fault current. Once the arcing fault current and fault duration are known, equations from IEEE 1584 are used to calculate the available incident energy and arc flash boundary for each location under study. Per IEEE 1584, for low voltage (less than 1000V) buses, a second arcing fault current value is calculated to be equal to 85% of the arcing fault value originally calculated. From this second calculation, a second device operating time is determined. The incident energy and arc flash boundaries are calculated using both sets of values, and the worst case result is reported in this analysis. IEEE 1584 also contains equations specifically for buses protected by Class RK1 or Class L (through 2000A) current-limiting fuses, and these equations were used when appropriate.

The calculated incident energy levels are also based on the “working distance” from the fault, which is the distance from the head and torso of the worker to the source of arcing energy. A working distance of 36 inches was assumed for medium-voltage equipment, 24 inches for low-voltage switchgear, and 18 inches for motor control centers and panelboards, per the IEEE 1584 recommendations. In addition to the incident energy levels at the given working distance, the arc flash boundary at each location is provided. This distance corresponds to the distance from the equipment that the incident energy equals 1.2 cal/cm², which is generally accepted to be the energy level sufficient to cause the onset of a 2nd degree burn on bare skin. When working inside the arc flash boundary, proper personal protective equipment (PPE) is required.

For buses that represent low-voltage switchboards, panelboards, and MCCs the values shown in the Flash Hazard tables assume that the fault is cleared by the upstream protective device, even if the equipment contains a main overcurrent protective device. Since this equipment typically lacks the internal barriers or compartments that are typical of switchgear construction, it may be possible for arcing faults—particularly those that originate close to the main section and that are not cleared instantaneously—to propagate to the line side of the main overcurrent protective device. If this happens, then the fault can no longer be cleared by the local main, but rather by the next upstream overcurrent protective device. In cases where the next upstream device is a fuse or relay on the primary side of a step-down transformer, the fault clearing time and resulting AFIE level can increase significantly. Specific equipment testing has not been performed to assess the

risk of such fault propagation, but the assumption that the upstream device clears the fault produces conservative results.

Motor contribution to the arcing fault current is considered in the analysis. For this study, induction motor contribution for motors 50HP and larger was assumed to go to zero after 5 cycles if not already cleared by the opening/clearing of a breaker/fuse. Contribution from induction motors is generally not considered to last for more than a few cycles, so this 5-cycle contribution time is believed to produce rational results when motor contribution is considered.

For buses with more than one source of fault current, the SKM software continues to accumulate incident energy until the *Fault Clear Threshold* is reached. The Fault Cleared Threshold is the percent of the total bus arcing fault current that must be interrupted by protective devices in order to consider the fault cleared. The assumption is; after the threshold is reached the remaining arcing fault current is not sufficient to maintain the arc and should not be included as accumulated incident energy. The result of this study option is that incident energy will be accumulated until either the Fault Cleared Threshold or the Maximum Protection Trip Time is reached, whichever occurs first. There are no recommendations in NFPA 70E or IEEE 1584 for determining a fault cleared threshold; a value of 99% was used in the analysis and is the maximum allowed value in the SKM software.

The SKM software, when calculating trip times for use in the arc flash hazard analysis, checks the upstream devices to determine which actually trips first rather than simply considering the characteristics of the next upstream device. In cases where the next upstream device was not the one that trips the fastest, the software flags this as “miscoordination” between the devices.

Ingress/egress should always be reviewed as part of the overall safety program as it cannot be solely determined by this analysis. However, some maximum arcing durations are cut off at 2.0 seconds. Annex B.1.2 of IEEE 1584 recognizes that it is likely a worker exposed to an arcing fault will quickly move away from the source of the arc if physically possible, and states under such conditions, “...*two seconds is a reasonable maximum time for calculations.*” Situations where such a cutoff might not be appropriate include workers in a lift bucket inspecting or operating overcurrent devices in elevated plug-in busway, or in other locations where clear ingress/egress is not available.

Neither the calculated incident energy levels nor the arc flash boundaries calculated as part of this analysis are relevant to the shock hazard that exists near all energized equipment. Shock hazard analyses may also be required before qualified employees are able to work on or near energized equipment. NFPA 70E-2012 defines *shock hazard* as “A dangerous condition associated with the possible release of energy caused by contact or approach to energized electrical conductors or circuit parts.” The standard also defines the *Limited Approach Boundary* as “An approach limit at a distance from an exposed energized electrical conductor or circuit part within which a shock hazard exists.” Only qualified employees can cross the Limited Approach Boundary and enter the limited space in order to perform a given task. A shock hazard analysis shall determine the voltage to which the personnel will be exposed, boundary requirements, and the personal protective equipment necessary in order to minimize the possibility of electric shock. In addition to the Limited Approach Boundary, the Restricted and Prohibited Approach Boundaries are also applicable to situations in which qualified personnel are exposed to live parts. See NFPA 70E Tables 130.4(C)(a) and 130.4(C)(b) for the boundary distances associated with various system voltages.

6.3 AF Hazard Analysis Results and Recommendations

The results of the arc flash hazard analysis are presented in the “ARC FLASH HAZARD ANALYSIS TABLES.” The parameters that the analysis is based upon—fault current, arc duration, and working distance—are presented along with the incident energy, arc flash boundary, and minimum PPE class required for each bus.

As discussed previously, the calculations are cut off at a maximum arcing duration of 2.0 seconds.

Arc Flash labels or procedures should not be based on the AFIE levels shown in Arc Flash Hazard Analysis until after the recommended settings have been implemented.

Overly conservative available fault current values should not be used solely for an arc flash analysis. Therefore, three arc flash fault current scenarios were considered. The first consisted of a high utility source 80,000 Amps at 13.2kV, based on maximum fault current. The second considered a minimum utility source 1,531Amps at 13.2kV, available fault current assumed. The third was a generator source for equipment fed by the emergency generator. All arc flash scenarios were considered with motor loads turned off and on to find the worst case. The results of all the scenarios were combined into one composite table showing the worst case results for each piece of equipment evaluated.

IEEE 1584 states that during testing, arcs on 208V systems were difficult to sustain, and arc flash levels on systems operating below 240V and fed by transformers sized below 125 kVA are “not a concern”. NFPA 70E-2012 article 130.5 Informational Note No. 5 refers to IEEE 1584 for more information regarding arc flash hazards for three-phase systems rated less than 240 volts. Based on this guidance from the standards, for buses operating less than 240V, the PPE level was assumed to be Category 0 (1.2 cal/cm² or less) as long as the transformer size is less than 125 kVA. The arc flash boundary at these locations is a maximum of 18 inches.

For some buses, more than one AFIE value and arc flash boundary distance are provided. This is the case when various parts of a single piece of equipment may actually be in different arc flash “zones of protection.” For example, consider a lineup of low-voltage drawout switchgear containing both a main breaker and several feeder breakers. The compartmentalized switchgear construction would be expected to reduce the chance that faults in the feeder sections would propagate to the line-side of the main, so any fault occurring in a feeder section would be considered to be cleared by the main breaker. However, an arcing fault in the main section could either occur on the load side or the line side of the main, so such faults must be considered to be cleared by the next upstream protective device (e.g., the transformer primary overcurrent protective device). This results in different values for AFIE and for the arc flash boundary for such locations, possibly requiring different levels of PPE for workers depending on which section they are working on or near. In such cases, the results of both calculations are presented in the tables.

There are no personal protective equipment categories given for locations with energy levels exceeding 40 cal/cm², even though protective clothing capable of providing flash protection at incident energy levels of up to 112 cal/cm² is commercially available. **The ARC FLASH HAZARD ANALYSIS TABLES makes use of the term “Dangerous” to identify when the Hazard/Risk Category (PPE) is greater than 40cal/cm².** While NFPA 70E-2012 does not explicitly prohibit work at locations with energy levels above 40 cal/cm², research into the potential for non-burn injuries (internal injuries, hearing damage, etc.) indicates that these other injuries become a significant concern at such high-energy locations. *Power System Engineering does not recommend work at locations with energy levels greater than 40 cal/cm², unless the equipment has been placed into an electrically safe work condition.*

After the initial breaker coordination work was performed, a review of settings affecting locations with energy levels greater than 40 cal/cm² was conducted to determine whether adjustment of device settings could be performed to reduce the flash hazard level. In many some cases, the settings could be adjusted with no significant loss of coordination, as discussed in Overcurrent Device Coordination Analysis Results and Recommendations.

In other cases, devices were either nonadjustable or their settings could not be reduced without a significant loss of selectivity between devices, as discussed in the following paragraphs:

KWHs Power company owned fuse is the primary overcurrent protective device for the 1,500 kVA transformer and cannot be reduced in size enough causing this situation to be unavoidable.

There were seven locations where the arc flash incident energy level is greater than 40 cal/cm² which is considered the upper limit defined by NFPA 70E. Flash hazard levels at (100 UTC_MDPH1, 101 MDPH1, 108 SDPL1, 200 UTC2_MDPH2, 201 MDPH2, 213 SDPH21 and 229 SDPH22) exceeded 40 cal/cm², and this equipment is reported as “Dangerous” in the Flash Hazard Table. The arcing fault current must be cleared by the upstream utility transformer primary fuse. Equipment protected by a transformer primary overcurrent device generally results in long trip delay times which cannot be adjusted lower because of the load and/or transformer inrush, or due to limitations or non-adjustability of the protective device. Knowing the actual device information for this project is not likely to result in any improvement at this equipment location.

- Work should not be performed on 100 UTC_MDPH1 and 200 UTC2_MDPH2 without first opening and locking out power on the primary side of the Utilities service transformer.
- Work should not be performed on 101 MDPH1, 108 SDPL1, 201 MDPH2, 213 SDPH21 and 229 SDPH22 without first opening and locking out power on the protective device that feeds each equipment.

6.3.1 Arc Flash Hazard Table Headings Guide and PPE Table

The arc flash hazard table summarizes the results of the arc flash hazard analysis. The calculations are based on the protective relay and low voltage circuit breaker settings developed in previous sections. Following is a brief description of the arc flash hazard analysis table headings.

- Protective Device Name: The designation for the overcurrent protective device that clears the arcing fault. In cases where several sources are connected to a single bus (e.g., multiple mains, motor contribution to an MCC, etc.), the main device to operate is reported.
- Bus Bolted Fault (kA): The calculated three-phase bolted fault current, RMS symmetrical amperes.
- Prot. Dev. Bolted Fault (kA): The portion of the bolted fault current through the protective device.
- Prot. Dev. Arcing Fault (kA): The calculated arcing fault current associated with the bolted fault current.
- Trip/Delay Time (sec.): This is the time for the main protective device to react to the arcing current. For fuses, it is the total clearing time. For circuit breakers, it is the relay or trip unit time delay. The time is taken from a time-current curve using the arcing current or the reduced (85%) arcing current, unless the maximum tripping time of 2.0 seconds is used.

- Breaker Opening Time (sec.): This is the time for the circuit breaker mechanism to open the contacts and interrupt the current. The time is in addition to the trip or delay time. For low-voltage breakers, the opening time is included in the trip/delay time.
- Ground: This indicates whether the system is grounded or ungrounded (including ungrounded or impedance grounded).
- Equip. Type: This indicates the type of equipment in which the arc is assumed to occur: switchgear, panelboard, cable, or open air.
- Gap: This is the gap between conductors and defines the length of the arc. Standard bus gap distances are defined in IEEE 1584.
- Arc Flash Hazard Boundary: This is the working distance at which incident energy equals 1.2 cal/cm^2 , considered to be the level which can produce second-degree burns on exposed skin. Any approach closer than the arc flash boundary requires use of personal protective equipment.
- Working Distance: The assumed distance from the arc point to the head and body of the worker positioned in place to perform the assigned task.
- Incident Energy: The thermal energy density to which a person at the working distance is exposed.
- Required Protective Arc Rated (AR) Clothing Characteristics: The information is intended to provide a convenient classification of hazard levels in the system to allow for selection of PPE. The requirements for protective clothing and other protective equipment are based on the hazard/risk categories 0-4 in 70E. If the incident energy is greater than 40 cal/cm^2 (Category 4), work should not be performed on or near the equipment unless the equipment has been placed in an electrically safe condition. For such hazard levels, the description "Dangerous" is used. The required AR clothing characteristics reported in the table are based on Table 130.7(C)(16) of NFPA 70E, as shown in the **Table 2** on the following page. The descriptions in the arc flash summary table are typical—consult NFPA 70E and manufacturers' Arc Rating information for further information and additional requirements on other required protective clothing, including hearing, face, and eye protection. The latest edition of NFPA 70E should also be reviewed regarding limitations and requirements for working on energized equipment. Requirements related to energized work, including mandatory energized work permits, are much more restrictive than in previous versions of NFPA 70E.

Table 2: Protective Clothing Characteristics from Table 130.7(C)(16) of NFPA 70E.

Hazard/Risk Category	Clothing Description	Minimum Required ATPV
0	Protective Clothing, Nonmelting or Untreated Natural Fiber (i.e., untreated cotton, wool, rayon, or silk, or blends of these materials) with a Fabric Weight of at Least 4.5 oz/yd ² Shirt (long sleeve); Pants (long)	N/A
1	Arc-Rated Clothing Arc-rated long-sleeve shirt and pants or arc-rated coverall; Arc-rated face shield or arc flash suit hood; Arc-rated jacket, parka, rainwear, or hard hat liner (AN)	4
2	Arc-Rated Clothing Arc-rated long-sleeve shirt and pants or arc-rated coverall; Arc-rated flash suit hood or arc-rated face shield and arc-rated balaclava; Arc-rated jacket, parka, rainwear, or hard hat liner (AN)	8
3	Arc-Rated Clothing Selected so That the System Arc Rating Meets the Required Minimum Arc Rating Arc-rated long-sleeve shirt (AR); Arc-rated pants (AR); Arc-rated coverall (AR); Arc-rated arc flash suit jacket (AR); Arc-rated arc flash suit pants (AR); Arc-rated arc flash suit hood; Arc-rated gloves; Arc-rated jacket, parka, rainwear, or hard hat liner (AN)	25
4	Arc-Rated Clothing Selected so That the System Arc Rating Meets the Required Minimum Arc Rating Arc-rated long-sleeve shirt (AR); Arc-rated pants (AR); Arc-rated coverall (AR); Arc-rated arc flash suit jacket (AR); Arc-rated arc flash suit pants (AR); Arc-rated arc flash suit hood; Arc-rated gloves; Arc-rated jacket, parka, rainwear, or hard hat liner (AN)	40

While using categories 0-4 is a convenient way to determine the arc-rated clothing and other personal protective equipment (PPE), for a given location, Informative Annex H in 70E is a suggested simplified approach to select PPE when an incident energy analysis is performed. That analysis is a component of a broader arc flash hazard analysis used to predict the incident energy of an arc flash for a specified set of conditions. Selection of PPE is always left up to the worker and the safety policy of the worker's facility based on the type of exposure for a given task.

6.3.2 Arc Flash Hazard Analysis Table – Recommended Settings



POWER SYSTEM ENGINEERING

ARC FLASH HAZARD
ANALYSIS TABLE

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502
BASED ON RECOMMENDED SETTINGS

BUS NAME	PROTECTIVE DEVICE NAME	kV	BUS BOLTED FAULT (kA)	PROT. DEV. BOLTED FAULT (kA)	ARCING FAULT (kA)	TRIP/ DELAY TIME (sec)	BREAKER OPENING TIME (sec)	GROUND	EQUIP. TYPE	GAP (mm)	ARC FLASH BOUNDARY (in)	WORKING DISTANCE (in)	INCIDENT ENERGY (cal/cm2)	REQUIRED PROTECTIVE ARC RATED (AR) CLOTHING CHARACTERISTICS
100 UTC_MDPH1	UTILITY FUSE	0.480	34.44	30.62	16.77	2.000	0.000	Yes	PNL	25	297	18	119	Dangerous! (*N9) High Utility Source
101 MDPH1	100-02 UTC_MDPH1	0.480	32.77	28.93	15.96	2.000	0.000	Yes	PNL	25	288	18	113	Dangerous! (*N9) High Utility Source
102 H1L1	101-04 MDPH1_H1L1	0.480	27.26	27.26	15.45	0.050	0.000	Yes	PNL	25	29	18	2.66	Category 1 High Utility Source
103 H1L2	101-05	0.480	16.15	16.15	9.87	0.018	0.000	Yes	PNL	25	12	18	0.57	Category 0 High Utility Source
104 H1L3	101-06 MDPH1_H1L3	0.480	15.16	15.16	9.36	0.016	0.000	Yes	PNL	25	11	18	0.49	Category 0 High Utility Source
105 H1L4	101-07 MDPH1_H1L4	0.480	16.75	16.75	10.19	0.054	0.000	Yes	PNL	25	23	18	1.83	Category 1 High Utility Source
106 MD/G	105-02 H1L4_XFMR_MD/G	0.208	6.10	6.10	3.05	2.000	0.000	Yes	PNL	25	95	18	18.40	Category 3 (*N9) (*N16) High Utility Source
107 G/GA	101-07 MDPH1_H1L4	0.208	6.55	6.55	2.75	0.074	0.000	Yes	PNL	25	12	18	0.61	Category 0 (*N3) (*N5) Low Utility Source
108 SDPL1	101-08 MDPH1_XFMR_SDPL1	0.208	23.91	23.91	7.79	2.000	0.000	Yes	PNL	25	177	18	51	Dangerous! (*N9) (*N16) High Utility Source
109 L1M1	108-02	0.208	2.69	2.69	1.73	2.000	0.000	Yes	PNL	25	65	18	9.93	Category 3 (*N9) (*N16) High Utility Source
110 L1L1	108-03 SDPL1_L1L1	0.208	15.48	15.48	4.79	1.119	0.000	Yes	PNL	25	90	18	16.84	Category 3 (*N3) (*N16) Low Utility Source
111 L1L2	108-04 SDPL1_L1L2	0.208	13.37	13.37	5.12	2.000	0.000	Yes	PNL	25	134	18	32.27	Category 4 (*N9) (*N16) Low Utility Source
112 L1L3	108-05 SDPL1_L1L3	0.208	10.27	10.27	3.77	0.092	0.000	Yes	PNL	25	17	18	1.06	Category 0 (*N3) Low Utility Source
113 L1L31	112-02	0.208	9.24	9.24	4.12	0.015	0.000	Yes	PNL	25	6	18	0.19	Category 0 High Utility Source
114 L1L4	108-06	0.208	5.33	5.33	2.78	2.000	0.000	Yes	PNL	25	90	18	16.66	Category 3 (*N9) (*N16) High Utility Source
115 L1L5	108-07	0.208	5.25	5.25	2.73	2.000	0.000	Yes	PNL	25	89	18	16.31	Category 3 (*N9) (*N16) Low Utility Source
116 L1L6	108-08	0.208	6.87	6.87	2.84	0.028	0.000	Yes	PNL	25	7	18	0.24	Category 0 (*N3) Low Utility Source
117 L1B1	108-09	0.208	13.18	13.18	5.28	0.017	0.000	Yes	PNL	25	8	18	0.28	Category 0 High Utility Source
118 L1B2	108-10	0.208	2.53	2.53	1.41	2.000	0.000	Yes	PNL	25	57	18	7.97	Category 2 (*N3) (*N9) (*N16) High Utility Source
119 H1B1	101-09	0.480	15.63	15.63	9.60	0.018	0.000	Yes	PNL	25	11	18	0.56	Category 0 High Utility Source
200 UTC2_MDPH2	UTILITY FUSE 2	0.480	32.64	29.31	16.18	2.000	0.000	Yes	PNL	25	290	18	114	Dangerous! (*N9) High Utility Source
201 MDPH2	200-02 UTC2_MDPH2	0.480	31.85	28.51	15.79	2.000	0.000	Yes	PNL	25	285	18	111	Dangerous! (*N9) High Utility Source
202 SDPL2	201-03 MDPH2_XFMR_SDPL2	0.208	16.27	16.27	6.01	2.000	0.000	Yes	PNL	25	149	18	38.34	Category 4 (*N9) (*N16) High Utility Source
203 L2M1	202-02 SDPL2_L2M1	0.208	12.23	12.23	5.01	0.059	0.000	Yes	PNL	25	15	18	0.93	Category 0 High Utility Source
204 L2M11	203-02 L2M1_L2M11	0.208	10.15	10.15	4.39	0.051	0.000	Yes	PNL	25	13	18	0.69	Category 0 High Utility Source
205 L2M2	202-03 SDPL2_L2M2	0.208	9.79	9.79	3.55	2.000	0.000	Yes	PNL	25	105	18	21.69	Category 3 (*N3) (*N9) (*N16) Low Utility Source
206 L2M21	205-02	0.208	6.70	6.70	3.28	0.017	0.000	Yes	PNL	25	5	18	0.17	Category 0 High Utility Source
207 L2B2	202-04	0.208	8.77	8.77	3.97	0.018	0.000	Yes	PNL	25	7	18	0.23	Category 0 High Utility Source
208 L2B1	202-05	0.208	10.10	10.10	4.38	0.018	0.000	Yes	PNL	25	7	18	0.24	Category 0 High Utility Source
209 H2M1	201-05 MDPH2_H2M1	0.480	19.07	19.07	11.38	0.016	0.000	Yes	PNL	25	12	18	0.61	Category 0 High Utility Source
210 H2M2	201-06 MDPH2_H2M2	0.480	20.65	20.65	12.18	0.050	0.000	Yes	PNL	25	25	18	2.05	Category 1 High Utility Source
211 H2B2	201-07 MDPH2_H2B2	0.480	29.14	29.14	16.35	0.050	0.000	Yes	PNL	25	30	18	2.82	Category 1 High Utility Source
212 H2B1	201-08	0.480	13.49	13.49	8.47	0.016	0.000	Yes	PNL	25	10	18	0.45	Category 0 High Utility Source
213 SDPH21	201-09 MDPH2_SDPH21	0.480	17.80	17.80	10.19	2.000	0.000	Yes	PNL	25	211	18	68	Dangerous! (*N9) (*N16) High Utility Source
214 H21B1	213-05	0.480	11.10	11.10	7.17	0.017	0.000	Yes	PNL	25	9	18	0.39	Category 0 High Utility Source
215 H21M1	213-04	0.480	9.26	9.26	6.14	0.017	0.000	Yes	PNL	25	8	18	0.33	Category 0 High Utility Source
216 H21U1	213-03	0.480	7.29	7.29	5.01	0.017	0.000	Yes	PNL	25	7	18	0.26	Category 0 High Utility Source



POWER SYSTEM ENGINEERING

ARC FLASH HAZARD
ANALYSIS TABLE

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502
BASED ON RECOMMENDED SETTINGS

BUS NAME	PROTECTIVE DEVICE NAME	kV	BUS BOLTED FAULT (kA)	PROT. DEV. BOLTED FAULT (kA)	ARCING FAULT (kA)	TRIP/ DELAY TIME (sec)	BREAKER OPENING TIME (sec)	GROUND	EQUIP. TYPE	GAP (mm)	ARC FLASH BOUNDARY (in)	WORKING DISTANCE (in)	INCIDENT ENERGY (cal/cm2)	REQUIRED PROTECTIVE ARC RATED (AR) CLOTHING CHARACTERISTICS
217 SDPL21	213-02 SDPH21_SDPL21	0.208	13.88	13.88	5.39	2.000	0.000	Yes	PNL	25	139	18	34.08	Category 4 (*N9) (*N16) High Utility Source
218 L21U1	217-02	0.208	6.53	6.53	2.73	2.000	0.000	Yes	PNL	25	88	18	16.29	Category 3 (*N3) (*N9) (*N16) High Utility Source
219 L21U2	217-03	0.208	3.45	3.45	2.05	2.000	0.000	Yes	PNL	25	73	18	11.99	Category 3 (*N9) (*N16) High Utility Source
220 L21U3	217-04	0.208	5.56	5.56	2.44	2.000	0.000	Yes	PNL	25	82	18	14.43	Category 3 (*N3) (*N9) (*N16) High Utility Source
221 L21U4	217-05	0.208	3.81	3.81	2.20	2.000	0.000	Yes	PNL	25	77	18	12.94	Category 3 (*N9) (*N16) High Utility Source
222 L21U5	217-06	0.208	6.66	6.66	2.78	0.035	0.000	Yes	PNL	25	8	18	0.29	Category 0 (*N3) Low Utility Source
223 L21M1	217-07	0.208	4.45	4.45	2.45	2.000	0.000	Yes	PNL	25	82	18	14.53	Category 3 (*N9) (*N16) High Utility Source
224 L21M11	223-02	0.208	3.91	3.91	2.24	2.000	0.000	Yes	PNL	25	78	18	13.18	Category 3 (*N9) (*N16) High Utility Source
225 L21M2	217-08	0.208	6.53	6.53	2.73	2.000	0.000	Yes	PNL	25	88	18	16.29	Category 3 (*N3) (*N9) (*N16) High Utility Source
226 L21M3	217-09	0.208	5.11	5.11	2.70	2.000	0.000	Yes	PNL	25	88	18	16.14	Category 3 (*N9) (*N16) High Utility Source
227 L21M4	217-10	0.208	8.03	8.03	3.17	0.025	0.000	Yes	PNL	25	7	18	0.24	Category 0 (*N3) Low Utility Source
228 L21B1	217-11	0.208	10.69	10.69	4.56	0.017	0.000	Yes	PNL	25	7	18	0.24	Category 0 High Utility Source
229 SDPH22	201-10 MDPH2_SDPH22	0.480	15.94	15.94	9.32	2.000	0.000	Yes	PNL	25	199	18	62	Dangerous! (*N9) (*N16) High Utility Source
230 H22B1	229-05	0.480	12.18	12.18	7.76	0.017	0.000	Yes	PNL	25	10	18	0.42	Category 0 High Utility Source
231 H22M1	229-04	0.480	4.60	4.60	3.38	0.017	0.000	Yes	PNL	25	6	18	0.17	Category 0 High Utility Source
232 H22U1	229-03	0.480	8.90	8.90	5.94	0.018	0.000	Yes	PNL	25	8	18	0.33	Category 0 High Utility Source
233 SDPL22	229-02 SDPH22_SDPL22	0.208	13.57	13.57	5.31	2.000	0.000	Yes	PNL	25	137	18	33.51	Category 4 (*N9) (*N16) High Utility Source
234 L22U1	233-02	0.208	6.17	6.17	2.62	2.000	0.000	Yes	PNL	25	86	18	15.60	Category 3 (*N3) (*N9) (*N16) High Utility Source
235 L22U2	233-03	0.208	5.55	5.55	2.44	2.000	0.000	Yes	PNL	25	82	18	14.42	Category 3 (*N3) (*N9) (*N16) High Utility Source
236 L22U3	233-04	0.208	4.44	4.44	2.45	2.000	0.000	Yes	PNL	25	82	18	14.51	Category 3 (*N9) (*N16) High Utility Source
237 L22U4	233-05	0.208	5.85	5.85	2.52	2.000	0.000	Yes	PNL	25	84	18	14.99	Category 3 (*N3) (*N9) (*N16) High Utility Source
238 L22U5	233-06	0.208	5.14	5.14	2.70	2.000	0.000	Yes	PNL	25	88	18	16.11	Category 3 (*N9) (*N16) Low Utility Source
239 L22M1	233-07	0.208	6.17	6.17	2.62	2.000	0.000	Yes	PNL	25	86	18	15.60	Category 3 (*N3) (*N9) (*N16) High Utility Source
240 L22M2	233-08	0.208	5.14	5.14	2.70	2.000	0.000	Yes	PNL	25	88	18	16.11	Category 3 (*N9) (*N16) Low Utility Source
241 L22M3	233-09	0.208	5.14	5.14	2.70	2.000	0.000	Yes	PNL	25	88	18	16.11	Category 3 (*N9) (*N16) Low Utility Source
242 L22M4	233-10	0.208	5.05	5.05	2.68	2.000	0.000	Yes	PNL	25	87	18	16.00	Category 3 (*N9) (*N16) High Utility Source
243 L22M5	233-11	0.208	5.79	5.79	2.50	2.000	0.000	Yes	PNL	25	84	18	14.86	Category 3 (*N3) (*N9) (*N16) High Utility Source
244 L22M6	233-12	0.208	4.62	4.62	2.52	2.000	0.000	Yes	PNL	25	84	18	14.97	Category 3 (*N9) (*N16) High Utility Source
245 L22B1	233-13	0.208	6.61	6.61	3.25	0.017	0.000	Yes	PNL	25	5	18	0.17	Category 0 High Utility Source
300 GEN SEC	MaxTripTime @2.0s	0.480	2.00	2.00	1.66	2.000	0.000	Yes	PNL	25	43	18	4.98	Category 2 (*N2) (*N9) High Utility Source
301 ATS_E1B1	101-10	0.480	12.79	12.79	8.09	0.018	0.000	Yes	PNL	25	10	18	0.46	Category 0 High Utility Source
302 ATS_E2B1	300-03 GEN SEC_ATS_E2B1	0.480	1.85	1.85	0.82	2.000	0.000	Yes	PNL	25	42	18	4.81	Category 2 (*N9) (*N16) Generator Source



POWER SYSTEM ENGINEERING

ARC FLASH HAZARD
ANALYSIS TABLE

KELLY WALSH HIGH SCHOOL
Casper, WY
6.E501 & 6.E502
BASED ON RECOMMENDED SETTINGS

BUS NAME	PROTECTIVE DEVICE NAME	kV	BUS BOLTED FAULT (kA)	PROT. DEV. BOLTED FAULT (kA)	ARCING FAULT (kA)	TRIP/ DELAY TIME (sec)	BREAKER OPENING TIME (sec)	GROUND	EQUIP. TYPE	GAP (mm)	ARC FLASH BOUNDARY (in)	WORKING DISTANCE (in)	INCIDENT ENERGY (cal/cm2)	REQUIRED PROTECTIVE ARC RATED (AR) CLOTHING CHARACTERISTICS
303 E1B1	101-10	0.480	10.77	10.77	6.99	0.018	0.000	Yes	PNL	25	9	18	0.39	Category 0 High Utility Source
304 E1L1	303-02	0.480	1.48	1.48	1.09	0.133	0.000	Yes	PNL	25	9	18	0.40	Category 0 (*N3) Generator Source
305 E1L2	303-03	0.480	1.40	1.40	0.64	1.161	0.000	Yes	PNL	25	26	18	2.17	Category 1 (*N3) (*N16) Generator Source
306 E1BL1	303-04	0.208	1.79	1.79	1.30	0.793	0.000	Yes	PNL	25	18	18	1.20	Category 0 (*N5) (*N15) (*N16) High Utility Source
307 E1BL2	306-02	0.208	1.28	1.28	0.87	0.158	0.000	Yes	PNL	25	9	18	0.38	Category 0 (*N3) (*N15) Generator Source
308 E2B1	300-03 GEN SEC_ATS_E2B1	0.480	1.83	1.83	0.82	2.000	0.000	Yes	PNL	25	42	18	4.79	Category 2 (*N9) (*N16) Generator Source
309 E2BL1	308-02	0.208	2.98	2.98	1.85	2.000	0.000	Yes	PNL	25	18	18	1.20	Category 0 (*N5) (*N9) (*N15) (*N16) High Utility Source
310 E2BL2	309-02	0.208	1.49	1.49	1.14	2.000	0.000	Yes	PNL	25	18	18	1.20	Category 0 (*N9) (*N15) (*N16) High Utility Source
311 E2BL3	310-02	0.208	1.01	1.01	0.87	2.000	0.000	Yes	PNL	25	18	18	1.20	Category 0 (*N9) (*N15) (*N16) High Utility Source
312 E2M1	308-03	0.480	1.53	1.53	1.12	0.126	0.000	Yes	PNL	25	9	18	0.39	Category 0 (*N3) Generator Source
313 E2B2	308-04	0.480	1.37	1.37	0.74	2.000	0.000	Yes	PNL	25	39	18	4.22	Category 2 (*N9) (*N16) Generator Source
314 E2M3	313-02	0.480	1.16	1.16	0.60	0.448	0.000	Yes	PNL	25	15	18	0.85	Category 0 (*N3) (*N16) Generator Source
315 E2U1	313-03	0.480	1.12	1.12	0.59	0.461	0.000	Yes	PNL	25	15	18	0.85	Category 0 (*N3) (*N16) Generator Source
316 E2B3	313-04	0.480	1.11	1.11	0.58	1.398	0.000	Yes	PNL	25	27	18	2.28	Category 1 (*N3) (*N16) Generator Source
317 E2M2	316-02	0.480	0.86	0.86	0.52	0.585	0.000	Yes	PNL	25	15	18	0.88	Category 0 (*N3) (*N16) Generator Source
318 E2U2	316-03	0.480	0.83	0.83	0.51	0.605	0.000	Yes	PNL	25	15	18	0.88	Category 0 (*N3) (*N16) Generator Source

Notes Section (The following default note numbers from the software have been used in this analysis.)

(*N2) - Percentage of fault current cleared is less than the Cleared Fault Threshold specified in the study options.

(*N3) - Arcing Fault Current Low Tolerances Used.

(*N5) - Mis-coordinated, Upstream Device Tripped.

(*N9) - Max. Arcing Duration Reached. The time taken for the protective device to clear the fault is longer than the Max. Arcing Duration as specified in the study options.

(*N15) - Fed by Transformer Size < 125 kVA, on bus voltage level < 240V; Report as Category 0.

(*N16) - Trip Time Recalculated.

6.4 Power System Engineering Arc Flash Labeling Practice

The Power System Engineering arc flash labeling practice will be used for this job. Labels for each piece of equipment, or for each section of multi-section equipment will consist of two labels: (1) An Arc Flash Information label and (2) a general safety label. The Arc Flash Information label is printed with values produced by the arc flash hazard analysis and is field installed. The general safety label is factory installed on new Schneider Electric, Square D brand, equipment and will be provided for field installation on any electrical equipment (Square D or other) lacking these labels, or having existing safety labels not meeting the intent of these general safety labels.

6.4.1 Arc Flash Information Labels

The Arc Flash Information labels are printed with black letters on Brady B-423 glossy white polyester label stock (2 mil) using a thermal transfer printer. The labels have a pressure sensitive permanent acrylic adhesive backing (1 mil) and are 4.0-inches by 4.0-inches. Clear polyvinyl chloride overlaminates (2.6 mil) are available for outdoor application where UV resistance is required. These clear overlaminates use Brady B-649 material and are 4.5-inches by 4.5-inches. Technical data sheets for each Brady material are available on-line at www.bradyid.com. The following information is included on each label:

- a. "Arc Flash Information" banner on the top of the label
- b. Arc Flash Boundary in inches
- c. Incident Energy in cal/cm^2
- d. Working Distance in inches
- e. PPE Category per NFPA 70E (also repeated in large font in the upper left corner)
- f. Shock hazard when cover is open
- g. Limited Approach in inches
- h. Restricted Approach in inches
- i. Prohibited Approach in inches
- j. Equipment name (optional)
- k. Arc Flash Analysis study number
- l. Arc Flash Analysis study date

The standard Arc Flash Information label will report the maximum incident energy and arc flash boundary for each PPE category number and equipment type, unless voltage is greater than 15kV, or if incident energy is above $40 \text{ cal}/\text{cm}^2$ (refer to Figure 5 and Figure 6 for typical labels). Generally no equipment name is printed on the label, unless the voltage is greater than 15kV, or if incident energy is greater than $40 \text{ cal}/\text{cm}^2$. This type of Arc Flash Information label may reduce the need to replace arc flash labels due to changes in the electrical system that change the incident energy and arc flash boundary values but do not affect the PPE category at a given piece of equipment.

For this project, standard Arc Flash Information labels will be supplied.

Multiple labels for one piece of equipment are sometimes sent for a variety of reasons which may include, but are not limited to the following: multiple sections of equipment, side/rear accessible equipment, equipment built to low-voltage Metal-Enclosed Switchgear or medium-voltage Metal-Clad Switchgear standards, and so on.

Arc Flash Information	
Category 0	Use this information in accordance with applicable OSHA standards, NFPA 70E, and other required safe electrical work practices.
18 inches Flash Protection Boundary 1.2 cal/cm² Max Incident Energy at 18" Working Distance Category 0 PPE Category (Per NFPA 70E-2012)	
480 V Shock hazard when cover is open 42 inches Limited Approach 12 inches Restricted Approach 1 inch Prohibited Approach	
<div style="text-align: right;">} Per NFPA 70E-2012</div>	
<div style="display: flex; justify-content: space-between;"> <div> <small>Values produced by a Schneider Electric engineering analysis. Any system modification, adjustment of protective device settings, or failure to properly maintain equipment will invalidate this label. For more information, contact Schneider Electric at 1-888-778-2733.</small> <small>Copyright © 2011 Schneider Electric All Rights Reserved</small> </div> <div> Q2C: 12345678 Date: 10/26/11 </div> </div>	

Arc Flash Information	
Category 0	Use this information in accordance with applicable OSHA standards, NFPA 70E, and other required safe electrical work practices.
18 inches Flash Protection Boundary 1.2 cal/cm² Max Incident Energy at 18" Working Distance Category 0 PPE Category (Per NFPA 70E-2012)	
480 V Shock hazard when cover is open 42 inches Limited Approach 12 inches Restricted Approach 1 inch Prohibited Approach	
<div style="text-align: right;">} Per NFPA 70E-2012</div>	
<div style="display: flex; justify-content: space-between;"> <div> <small>Values produced by a Schneider Electric engineering analysis. Any system modification, adjustment of protective device settings, or failure to properly maintain equipment will invalidate this label. For more information, contact Schneider Electric at 1-888-778-2733.</small> <small>Copyright © 2011 Schneider Electric All Rights Reserved</small> </div> <div> Q2C: 12345678 Date: 10/26/11 </div> </div>	

Figure 5: Typical Standard Arc Flash Information Labels – Actual sizes are 4" x 4".
Without Equipment Name (shown left); With Equipment Name (shown right).

Arc Flash Information	
Use this information in accordance with applicable OSHA standards, NFPA 70E, and other required safe electrical work practices.	
161 inches Flash Protection Boundary 43 cal/cm² Incident Energy at 18" Working Distance Dangerous! Exceeds NFPA 70E-2012 PPE Categories	
480 V Shock hazard when cover is open 42 inches Limited Approach 12 inches Restricted Approach 1 inch Prohibited Approach	
<div style="text-align: right;">} Per NFPA 70E-2012</div>	
<div style="display: flex; justify-content: space-between;"> <div> <small>Values produced by a Schneider Electric engineering analysis. Any system modification, adjustment of protective device settings, or failure to properly maintain equipment will invalidate this label. For more information, contact Schneider Electric at 1-888-778-2733.</small> <small>Copyright © 2011 Schneider Electric All Rights Reserved</small> </div> <div> Q2C: 12345678 Date: 10/26/11 </div> </div>	

Figure 6: Typical Standard Arc Flash Information Label – Actual size is 4" x 4".
Exceeds NFPA 70E-2012 PPE Categories (shown above).

6.4.2 General Safety Labels

General safety labels (typical label shown in Figure 7) are applied to power distribution equipment to warn of general electrical hazards associated with shock, arc flash, and explosions, and to instruct workers to turn off power prior to work. The labels remind workers to de-energize equipment prior to work.

New Schneider Electric, Square D brand, factory installed general safety labels vary in size, wording and physical characteristics, but convey the safety message outlined below. General safety labels provided for field installation are printed with black letters (unless otherwise noted below) on white polyester label stock (2 mil) with UV resistant lamination (3 mil). The labels have a pressure sensitive permanent acrylic adhesive backing (1 mil) and are 3.6-inches by 3.6-inches. The following information is printed on each label:

- a. A safety symbol/pictorial (ANSIMan - figure of a person contacting an energized conductor) in the upper left corner of the label.
- b. A header in ANSI "Safety Red" with white lettering consisting of a safety alert symbol (an "!" inside a triangle) preceding the signal word "DANGER".
- c. HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH
- d. Apply appropriate personal protective equipment (PPE) and follow safe electrical work practices. See NFPA 70E.
- e. This equipment must be installed and serviced only by qualified electrical personnel.
- f. Turn off all power supplying this equipment before working on or inside equipment.
- g. Always use a properly rated voltage sensing device to confirm power is off.
- h. Replace all devices, doors and covers before turning on power to this equipment.
- i. **Failure to follow these instructions will result in death or serious injury.**

For Square D brand equipment manufactured in 2006 or more recently, general safety labels do not need to be affixed. General safety labels prior to 2006 lack the words "OR ARC FLASH" in the warning statement.

For older Square D brand equipment lacking appropriate general safety labels, or for equipment manufactured by others, affix Schneider Electric general safety labels (Figure 7) as close as possible to the Arc Flash Information labels – DO NOT REMOVE OR COVER UP EXISTING SAFETY LABELS (ONES HAVING THE WORDS: DANGER, WARNING, OR CAUTION).




Figure 7: Typical General Safety Label for Electrical Equipment (Actual size is 3.6" x 3.6").

APPENDIX A: ABBREVIATIONS AND TRADEMARKS

Organizations and Standards

ANSI	- American National Standards Institute
IEEE	- Institute of Electrical and Electronics Engineers
ICEA	- Insulated Cable Engineers Association
NEC	- National Electrical Code (NFPA No. 70)
NEMA	- National Electrical Manufacturers Association
UL	- Underwriters' Laboratories, Inc.

Other Abbreviations

A	- Amperes (RMS symmetrical)
AFIE	- Arc Flash Incident Energy (cal/cm ²)
AIC	- Amperes Interrupting Capacity (Three-Phase RMS sym.)
ASD	- Adjustable Speed ac Drive
ATPV	- Protective Clothing Arc Rating
ATS	- Automatic Transfer Switch
C/B	- Circuit Breaker
CHP	- Combined Horsepower
CFLA	- Combined Full Load Amperes
CT	- Current Transformer
FLA	- Full Load Amperes
AFB / FPB	- Arc Flash Boundary / Flash Protection Boundary
HP	- Horsepower
I _L	- Max. Demand Load Current at PCC
I _{sc}	- Short-Circuit Current at PCC
kVA	- Kilovolt-Ampere
kVAm	- Kilovolt-Amperes of Motor Short Circuit contribution
kW	- Kilowatt
L-L	- Line-To-Line
LRA	- Locked-Rotor Amperes
L.V.	- Low Voltage
LSIG.	- L = Long Time, S = Short time, I = Instantaneous, G = Ground fault protection
MCC	- Motor Control Center
MCS	- Molded Case Switch
Mohms	- Milliohms
M.V.	- Medium Voltage
OCPD	- Overcurrent Protective Device
O.L.	- Overload
PCC	- Point of Common Coupling
PF	- Power Factor
PPE	- Personal Protective Equipment
PWM	- Pulse Width Modulated
R	- Resistance
RMS	- Root-Mean-Square
SCA	- Short-Circuit Amperes
SCAm	- Short-Circuit Amperes of Motor Contribution
SCCR	- Short-Circuit Current Rating
S.F.	- Service Factor
sym.	- Symmetrical
TCC.	- Time Current Coordination graph
TCR	- Trip Current Rating
TDD	- Total Demand Distortion
THD	- Total Harmonic Distortion
V	- Line-To-Line Volts (RMS sym.)
WCR	- Withstand Current Rating
X	- Reactance
Z	- Impedance
%Z	- Percent Impedance

Trademarks

BOLT-LOC, ECONOPAK, EZ METER-PAK, GROUND SENSOR, I-LIMITER, I-LINE, ISO-FLEX, MAG-GARD, MICROLOGIC, MINI POWER-ZONE, OMEGAPAK, POWER-CAST, POWER STYLE, POWER ZONE, QF, QO, QWIK-GARD, SORGEL, SPEED-D, SQUARE D, VACARC and WATCHDOG are registered trademarks of Schneider Electric North America. I-75,000, METER-PAK, and PZ-8 are trademarks of Schneider Electric North America.

Company Abbreviations

Allen-Bradley	A-B
Allis-Chalmers	A-C
ASEA Brown Boveri	ABB
Automatic Switch Co	ASCO
Basler	BAS
Bussmann	BUSS
Challenger	CHA
Cooper	COOP
Cutler – Hammer	C-H
Economy Fuse	ECON
Federal Pacific Electric	FPE
G & W Electric	G&W
General Electric	GE
Gould Shawmut	GS
I-T-E Imperial	ITE
Kearney	KEA
Klockner	KLO
Littelfuse	LIT
McGraw Edison	ME
Merlin Gerin	MG
Powell	POW
Reliance	REL
RTE Corp.	RTE
Russelectric	RUSS
S & C Electric	S&C
Schweitzer Engr. Labs	SEL
Siemens	SIE
Square D	SQD
Thomas Betts	T-B
Toshiba	TOS
Westinghouse	WEST
Zenith	Z

APPENDIX B: SHORT CIRCUIT INPUT TABULATIONS

ALL PU VALUES ARE EXPRESSED ON A 100 MVA BASE.

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0001	BUS-0002	100 UTC_MDPH1	8	480	9.0 FEET	600	Copper
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0209 + J 0.0382	Ohms/1000 ft	0.0102 + J 0.0187	PU			
	Z0 Impedance: 0.0659 + J 0.0941	Ohms/1000 ft	0.0322 + J 0.0459	PU			
CBL-0002	100 UTC_MDPH1	101 MDPH1	8	480	100.0 FEET	700	Aluminum
	Duct Material: Non-Magnetic	Insulation Type: XLPE	Insulation Class:		XHHW-2		
	+/- Impedance: 0.0340 + J 0.0380	Ohms/1000 ft	0.1845 + J 0.2062	PU			
	Z0 Impedance: 0.0540 + J 0.0967	Ohms/1000 ft	0.2930 + J 0.5246	PU			
CBL-0003	101 MDPH1	ACC-2	2	480	250.0 FEET	250	Copper
	Duct Material: Non-Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0457 + J 0.0319	Ohms/1000 ft	2.48 + J 1.73	PU			
	Z0 Impedance: 0.0727 + J 0.0812	Ohms/1000 ft	3.94 + J 4.41	PU			
CBL-0004	101 MDPH1	ACC-3	1	480	180.0 FEET	4/0	Copper
	Duct Material: Non-Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0534 + J 0.0314	Ohms/1000 ft	4.17 + J 2.45	PU			
	Z0 Impedance: 0.0849 + J 0.0799	Ohms/1000 ft	6.63 + J 6.24	PU			
CBL-0005	101 MDPH1	102 H1L1	2	480	60.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0722 + J 0.0399	Ohms/1000 ft	0.9401 + J 0.5195	PU			
	Z0 Impedance: 0.2275 + J 0.0983	Ohms/1000 ft	2.96 + J 1.28	PU			
CBL-0006	101 MDPH1	103 H1L2	1	480	100.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft	4.60 + J 1.74	PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft	14.50 + J 4.28	PU			
CBL-0007	101 MDPH1	104 H1L3	1	480	160.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0602 + J 0.0393	Ohms/1000 ft	4.18 + J 2.73	PU			
	Z0 Impedance: 0.1897 + J 0.0968	Ohms/1000 ft	13.17 + J 6.72	PU			
CBL-0008	101 MDPH1	105 H1L4	2	480	290.0 FEET	350	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0520 + J 0.0388	Ohms/1000 ft	3.27 + J 2.44	PU			
	Z0 Impedance: 0.1639 + J 0.0956	Ohms/1000 ft	10.31 + J 6.02	PU			
CBL-0009	105 H1L4	BUS-0011	1	480	20.0 FEET	4/0	Copper
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.0534 + J 0.0393	Ohms/1000 ft	0.4635 + J 0.3411	PU			
	Z0 Impedance: 0.1683 + J 0.0968	Ohms/1000 ft	1.46 + J 0.8403	PU			

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0010	BUS-0012	106 MD/G	2	208	20.0 FEET	350	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0333 + J 0.0388 Ohms/1000 ft	0.7697 + J 0.8968 PU					
	Z0 Impedance: 0.1050 + J 0.0956 Ohms/1000 ft	2.43 + J 2.21 PU					
CBL-0011	106 MD/G	107 G/GA	1	208	20.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0602 + J 0.0393 Ohms/1000 ft	2.78 + J 1.82 PU					
	Z0 Impedance: 0.1897 + J 0.0968 Ohms/1000 ft	8.77 + J 4.47 PU					
CBL-0017	101 MDPH1	BUS-0036	4	480	40.0 FEET	350	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0520 + J 0.0388 Ohms/1000 ft	0.2257 + J 0.1684 PU					
	Z0 Impedance: 0.1639 + J 0.0956 Ohms/1000 ft	0.7114 + J 0.4149 PU					
CBL-0018	108 SDPL1	109 L1M1	1	208	500.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0722 + J 0.0399 Ohms/1000 ft	83.44 + J 46.11 PU					
	Z0 Impedance: 0.2275 + J 0.0983 Ohms/1000 ft	262.92 + J 113.60 PU					
CBL-0019	108 SDPL1	110 L1L1	2	208	80.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379 Ohms/1000 ft	3.47 + J 3.50 PU					
	Z0 Impedance: 0.1182 + J 0.0933 Ohms/1000 ft	10.93 + J 8.63 PU					
CBL-0020	108 SDPL1	111 L1L2	2	208	130.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379 Ohms/1000 ft	5.63 + J 5.69 PU					
	Z0 Impedance: 0.1182 + J 0.0933 Ohms/1000 ft	17.76 + J 14.02 PU					
CBL-0021	108 SDPL1	112 L1L3	2	208	170.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0722 + J 0.0399 Ohms/1000 ft	14.19 + J 7.84 PU					
	Z0 Impedance: 0.2275 + J 0.0983 Ohms/1000 ft	44.70 + J 19.31 PU					
CBL-0022	108 SDPL1	114 L1L4	1	208	260.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0602 + J 0.0393 Ohms/1000 ft	36.18 + J 23.62 PU					
	Z0 Impedance: 0.1897 + J 0.0968 Ohms/1000 ft	114.00 + J 58.17 PU					
CBL-0023	108 SDPL1	115 L1L5	1	208	300.0 FEET	400	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0460 + J 0.0385 Ohms/1000 ft	31.90 + J 26.70 PU					
	Z0 Impedance: 0.1450 + J 0.0948 Ohms/1000 ft	100.55 + J 65.74 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0024	108 SDPL1	116 L1L6	1	208	100.0 FEET	2/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1330 + J 0.0409 Ohms/1000 ft	30.74 + J 9.45 PU					
	Z0 Impedance: 0.4192 + J 0.1007 Ohms/1000 ft	96.89 + J 23.28 PU					
CBL-0025	108 SDPL1	117 L1B1	1	208	40.0 FEET	2/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1330 + J 0.0409 Ohms/1000 ft	12.30 + J 3.78 PU					
	Z0 Impedance: 0.4192 + J 0.1007 Ohms/1000 ft	38.76 + J 9.31 PU					
CBL-0026	108 SDPL1	118 L1B2	1	208	260.0 FEET	1/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1680 + J 0.0417 Ohms/1000 ft	100.96 + J 25.06 PU					
	Z0 Impedance: 0.5295 + J 0.1027 Ohms/1000 ft	318.21 + J 61.72 PU					
CBL-0027	112 L1L3	113 L1L31	1	208	20.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	4.90 + J 1.85 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	15.44 + J 4.55 PU					
CBL-0028	101 MDPH1	119 H1B1	1	480	60.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	5.49 + J 1.11 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	17.32 + J 2.74 PU					
CBL-0029	303 E1B1	304 E1L1	1	480	100.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0475 Ohms/1000 ft	27.80 + J 2.06 PU					
	Z0 Impedance: 2.02 + J 0.1170 Ohms/1000 ft	87.60 + J 5.08 PU					
CBL-0030	303 E1B1	305 E1L2	1	480	340.0 FEET	3	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2050 + J 0.0430 Ohms/1000 ft	30.25 + J 6.35 PU					
	Z0 Impedance: 0.6461 + J 0.1059 Ohms/1000 ft	95.34 + J 15.63 PU					
CBL-0031	200 UTC2_MDPH2	201 MDPH2	16	480	100.0 FEET	700	Aluminum
	Duct Material: Non-Magnetic	Insulation Type: XLPE		Insulation Class:	XHHW-2		
	+/- Impedance: 0.0340 + J 0.0380 Ohms/1000 ft	0.0922 + J 0.1031 PU					
	Z0 Impedance: 0.0540 + J 0.0967 Ohms/1000 ft	0.1465 + J 0.2623 PU					
CBL-0032	303 E1B1	BUS-0013	1	480	30.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0437 Ohms/1000 ft	5.34 + J 0.5690 PU					
	Z0 Impedance: 1.29 + J 0.1076 Ohms/1000 ft	16.82 + J 1.40 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0033	BUS-0037	108 SDPL1	6	208	40.0 FEET	600	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0319 + J 0.0382 Ohms/1000 ft	0.4916 + J 0.5886 PU					
	Z0 Impedance: 0.1005 + J 0.0941 Ohms/1000 ft	1.55 + J 1.45 PU					
CBL-0034	BUS-0014	306 E1BL1	1	208	20.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	9.75 + J 1.97 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	30.74 + J 4.86 PU					
CBL-0035	101 MDPH1	BUS-0039	1	480	80.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	7.33 + J 1.48 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	23.09 + J 3.65 PU					
CBL-0036	300 GEN SEC	BUS-0040	1	480	150.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	13.74 + J 2.78 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	43.29 + J 6.85 PU					
CBL-0037	301 ATS_E1B1	303 E1B1	1	480	20.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	1.83 + J 0.3707 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	5.77 + J 0.9132 PU					
CBL-0038	306 E1BL1	307 E1BL2	1	208	30.0 FEET	4	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2590 + J 0.0441 Ohms/1000 ft	17.96 + J 3.06 PU					
	Z0 Impedance: 0.8163 + J 0.1086 Ohms/1000 ft	56.60 + J 7.53 PU					
CBL-0039	BUS-0003	200 UTC2_MDPH2	9	480	100.0 FEET	600	Copper
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.0209 + J 0.0382 Ohms/1000 ft	0.1008 + J 0.1842 PU					
	Z0 Impedance: 0.0659 + J 0.0941 Ohms/1000 ft	0.3178 + J 0.4538 PU					
CBL-0040	300 GEN SEC	BUS-0128	1	480	200.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	9.20 + J 3.47 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	29.00 + J 8.55 PU					
CBL-0046	201 MDPH2	BUS-0055	2	480	30.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379 Ohms/1000 ft	0.2441 + J 0.2467 PU					
	Z0 Impedance: 0.1182 + J 0.0933 Ohms/1000 ft	0.7695 + J 0.6074 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0047	BUS-0056	202 SDPL2	4	208	30.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0375 + J 0.0379 Ohms/1000 ft	0.6501 + J 0.6570 PU					
	Z0 Impedance: 0.1182 + J 0.0933 Ohms/1000 ft	2.05 + J 1.62 PU					
CBL-0048	201 MDPH2	ACC-1	2	480	460.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0602 + J 0.0393 Ohms/1000 ft	6.01 + J 3.92 PU					
	Z0 Impedance: 0.1897 + J 0.0968 Ohms/1000 ft	18.94 + J 9.66 PU					
CBL-0049	201 MDPH2	209 H2M1	1	480	100.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0602 + J 0.0393 Ohms/1000 ft	2.61 + J 1.71 PU					
	Z0 Impedance: 0.1897 + J 0.0968 Ohms/1000 ft	8.23 + J 4.20 PU					
CBL-0050	201 MDPH2	210 H2M2	2	480	150.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0722 + J 0.0399 Ohms/1000 ft	2.35 + J 1.30 PU					
	Z0 Impedance: 0.2275 + J 0.0983 Ohms/1000 ft	7.41 + J 3.20 PU					
CBL-0051	201 MDPH2	211 H2B2	2	480	30.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0722 + J 0.0399 Ohms/1000 ft	0.4701 + J 0.2598 PU					
	Z0 Impedance: 0.2275 + J 0.0983 Ohms/1000 ft	1.48 + J 0.6400 PU					
CBL-0053	201 MDPH2	212 H2B1	1	480	40.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.4100 + J 0.0437 Ohms/1000 ft	7.12 + J 0.7587 PU					
	Z0 Impedance: 1.29 + J 0.1076 Ohms/1000 ft	22.43 + J 1.87 PU					
CBL-0054	201 MDPH2	213 SDPH21	4	480	500.0 FEET	350	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0520 + J 0.0388 Ohms/1000 ft	2.82 + J 2.11 PU					
	Z0 Impedance: 0.1639 + J 0.0956 Ohms/1000 ft	8.89 + J 5.19 PU					
CBL-0055	201 MDPH2	229 SDPH22	4	480	750.0 FEET	600	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0319 + J 0.0382 Ohms/1000 ft	2.60 + J 3.11 PU					
	Z0 Impedance: 0.1005 + J 0.0941 Ohms/1000 ft	8.18 + J 7.66 PU					
CBL-0056	201 MDPH2	BUS-0129	1	480	50.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	2.30 + J 0.8681 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	7.25 + J 2.14 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0057	302 ATS_E2B1	308 E2B1	1	480	20.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	0.9201 + J 0.3472 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	2.90 + J 0.8550 PU					
CBL-0058	308 E2B1	312 E2M1	1	480	100.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0475 Ohms/1000 ft	27.80 + J 2.06 PU					
	Z0 Impedance: 2.02 + J 0.1170 Ohms/1000 ft	87.60 + J 5.08 PU					
CBL-0059	308 E2B1	BUS-0070	1	480	100.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	9.16 + J 1.85 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	28.86 + J 4.57 PU					
CBL-0060	BUS-0072	309 E2BL1	1	208	20.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.0722 + J 0.0399 Ohms/1000 ft	3.34 + J 1.84 PU					
	Z0 Impedance: 0.2275 + J 0.0983 Ohms/1000 ft	10.52 + J 4.54 PU					
CBL-0061	309 E2BL1	310 E2BL2	1	208	450.0 FEET	4/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.0844 + J 0.0393 Ohms/1000 ft	87.79 + J 40.88 PU					
	Z0 Impedance: 0.2660 + J 0.0968 Ohms/1000 ft	276.67 + J 100.68 PU					
CBL-0062	310 E2BL2	311 E2BL3	1	208	290.0 FEET	2/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.1330 + J 0.0409 Ohms/1000 ft	89.15 + J 27.42 PU					
	Z0 Impedance: 0.4192 + J 0.1007 Ohms/1000 ft	280.99 + J 67.50 PU					
CBL-0063	308 E2B1	313 E2B2	1	480	480.0 FEET	1/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.1680 + J 0.0417 Ohms/1000 ft	35.00 + J 8.69 PU					
	Z0 Impedance: 0.5295 + J 0.1027 Ohms/1000 ft	110.31 + J 21.40 PU					
CBL-0064	313 E2B2	314 E2M3	1	480	80.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0475 Ohms/1000 ft	22.24 + J 1.65 PU					
	Z0 Impedance: 2.02 + J 0.1170 Ohms/1000 ft	70.08 + J 4.06 PU					
CBL-0065	313 E2B2	315 E2U1	1	480	100.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THWN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0475 Ohms/1000 ft	27.80 + J 2.06 PU					
	Z0 Impedance: 2.02 + J 0.1170 Ohms/1000 ft	87.60 + J 5.08 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0066	313 E2B2	316 E2B3	1	480	290.0 FEET	3	Copper
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.2050 + J 0.0430	Ohms/1000 ft 25.80 + J 5.41	PU				
	Z0 Impedance: 0.6461 + J 0.1059	Ohms/1000 ft 81.32 + J 13.33	PU				
CBL-0067	316 E2B3	317 E2M2	1	480	140.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.6404 + J 0.0475	Ohms/1000 ft 38.91 + J 2.89	PU				
	Z0 Impedance: 2.02 + J 0.1170	Ohms/1000 ft 122.63 + J 7.11	PU				
CBL-0068	316 E2B3	318 E2U2	1	480	160.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THWN	Insulation Class:				
	+/- Impedance: 0.6404 + J 0.0475	Ohms/1000 ft 44.47 + J 3.30	PU				
	Z0 Impedance: 2.02 + J 0.1170	Ohms/1000 ft 140.15 + J 8.13	PU				
CBL-0069	202 SDPL2	203 L2M1	4	208	200.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0375 + J 0.0379	Ohms/1000 ft 4.33 + J 4.38	PU				
	Z0 Impedance: 0.1182 + J 0.0933	Ohms/1000 ft 13.66 + J 10.78	PU				
CBL-0070	203 L2M1	204 L2M11	1	208	40.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0375 + J 0.0379	Ohms/1000 ft 3.47 + J 3.50	PU				
	Z0 Impedance: 0.1182 + J 0.0933	Ohms/1000 ft 10.93 + J 8.63	PU				
CBL-0071	202 SDPL2	205 L2M2	2	208	120.0 FEET	250	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0722 + J 0.0399	Ohms/1000 ft 10.01 + J 5.53	PU				
	Z0 Impedance: 0.2275 + J 0.0983	Ohms/1000 ft 31.55 + J 13.63	PU				
CBL-0072	205 L2M2	206 L2M21	1	208	20.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.4100 + J 0.0437	Ohms/1000 ft 18.95 + J 2.02	PU				
	Z0 Impedance: 1.29 + J 0.1076	Ohms/1000 ft 59.73 + J 4.97	PU				
CBL-0073	202 SDPL2	208 L2B1	1	208	30.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.2110 + J 0.0427	Ohms/1000 ft 14.63 + J 2.96	PU				
	Z0 Impedance: 0.6650 + J 0.1052	Ohms/1000 ft 46.11 + J 7.29	PU				
CBL-0074	202 SDPL2	207 L2B2	1	208	100.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0602 + J 0.0393	Ohms/1000 ft 13.91 + J 9.08	PU				
	Z0 Impedance: 0.1897 + J 0.0968	Ohms/1000 ft 43.85 + J 22.37	PU				

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0075	213 SDPH21	BUS-0057	2	480	30.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379 Ohms/1000 ft	0.2441 + J 0.2467 PU					
	Z0 Impedance: 0.1182 + J 0.0933 Ohms/1000 ft	0.7695 + J 0.6074 PU					
CBL-0076	BUS-0058	217 SDPL21	4	208	30.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379 Ohms/1000 ft	0.6501 + J 0.6570 PU					
	Z0 Impedance: 0.1182 + J 0.0933 Ohms/1000 ft	2.05 + J 1.62 PU					
CBL-0077	217 SDPL21	218 L21U1	1	208	100.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	24.50 + J 9.25 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	77.22 + J 22.77 PU					
CBL-0078	217 SDPL21	219 L21U2	1	208	250.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	61.25 + J 23.11 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	193.06 + J 56.92 PU					
CBL-0079	217 SDPL21	220 L21U3	1	208	130.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	31.85 + J 12.02 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	100.39 + J 29.60 PU					
CBL-0080	217 SDPL21	221 L21U4	1	208	220.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	53.90 + J 20.34 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	169.89 + J 50.09 PU					
CBL-0081	217 SDPL21	222 L21U5	1	208	90.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	22.05 + J 8.32 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	69.50 + J 20.49 PU					
CBL-0082	217 SDPL21	223 L21M1	1	208	270.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0602 + J 0.0393 Ohms/1000 ft	37.57 + J 24.53 PU					
	Z0 Impedance: 0.1897 + J 0.0968 Ohms/1000 ft	118.39 + J 60.41 PU					
CBL-0083	223 L21M1	224 L21M11	1	208	20.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427 Ohms/1000 ft	9.75 + J 1.97 PU					
	Z0 Impedance: 0.6650 + J 0.1052 Ohms/1000 ft	30.74 + J 4.86 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0084	217 SDPL21	225 L21M2	1	208	100.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 24.50 + J 9.25		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 77.22 + J 22.77		PU			
CBL-0085	217 SDPL21	226 L21M3	1	208	220.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0602 + J 0.0393	Ohms/1000 ft 30.61 + J 19.98		PU			
	Z0 Impedance: 0.1897 + J 0.0968	Ohms/1000 ft 96.46 + J 49.22		PU			
CBL-0086	217 SDPL21	227 L21M4	1	208	60.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 14.70 + J 5.55		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 46.33 + J 13.66		PU			
CBL-0087	217 SDPL21	228 L21B1	1	208	10.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0437	Ohms/1000 ft 9.48 + J 1.01		PU			
	Z0 Impedance: 1.29 + J 0.1076	Ohms/1000 ft 29.87 + J 2.49		PU			
CBL-0088	213 SDPH21	216 H21U1	1	480	120.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427	Ohms/1000 ft 10.99 + J 2.22		PU			
	Z0 Impedance: 0.6650 + J 0.1052	Ohms/1000 ft 34.64 + J 5.48		PU			
CBL-0089	213 SDPH21	215 H21M1	1	480	80.0 FEET	1	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2110 + J 0.0427	Ohms/1000 ft 7.33 + J 1.48		PU			
	Z0 Impedance: 0.6650 + J 0.1052	Ohms/1000 ft 23.09 + J 3.65		PU			
CBL-0090	213 SDPH21	214 H21B1	1	480	30.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0437	Ohms/1000 ft 5.34 + J 0.5690		PU			
	Z0 Impedance: 1.29 + J 0.1076	Ohms/1000 ft 16.82 + J 1.40		PU			
CBL-0091	229 SDPH22	BUS-0059	2	480	20.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379	Ohms/1000 ft 0.1628 + J 0.1645		PU			
	Z0 Impedance: 0.1182 + J 0.0933	Ohms/1000 ft 0.5130 + J 0.4049		PU			
CBL-0092	BUS-0060	233 SDPL22	4	208	20.0 FEET	500	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0375 + J 0.0379	Ohms/1000 ft 0.4334 + J 0.4380		PU			
	Z0 Impedance: 0.1182 + J 0.0933	Ohms/1000 ft 1.37 + J 1.08		PU			

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0093	233 SDPL22	234 L22U1	1	208	110.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 26.95 + J 10.17		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 84.95 + J 25.04		PU			
CBL-0094	233 SDPL22	235 L22U2	1	208	130.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 31.85 + J 12.02		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 100.39 + J 29.60		PU			
CBL-0095	233 SDPL22	236 L22U3	1	208	180.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 44.10 + J 16.64		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 139.00 + J 40.98		PU			
CBL-0096	233 SDPL22	237 L22U4	1	208	120.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 29.40 + J 11.09		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 92.67 + J 27.32		PU			
CBL-0097	233 SDPL22	238 L22U5	1	208	140.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 34.30 + J 12.94		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 108.11 + J 31.87		PU			
CBL-0098	233 SDPL22	239 L22M1	1	208	110.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 26.95 + J 10.17		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 84.95 + J 25.04		PU			
CBL-0099	233 SDPL22	240 L22M2	1	208	140.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 34.30 + J 12.94		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 108.11 + J 31.87		PU			
CBL-0100	233 SDPL22	241 L22M3	1	208	140.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 34.30 + J 12.94		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 108.11 + J 31.87		PU			
CBL-0101	233 SDPL22	242 L22M4	1	208	150.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400	Ohms/1000 ft 36.75 + J 13.87		PU			
	Z0 Impedance: 0.3341 + J 0.0985	Ohms/1000 ft 115.84 + J 34.15		PU			

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CBL-0102	233 SDPL22	243 L22M5	1	208	180.0 FEET	300	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0602 + J 0.0393 Ohms/1000 ft	25.05 + J 16.35 PU					
	Z0 Impedance: 0.1897 + J 0.0968 Ohms/1000 ft	78.92 + J 40.27 PU					
CBL-0103	233 SDPL22	244 L22M6	1	208	170.0 FEET	3/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1060 + J 0.0400 Ohms/1000 ft	41.65 + J 15.72 PU					
	Z0 Impedance: 0.3341 + J 0.0985 Ohms/1000 ft	131.28 + J 38.70 PU					
CBL-0104	233 SDPL22	245 L22B1	1	208	30.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0437 Ohms/1000 ft	28.43 + J 3.03 PU					
	Z0 Impedance: 1.29 + J 0.1076 Ohms/1000 ft	89.60 + J 7.46 PU					
CBL-0105	229 SDPH22	231 H22M1	1	480	120.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0437 Ohms/1000 ft	21.35 + J 2.28 PU					
	Z0 Impedance: 1.29 + J 0.1076 Ohms/1000 ft	67.30 + J 5.60 PU					
CBL-0106	229 SDPH22	232 H22U1	1	480	120.0 FEET	2/0	Aluminum
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1330 + J 0.0409 Ohms/1000 ft	6.93 + J 2.13 PU					
	Z0 Impedance: 0.4192 + J 0.1007 Ohms/1000 ft	21.83 + J 5.24 PU					
CBL-0107	229 SDPH22	230 H22B1	1	480	20.0 FEET	6	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0437 Ohms/1000 ft	3.56 + J 0.3793 PU					
	Z0 Impedance: 1.29 + J 0.1076 Ohms/1000 ft	11.22 + J 0.9340 PU					

TRANSFORMER INPUT DATA

TRANSFORMER NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	NOMINAL KVA
TE1	BUS-0013	D 480.00	BUS-0014	YG 208.00	45.00	45.00
	Pos. Seq. Z%: 4.39 + J 3.95 (Zpu 97.45 + j 87.71)		Shell Type			
	Zero Seq. Z%: 4.39 + J 3.95 (Sec 97.45 + j 87.71 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
TE2	BUS-0070	D 480.00	BUS-0072	YG 208.00	75.00	75.00
	Pos. Seq. Z%: 3.48 + J 4.52 (Zpu 46.34 + j 60.24)		Shell Type			
	Zero Seq. Z%: 3.48 + J 4.52 (Sec 46.34 + j 60.24 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
XF2-0001	UTILITY PRI	D 13200.0	BUS-0002	YG 480.00	1500.00	1500.00
	Pos. Seq. Z%: 0.699 + J 5.74 (Zpu 0.466 + j 3.83)		Shell Type			
	Zero Seq. Z%: 0.699 + J 5.74 (Sec 0.466 + j 3.83 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
XF2-0004	UTILITY PRI 2	D 13200.0	BUS-0003	YG 480.00	1500.00	1500.00
	Pos. Seq. Z%: 0.699 + J 5.74 (Zpu 0.466 + j 3.83)		Shell Type			
	Zero Seq. Z%: 0.699 + J 5.74 (Sec 0.466 + j 3.83 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
XFMR_MD/G	BUS-0011	D 480.00	BUS-0012	YG 208.00	150.00	150.00
	Pos. Seq. Z%: 1.93 + J 5.18 (Zpu 12.85 + j 34.56)		Shell Type			
	Zero Seq. Z%: 1.93 + J 5.18 (Sec 12.85 + j 34.56 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
XFMR_SDPL1	BUS-0036	D 480.00	BUS-0037	YG 208.00	750.00	750.00
	Pos. Seq. Z%: 0.782 + J 5.24 (Zpu 1.04 + j 6.99)		Shell Type			
	Zero Seq. Z%: 0.782 + J 5.24 (Sec 1.04 + j 6.99 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

TRANSFORMER INPUT DATA

TRANSFORMER NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	NOMINAL KVA
XFMR_SDPL2	BUS-0055	D 480.00	BUS-0056	YG 208.00	500.00	500.00
	Pos. Seq. Z%: 1.72 + J 5.85 (Zpu 3.43 + j 11.71)		Shell Type			
	Zero Seq. Z%: 1.72 + J 5.85 (Sec 3.43 + j 11.71 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
XFMR_SDPL21	BUS-0057	D 480.00	BUS-0058	YG 208.00	500.00	500.00
	Pos. Seq. Z%: 1.72 + J 5.85 (Zpu 3.43 + j 11.71)		Shell Type			
	Zero Seq. Z%: 1.72 + J 5.85 (Sec 3.43 + j 11.71 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
XFMR_SDPL22	BUS-0059	D 480.00	BUS-0060	YG 208.00	500.00	500.00
	Pos. Seq. Z%: 1.72 + J 5.85 (Zpu 3.43 + j 11.71)		Shell Type			
	Zero Seq. Z%: 1.72 + J 5.85 (Sec 3.43 + j 11.71 Pri Open)					
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

GENERATION CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE L-L	MVA	X*d	X/R
300 GEN SEC	GEN-1	480.00	0.250	0.1500	12.40
	KG: 0.9174 xdsat: 2.05 Excitation Limit: 1.30 Ik - ON				
	Pos Sequence Impedance (100 MVA Base) 4.84 + J 60.00 PU				
UTILITY PRI	UTIL-0001	13200.0	1829.05		
	Three Phase Contribution: 80000.0 AMPS 8.00				
	Single Line to Ground Contribution: 80000.0 AMPS 8.00				
	Pos Sequence Impedance (100 MVA Base) 0.0068 + J 0.0543 PU				
	Zero Sequence Impedance (100 MVA Base) 0.0068 + J 0.0543 PU				
UTILITY PRI 2	UTIL-0003	13200.0	1829.05		
	Three Phase Contribution: 80000.0 AMPS 8.00				
	Single Line to Ground Contribution: 80000.0 AMPS 8.00				
	Pos Sequence Impedance (100 MVA Base) 0.0068 + J 0.0543 PU				
	Zero Sequence Impedance (100 MVA Base) 0.0068 + J 0.0543 PU				

MOTOR CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME		VOLTAGE L-L	BASE kVA	X"d	X/R	Motor Number
101 MDPH1	Pos	MDPH1 MOTOR LOAD	480	375.00	0.2500	10.0	1.00
	Sequence	Impedance (100 MVA Base)	6.67 + j	66.67 PU			
201 MDPH2	Pos	MDPH2 MOTOR LOAD	480	375.00	0.2500	10.0	1.00
	Sequence	Impedance (100 MVA Base)	6.67 + j	66.67 PU			
ACC-1	Pos	MTRI-0005	480	275.74	0.2000	10.0	1.00
	Sequence	Impedance (100 MVA Base)	7.25 + j	72.53 PU			
ACC-2	Pos	MTRI-0003	480	275.74	0.2000	10.0	1.00
	Sequence	Impedance (100 MVA Base)	7.25 + j	72.53 PU			
ACC-3	Pos	MTRI-0004	480	75.20	0.2000	10.0	1.00
	Sequence	Impedance (100 MVA Base)	26.59 + j	265.95 PU			

APPENDIX C: SHORT CIRCUIT OUTPUT TABULATIONS

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
100 UTC_MDPH1          3P Duty: 34.442 KA AT -82.96 DEG ( 28.63 MVA) X/R:      8.11
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0010 + J 0.0080 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 35.672 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 37.875 KA
CBL-0001              BUS-0002              30.623 KA      ANG: -82.93
CBL-0002              101 MDPH1             3.818 KA      ANG: 96.83

101 MDPH1              3P Duty: 32.770 KA AT -81.07 DEG ( 27.24 MVA) X/R:      6.46
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0013 + J 0.0084 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 32.770 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 34.666 KA
CONTRIBUTIONS: MDPH1 MOTOR LOAD
CBL-0003              ACC-2                1.795 KA      ANG: -84.29
CBL-0004              ACC-3                1.606 KA      ANG: 97.47
CBL-0002              100 UTC_MDPH1         0.445 KA      ANG: 96.54
CBL-0002              100 UTC_MDPH1         28.927 KA     ANG: -80.76

102 H1L1              3P Duty: 27.263 KA AT -69.99 DEG ( 22.67 MVA) X/R:      2.76
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0035 + J 0.0096 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 27.263 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 27.263 KA
CBL-0005              101 MDPH1             27.263 KA     ANG: -69.99

103 H1L2              3P Duty: 16.148 KA AT -46.04 DEG ( 13.43 MVA) X/R:      1.04
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0119 + J 0.0124 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 16.148 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 16.148 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 16.148 KA
CBL-0006              101 MDPH1             16.148 KA     ANG: -46.04

104 H1L3              3P Duty: 15.160 KA AT -53.22 DEG ( 12.60 MVA) X/R:      1.34
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0109 + J 0.0146 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 15.160 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 15.160 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 15.160 KA
CBL-0007              101 MDPH1             15.160 KA     ANG: -53.22

105 H1L4              3P Duty: 16.748 KA AT -57.66 DEG ( 13.92 MVA) X/R:      1.58
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0089 + J 0.0140 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 16.748 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 16.748 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 16.748 KA
CBL-0008              101 MDPH1             16.748 KA     ANG: -57.66

```

T H R E E P H A S E F A U L T R E P O R T
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

```

=====
106 MD/G          3P Duty: 6.096 KA AT -66.82 DEG ( 2.20 MVA) X/R: 2.34
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0078 + J 0.0181 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.096 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.608 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.096 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.096 KA
CBL-0010          BUS-0012          6.096 KA    ANG: -66.82

107 G/GA          3P Duty: 5.742 KA AT -64.64 DEG ( 2.07 MVA) X/R: 2.11
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0090 + J 0.0189 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.742 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.052 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.742 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.742 KA
CBL-0011          106 MD/G          5.742 KA    ANG: -64.64

108 SDPL1         3P Duty: 23.911 KA AT -78.42 DEG ( 8.61 MVA) X/R: 4.90
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0010 + J 0.0049 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 23.911 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 23.911 KA
CBL-0033          BUS-0037          23.911 KA    ANG: -258.42

109 L1M1          3P Duty: 2.688 KA AT -33.83 DEG ( 0.97 MVA) X/R: 0.67
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0371 + J 0.0249 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 2.688 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 2.688 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 2.688 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 2.688 KA
CBL-0018          108 SDPL1          2.688 KA    ANG: -33.83

110 L1L1          3P Duty: 17.385 KA AT -68.71 DEG ( 6.26 MVA) X/R: 2.57
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0025 + J 0.0064 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 17.385 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 17.385 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 17.385 KA
CBL-0019          108 SDPL1          17.385 KA    ANG: -68.71

111 L1L2          3P Duty: 14.738 KA AT -64.98 DEG ( 5.31 MVA) X/R: 2.15
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0034 + J 0.0074 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 14.738 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 14.738 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 14.738 KA
CBL-0020          108 SDPL1          14.738 KA    ANG: -64.98
  
```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
112 L1L3          3P Duty: 10.956 KA AT -49.32 DEG ( 3.95 MVA) X/R: 1.16
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0071 + J 0.0083 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 10.956 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 10.956 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 10.956 KA
CBL-0021          108 SDPL1          10.956 KA      ANG: -49.32

113 L1L31         3P Duty: 9.241 KA AT -44.52 DEG ( 3.33 MVA) X/R: 0.98
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0093 + J 0.0091 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 9.241 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 9.241 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 9.241 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 9.241 KA
CBL-0027          112 L1L3          9.241 KA      ANG: -44.52

114 L1L4         3P Duty: 5.335 KA AT -42.26 DEG ( 1.92 MVA) X/R: 0.91
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0167 + J 0.0151 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.335 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.335 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.335 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.335 KA
CBL-0022          108 SDPL1          5.335 KA      ANG: -42.26

115 L1L5         3P Duty: 5.422 KA AT -48.04 DEG ( 1.95 MVA) X/R: 1.11
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0148 + J 0.0165 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.422 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.422 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.422 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.422 KA
CBL-0023          108 SDPL1          5.422 KA      ANG: -48.04

116 L1L6         3P Duty: 7.102 KA AT -32.20 DEG ( 2.56 MVA) X/R: 0.63
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0143 + J 0.0090 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 7.102 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 7.102 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 7.102 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 7.102 KA
CBL-0024          108 SDPL1          7.102 KA      ANG: -32.20

117 L1B1         3P Duty: 13.179 KA AT -46.01 DEG ( 4.75 MVA) X/R: 1.04
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0063 + J 0.0066 OHMS

```

THREE PHASE FAULT REPORT
(FOR APPLICATION OF LOW VOLTAGE BREAKERS)
PRE FAULT VOLTAGE: 1.0000
MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER 13.179 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 13.179 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 13.179 KA
CBL-0025 108 SDPL1 13.179 KA ANG: -46.01

118 L1B2 3P Duty: 2.534 KA AT -19.43 DEG ( 0.91 MVA) X/R: 0.35
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0447 + J 0.0158 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 2.534 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 2.534 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 2.534 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 2.534 KA
CBL-0026 108 SDPL1 2.534 KA ANG: -19.43

119 H1B1 3P Duty: 15.630 KA AT -38.00 DEG ( 12.99 MVA) X/R: 0.78
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0140 + J 0.0109 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 15.630 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 15.630 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 15.630 KA
CBL-0028 101 MDPH1 15.630 KA ANG: -38.00

200 UTC2_MDPH2 3P Duty: 32.642 KA AT -81.99 DEG ( 27.14 MVA) X/R: 7.16
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0012 + J 0.0084 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 33.126 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 35.171 KA
CBL-0039 BUS-0003 29.310 KA ANG: -261.96
CBL-0031 201 MDPH2 3.333 KA ANG: -82.25

201 MDPH2 3P Duty: 31.848 KA AT -81.07 DEG ( 26.48 MVA) X/R: 6.44
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0014 + J 0.0086 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 31.848 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 33.670 KA
CONTRIBUTIONS: MDPH2 MOTOR LOAD 1.795 KA ANG: -84.29
CBL-0048 ACC-1 1.550 KA ANG: -260.16
CBL-0031 200 UTC2_MDPH2 28.506 KA ANG: -260.91

202 SDPL2 3P Duty: 16.266 KA AT -73.26 DEG ( 5.86 MVA) X/R: 3.33
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0021 + J 0.0071 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 16.266 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 16.468 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 16.266 KA
CBL-0047 BUS-0056 16.266 KA ANG: -73.26

203 L2M1 3P Duty: 12.232 KA AT -65.95 DEG ( 4.41 MVA) X/R: 2.24
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0040 + J 0.0090 OHMS

```

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER 12.232 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 12.232 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 12.232 KA
CBL-0069 202 SDPL2 12.232 KA ANG: -65.95

204 L2M11 3P Duty: 10.145 KA AT -62.31 DEG ( 3.66 MVA) X/R: 1.91
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0055 + J 0.0105 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 10.145 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 10.145 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 10.145 KA
CBL-0070 203 L2M1 10.145 KA ANG: -62.31

205 L2M2 3P Duty: 10.481 KA AT -55.69 DEG ( 3.78 MVA) X/R: 1.47
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0065 + J 0.0095 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 10.481 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 10.481 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 10.481 KA
CBL-0071 202 SDPL2 10.481 KA ANG: -55.69

206 L2M21 3P Duty: 6.695 KA AT -35.19 DEG ( 2.41 MVA) X/R: 0.71
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0147 + J 0.0103 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.695 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.695 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.695 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.695 KA
CBL-0072 205 L2M2 6.695 KA ANG: -35.19

207 L2B2 3P Duty: 8.773 KA AT -53.48 DEG ( 3.16 MVA) X/R: 1.35
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0081 + J 0.0110 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 8.773 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 8.773 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 8.773 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 8.773 KA
CBL-0074 202 SDPL2 8.773 KA ANG: -53.48

208 L2B1 3P Duty: 10.105 KA AT -44.64 DEG ( 3.64 MVA) X/R: 0.99
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0085 + J 0.0084 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 10.105 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 10.105 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 10.105 KA
CBL-0073 202 SDPL2 10.105 KA ANG: -44.64

209 H2M1 3P Duty: 19.068 KA AT -59.53 DEG ( 15.85 MVA) X/R: 1.70
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0074 + J 0.0125 OHMS
  
```

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER 19.068 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 19.068 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 19.068 KA
CBL-0049 201 MDPH2 19.068 KA ANG: -59.53

210 H2M2 3P Duty: 20.652 KA AT -59.72 DEG ( 17.17 MVA) X/R: 1.72
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0068 + J 0.0116 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 20.652 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 20.652 KA
CBL-0050 201 MDPH2 20.652 KA ANG: -59.72

211 H2B2 3P Duty: 29.137 KA AT -75.17 DEG ( 24.22 MVA) X/R: 3.80
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0024 + J 0.0092 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 29.137 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 29.137 KA
CBL-0051 201 MDPH2 29.137 KA ANG: -75.17

212 H2B1 3P Duty: 13.489 KA AT -30.23 DEG ( 11.21 MVA) X/R: 0.58
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0178 + J 0.0103 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 13.489 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 13.489 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 13.489 KA
CBL-0053 201 MDPH2 13.489 KA ANG: -30.23

213 SDPH21 3P Duty: 17.799 KA AT -59.72 DEG ( 14.80 MVA) X/R: 1.72
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0079 + J 0.0134 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 17.799 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 17.799 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 17.799 KA
CBL-0054 201 MDPH2 17.799 KA ANG: -59.72

214 H21B1 3P Duty: 11.096 KA AT -36.22 DEG ( 9.22 MVA) X/R: 0.73
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0202 + J 0.0148 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 11.096 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 11.096 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 11.096 KA
CBL-0090 213 SDPH21 11.096 KA ANG: -36.22

215 H21M1 3P Duty: 9.258 KA AT -34.29 DEG ( 7.70 MVA) X/R: 0.68
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0247 + J 0.0169 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 9.258 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 9.258 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 9.258 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 9.258 KA
  
```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
CONTRIBUTIONS TO 215 H21M1 (CONTINUED)
CBL-0089 213 SDPH21 9.258 KA ANG: -34.29

216 H21U1 3P Duty: 7.290 KA AT -29.24 DEG ( 6.06 MVA) X/R: 0.56
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0332 + J 0.0186 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 7.290 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 7.290 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 7.290 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 7.290 KA
CBL-0088 213 SDPH21 7.290 KA ANG: -29.24

217 SDPL21 3P Duty: 13.877 KA AT -67.25 DEG ( 5.00 MVA) X/R: 2.39
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0033 + J 0.0080 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 13.877 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 13.877 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 13.877 KA
CBL-0076 BUS-0058 13.877 KA ANG: -67.25

218 L21U1 3P Duty: 6.532 KA AT -40.66 DEG ( 2.35 MVA) X/R: 0.86
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0139 + J 0.0120 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.532 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.532 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.532 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.532 KA
CBL-0077 217 SDPL21 6.532 KA ANG: -40.66

219 L21U2 3P Duty: 3.446 KA AT -31.07 DEG ( 1.24 MVA) X/R: 0.60
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0298 + J 0.0180 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 3.446 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 3.446 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 3.446 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 3.446 KA
CBL-0078 217 SDPL21 3.446 KA ANG: -31.07

220 L21U3 3P Duty: 5.557 KA AT -37.58 DEG ( 2.00 MVA) X/R: 0.77
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0171 + J 0.0132 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.557 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.557 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.557 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.557 KA
CBL-0079 217 SDPL21 5.557 KA ANG: -37.58

221 L21U4 3P Duty: 3.811 KA AT -32.18 DEG ( 1.37 MVA) X/R: 0.63
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0267 + J 0.0168 OHMS

```

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER 3.811 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 3.811 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 3.811 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 3.811 KA
CBL-0080 217 SDPL21 3.811 KA ANG: -32.18

222 L21U5 3P Duty: 6.931 KA AT -41.95 DEG ( 2.50 MVA) X/R: 0.90
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0129 + J 0.0116 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.931 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.931 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.931 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.931 KA
CBL-0081 217 SDPL21 6.931 KA ANG: -41.95

223 L21M1 3P Duty: 4.445 KA AT -43.49 DEG ( 1.60 MVA) X/R: 0.95
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0196 + J 0.0186 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 4.445 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 4.445 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 4.445 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 4.445 KA
CBL-0082 217 SDPL21 4.445 KA ANG: -43.49

224 L21M11 3P Duty: 3.905 KA AT -39.23 DEG ( 1.41 MVA) X/R: 0.82
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0238 + J 0.0194 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 3.905 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 3.905 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 3.905 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 3.905 KA
CBL-0083 223 L21M1 3.905 KA ANG: -39.23

225 L21M2 3P Duty: 6.532 KA AT -40.66 DEG ( 2.35 MVA) X/R: 0.86
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0139 + J 0.0120 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.532 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.532 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.532 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.532 KA
CBL-0084 217 SDPL21 6.532 KA ANG: -40.66

226 L21M3 3P Duty: 5.113 KA AT -45.06 DEG ( 1.84 MVA) X/R: 1.00
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0166 + J 0.0166 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.113 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.113 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.113 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.113 KA
  
```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
CONTRIBUTIONS TO 226 L21M3 (CONTINUED)
CBL-0085 217 SDPL21 5.113 KA ANG: -45.06

227 L21M4 3P Duty: 8.450 KA AT -46.92 DEG ( 3.04 MVA) X/R: 1.07
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0097 + J 0.0104 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 8.450 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 8.450 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 8.450 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 8.450 KA
CBL-0086 217 SDPL21 8.450 KA ANG: -46.92

228 L21B1 3P Duty: 10.685 KA AT -48.50 DEG ( 3.85 MVA) X/R: 1.13
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0074 + J 0.0084 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 10.685 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 10.685 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 10.685 KA
CBL-0087 217 SDPL21 10.685 KA ANG: -48.50

229 SDPH22 3P Duty: 15.945 KA AT -65.05 DEG ( 13.26 MVA) X/R: 2.15
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0073 + J 0.0158 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 15.945 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 15.945 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 15.945 KA
CBL-0055 201 MDPH2 15.945 KA ANG: -65.05

230 H22B1 3P Duty: 12.178 KA AT -46.96 DEG ( 10.12 MVA) X/R: 1.07
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0155 + J 0.0166 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 12.178 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 12.178 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 12.178 KA
CBL-0107 229 SDPH22 12.178 KA ANG: -46.96

231 H22M1 3P Duty: 4.595 KA AT -20.38 DEG ( 3.82 MVA) X/R: 0.37
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0565 + J 0.0210 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 4.595 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 4.595 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 4.595 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 4.595 KA
CBL-0105 229 SDPH22 4.595 KA ANG: -20.38

232 H22U1 3P Duty: 8.900 KA AT -41.58 DEG ( 7.40 MVA) X/R: 0.89
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0233 + J 0.0207 OHMS

```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER      8.900 KA
MOLDED CASE CIRCUIT BREAKER < 10KA    8.900 KA
MOLDED CASE CIRCUIT BREAKER < 20KA    8.900 KA
MOLDED CASE CIRCUIT BREAKER > 20KA    8.900 KA
CBL-0106                               229 SDPH22                8.900 KA    ANG:   -41.58

233 SDPL22          3P Duty: 13.565 KA AT  -69.36 DEG (   4.89 MVA) X/R:    2.66
VOLTAGE:   208.   EQUIV. IMPEDANCE=  0.0031 + J  0.0083  OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER      13.565 KA
MOLDED CASE CIRCUIT BREAKER < 20KA    13.565 KA
MOLDED CASE CIRCUIT BREAKER > 20KA    13.565 KA
CBL-0092                               BUS-0060                13.565 KA    ANG:   -69.36

234 L22U1          3P Duty:  6.166 KA AT  -40.64 DEG (   2.22 MVA) X/R:    0.86
VOLTAGE:   208.   EQUIV. IMPEDANCE=  0.0148 + J  0.0127  OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER      6.166 KA
MOLDED CASE CIRCUIT BREAKER < 10KA    6.166 KA
MOLDED CASE CIRCUIT BREAKER < 20KA    6.166 KA
MOLDED CASE CIRCUIT BREAKER > 20KA    6.166 KA
CBL-0093                               233 SDPL22                6.166 KA    ANG:   139.36

235 L22U2          3P Duty:  5.554 KA AT  -38.59 DEG (   2.00 MVA) X/R:    0.80
VOLTAGE:   208.   EQUIV. IMPEDANCE=  0.0169 + J  0.0135  OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER      5.554 KA
MOLDED CASE CIRCUIT BREAKER < 10KA    5.554 KA
MOLDED CASE CIRCUIT BREAKER < 20KA    5.554 KA
MOLDED CASE CIRCUIT BREAKER > 20KA    5.554 KA
CBL-0094                               233 SDPL22                5.554 KA    ANG:   -38.59

236 L22U3          3P Duty:  4.437 KA AT  -34.90 DEG (   1.60 MVA) X/R:    0.70
VOLTAGE:   208.   EQUIV. IMPEDANCE=  0.0222 + J  0.0155  OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER      4.437 KA
MOLDED CASE CIRCUIT BREAKER < 10KA    4.437 KA
MOLDED CASE CIRCUIT BREAKER < 20KA    4.437 KA
MOLDED CASE CIRCUIT BREAKER > 20KA    4.437 KA
CBL-0095                               233 SDPL22                4.437 KA    ANG:   -34.90

237 L22U4          3P Duty:  5.845 KA AT  -39.56 DEG (   2.11 MVA) X/R:    0.83
VOLTAGE:   208.   EQUIV. IMPEDANCE=  0.0158 + J  0.0131  OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER      5.845 KA
MOLDED CASE CIRCUIT BREAKER < 10KA    5.845 KA
MOLDED CASE CIRCUIT BREAKER < 20KA    5.845 KA
MOLDED CASE CIRCUIT BREAKER > 20KA    5.845 KA
CBL-0096                               233 SDPL22                5.845 KA    ANG:   -39.56

```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
238 L22U5          3P Duty: 5.290 KA AT -37.71 DEG ( 1.91 MVA) X/R: 0.77
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0180 + J 0.0139 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.290 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.290 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.290 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.290 KA
CBL-0097          233 SDPL22          5.290 KA    ANG: -37.71

239 L22M1          3P Duty: 6.166 KA AT -40.64 DEG ( 2.22 MVA) X/R: 0.86
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0148 + J 0.0127 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.166 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.166 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.166 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.166 KA
CBL-0098          233 SDPL22          6.166 KA    ANG: -40.64

240 L22M2          3P Duty: 5.290 KA AT -37.71 DEG ( 1.91 MVA) X/R: 0.77
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0180 + J 0.0139 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.290 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.290 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.290 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.290 KA
CBL-0099          233 SDPL22          5.290 KA    ANG: -37.71

241 L22M3          3P Duty: 5.290 KA AT -37.71 DEG ( 1.91 MVA) X/R: 0.77
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0180 + J 0.0139 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.290 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.290 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.290 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.290 KA
CBL-0100          233 SDPL22          5.290 KA    ANG: -37.71

242 L22M4          3P Duty: 5.049 KA AT -36.91 DEG ( 1.82 MVA) X/R: 0.75
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0190 + J 0.0143 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 5.049 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.049 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.049 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.049 KA
CBL-0101          233 SDPL22          5.049 KA    ANG: -36.91

243 L22M5          3P Duty: 5.787 KA AT -47.74 DEG ( 2.08 MVA) X/R: 1.10
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0140 + J 0.0154 OHMS

```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER 5.787 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 5.787 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 5.787 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 5.787 KA
CBL-0102 233 SDPL22 5.787 KA ANG: -47.74

244 L22M6 3P Duty: 4.624 KA AT -35.51 DEG ( 1.67 MVA) X/R: 0.71
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0211 + J 0.0151 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 4.624 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 4.624 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 4.624 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 4.624 KA
CBL-0103 233 SDPL22 4.624 KA ANG: -35.51

245 L22B1 3P Duty: 6.612 KA AT -31.89 DEG ( 2.38 MVA) X/R: 0.62
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0154 + J 0.0096 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 6.612 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 6.612 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 6.612 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 6.612 KA
CBL-0104 233 SDPL22 6.612 KA ANG: -31.89

300 GEN SEC 3P Duty: 1.998 KA AT -85.39 DEG ( 1.66 MVA) X/R: 12.40
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0111 + J 0.1382 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 2.190 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 3.052 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 2.586 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 2.325 KA
CONTRIBUTIONS: GEN-1 1.998 KA ANG: -85.39

301 ATS_E1B1 3P Duty: 12.790 KA AT -32.90 DEG ( 10.63 MVA) X/R: 0.65
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0182 + J 0.0118 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 12.790 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 12.790 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 12.790 KA
ATS BUS-0039 12.790 KA ANG: -32.90

302 ATS_E2B1 3P Duty: 22.152 KA AT -57.88 DEG ( 18.42 MVA) X/R: 1.60
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0067 + J 0.0106 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 22.152 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 22.152 KA
ATS 200A BUS-0129 22.152 KA ANG: 122.12

303 E1B1 3P Duty: 10.773 KA AT -29.39 DEG ( 8.96 MVA) X/R: 0.56

```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0224 + J 0.0126 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 10.773 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 10.773 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 10.773 KA
CBL-0037 301 ATS_E1B1 10.773 KA ANG: -29.39

304 E1L1 3P Duty: 3.143 KA AT -11.36 DEG ( 2.61 MVA) X/R: 0.20
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0865 + J 0.0174 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 3.143 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 3.143 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 3.143 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 3.143 KA
CBL-0029 303 E1B1 3.143 KA ANG: -11.36

305 E1L2 3P Duty: 2.885 KA AT -16.48 DEG ( 2.40 MVA) X/R: 0.30
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0921 + J 0.0272 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 2.885 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 2.885 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 2.885 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 2.885 KA
CBL-0030 303 E1B1 2.885 KA ANG: -16.48

306 E1BL1 3P Duty: 1.787 KA AT -38.06 DEG ( 0.64 MVA) X/R: 0.78
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0529 + J 0.0414 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.787 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.787 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.787 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.787 KA
CBL-0034 BUS-0014 1.787 KA ANG: -38.06

307 E1BL2 3P Duty: 1.618 KA AT -35.16 DEG ( 0.58 MVA) X/R: 0.70
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0607 + J 0.0427 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.618 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.618 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.618 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.618 KA
CBL-0038 306 E1BL1 1.618 KA ANG: -35.16

308 E2B1 3P Duty: 19.271 KA AT -52.42 DEG ( 16.02 MVA) X/R: 1.30
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0088 + J 0.0114 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 19.271 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 19.271 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 19.271 KA
CBL-0057 302 ATS_E2B1 19.271 KA ANG: -52.42

```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

CONTRIBUTIONS TO 308 E2B1

(CONTINUED)

```

309 E2BL1      3P Duty: 2.981 KA AT -47.72 DEG ( 1.07 MVA) X/R: 1.10
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0271 + J 0.0298 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 2.981 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 2.981 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 2.981 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 2.981 KA
CBL-0060      BUS-0072      2.981 KA      ANG: 132.28

310 E2BL2      3P Duty: 1.491 KA AT -36.12 DEG ( 0.54 MVA) X/R: 0.73
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0651 + J 0.0475 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.491 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.491 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.491 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.491 KA
CBL-0061      309 E2BL1      1.491 KA      ANG: -36.12

311 E2BL3      3P Duty: 1.005 KA AT -29.79 DEG ( 0.36 MVA) X/R: 0.57
VOLTAGE: 208. EQUIV. IMPEDANCE= 0.1037 + J 0.0593 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.005 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.005 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.005 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.005 KA
CBL-0062      310 E2BL2      1.005 KA      ANG: -29.79

312 E2M1      3P Duty: 3.716 KA AT -12.50 DEG ( 3.09 MVA) X/R: 0.22
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0728 + J 0.0161 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 3.716 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 3.716 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 3.716 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 3.716 KA
CBL-0058      308 E2B1      3.716 KA      ANG: -12.50

313 E2B2      3P Duty: 2.924 KA AT -19.36 DEG ( 2.43 MVA) X/R: 0.35
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0894 + J 0.0314 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 2.924 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 2.924 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 2.924 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 2.924 KA
CBL-0063      308 E2B1      2.924 KA      ANG: -19.36

314 E2M3      3P Duty: 1.911 KA AT -14.06 DEG ( 1.59 MVA) X/R: 0.25
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.1406 + J 0.0352 OHMS

```

T H R E E P H A S E F A U L T R E P O R T

(FOR APPLICATION OF LOW VOLTAGE BREAKERS)

PRE FAULT VOLTAGE: 1.0000

MODEL TRANSFORMER TAPS: NO

```

=====
LOW VOLTAGE POWER CIRCUIT BREAKER 1.911 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.911 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.911 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.911 KA
CBL-0064 313 E2B2 1.911 KA ANG: -14.06

315 E2U1 3P Duty: 1.758 KA AT -13.26 DEG ( 1.46 MVA) X/R: 0.24
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.1535 + J 0.0362 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.758 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.758 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.758 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.758 KA
CBL-0065 313 E2B2 1.758 KA ANG: -13.26

316 E2B3 3P Duty: 1.786 KA AT -16.42 DEG ( 1.48 MVA) X/R: 0.29
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.1489 + J 0.0439 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.786 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.786 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.786 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.786 KA
CBL-0066 313 E2B2 1.786 KA ANG: -16.42

317 E2M2 3P Duty: 1.137 KA AT -11.96 DEG ( 0.94 MVA) X/R: 0.21
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.2385 + J 0.0505 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.137 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.137 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.137 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.137 KA
CBL-0067 316 E2B3 1.137 KA ANG: -11.96

318 E2U2 3P Duty: 1.080 KA AT -11.58 DEG ( 0.90 MVA) X/R: 0.20
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.2513 + J 0.0515 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 1.080 KA
MOLDED CASE CIRCUIT BREAKER < 10KA 1.080 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 1.080 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 1.080 KA
CBL-0068 316 E2B3 1.080 KA ANG: -11.58

ACC-1 3P Duty: 13.109 KA AT -53.91 DEG ( 10.90 MVA) X/R: 2.05
VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0125 + J 0.0171 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER 13.109 KA
MOLDED CASE CIRCUIT BREAKER < 20KA 13.109 KA
MOLDED CASE CIRCUIT BREAKER > 20KA 13.109 KA

```

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====					
	CONTRIBUTIONS TO ACC-1	(CONTINUED)			
	CONTRIBUTIONS: MTRI-0005		1.650 KA	ANG:	-84.29
	CBL-0048	201 MDPH2	11.715 KA	ANG:	-49.83
ACC-2	3P Duty: 20.489 KA AT -62.75 DEG (17.03 MVA)	X/R:	2.38		
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0062 + J 0.0120 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER 20.489 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA 20.489 KA				
	CONTRIBUTIONS: MTRI-0003		1.650 KA	ANG:	-84.29
	CBL-0003	101 MDPH1	18.964 KA	ANG:	-60.91
ACC-3	3P Duty: 15.894 KA AT -53.08 DEG (13.21 MVA)	X/R:	1.49		
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0105 + J 0.0139 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER 15.894 KA				
	MOLDED CASE CIRCUIT BREAKER < 20KA 15.894 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA 15.894 KA				
	CONTRIBUTIONS: MTRI-0004		0.450 KA	ANG:	-84.29
	CBL-0004	101 MDPH1	15.511 KA	ANG:	-52.22
BUS-0002	3P Duty: 34.594 KA AT -83.06 DEG (28.76 MVA)	X/R:	8.23		
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0010 + J 0.0080 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER 35.910 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA 38.127 KA				
	XF2-0001	UTILITY PRI	30.778 KA	ANG:	-263.04
	CBL-0001	100 UTC_MDPH1	3.816 KA	ANG:	96.84
UTILITY PRI	3P Duty: 80.124 KA AT -82.88 DEG (1831.87 MVA)	X/R:	8.00		
	VOLTAGE: 13200. EQUIV. IMPEDANCE= 0.0118 + J 0.0944 OHMS				
	CONTRIBUTIONS: UTIL-0001		80.000 KA	ANG:	-82.87
	XF2-0001	BUS-0002	0.124 KA	ANG:	96.86
UTILITY PRI 2	3P Duty: 80.109 KA AT -82.87 DEG (1831.54 MVA)	X/R:	8.00		
	VOLTAGE: 13200. EQUIV. IMPEDANCE= 0.0118 + J 0.0944 OHMS				
	CONTRIBUTIONS: UTIL-0003		80.000 KA	ANG:	-82.87
	XF2-0004	BUS-0003	0.109 KA	ANG:	-82.22

F A U L T S T U D Y S U M M A R Y
(FOR APPLICATION OF LOW VOLTAGE BREAKERS)
PRE FAULT VOLTAGE: 1.0000
MODEL TRANSFORMER TAPS: NO

BUS RECORD NO NAME	VOLTAGE L-L	A V A I L A B L E 3 PHASE	F A U L T D U T I E S (KA) X/R LINE/GRND X/R
=====			
100 UTC_MDPH1	480.	34.442	8.11
101 MDPH1	480.	32.770	6.46
102 H1L1	480.	27.263	2.76
103 H1L2	480.	16.148	1.04
104 H1L3	480.	15.160	1.34
105 H1L4	480.	16.748	1.58
106 MD/G	208.	6.096	2.34
107 G/GA	208.	5.742	2.11
108 SDPL1	208.	23.911	4.90
109 L1M1	208.	2.688	0.67
110 L1L1	208.	17.385	2.57
111 L1L2	208.	14.738	2.15
112 L1L3	208.	10.956	1.16
113 L1L31	208.	9.241	0.98
114 L1L4	208.	5.335	0.91
115 L1L5	208.	5.422	1.11
116 L1L6	208.	7.102	0.63
117 L1B1	208.	13.179	1.04
118 L1B2	208.	2.534	0.35
119 H1B1	480.	15.630	0.78
200 UTC2_MDPH2	480.	32.642	7.16
201 MDPH2	480.	31.848	6.44
202 SDPL2	208.	16.266	3.33
203 L2M1	208.	12.232	2.24
204 L2M11	208.	10.145	1.91
205 L2M2	208.	10.481	1.47
206 L2M21	208.	6.695	0.71
207 L2B2	208.	8.773	1.35
208 L2B1	208.	10.105	0.99
209 H2M1	480.	19.068	1.70
210 H2M2	480.	20.652	1.72
211 H2B2	480.	29.137	3.80
212 H2B1	480.	13.489	0.58
213 SDPH21	480.	17.799	1.72
214 H21B1	480.	11.096	0.73
215 H21M1	480.	9.258	0.68
216 H21U1	480.	7.290	0.56
217 SDPL21	208.	13.877	2.39
218 L21U1	208.	6.532	0.86
219 L21U2	208.	3.446	0.60
220 L21U3	208.	5.557	0.77
221 L21U4	208.	3.811	0.63
222 L21U5	208.	6.931	0.90
223 L21M1	208.	4.445	0.95

F A U L T S T U D Y S U M M A R Y
(FOR APPLICATION OF LOW VOLTAGE BREAKERS)
PRE FAULT VOLTAGE: 1.0000
MODEL TRANSFORMER TAPS: NO

BUS RECORD		V O L T A G E		A V A I L A B L E		F A U L T D U T I E S (KA)	
NO NAME		L-L	3 PHASE	X/R	LINE/GRND	X/R	
=====							
224	L21M11	208.	3.905	0.82			
225	L21M2	208.	6.532	0.86			
226	L21M3	208.	5.113	1.00			
227	L21M4	208.	8.450	1.07			
228	L21B1	208.	10.685	1.13			
229	SDPH22	480.	15.945	2.15			
230	H22B1	480.	12.178	1.07			
231	H22M1	480.	4.595	0.37			
232	H22U1	480.	8.900	0.89			
233	SDPL22	208.	13.565	2.66			
234	L22U1	208.	6.166	0.86			
235	L22U2	208.	5.554	0.80			
236	L22U3	208.	4.437	0.70			
237	L22U4	208.	5.845	0.83			
238	L22U5	208.	5.290	0.77			
239	L22M1	208.	6.166	0.86			
240	L22M2	208.	5.290	0.77			
241	L22M3	208.	5.290	0.77			
242	L22M4	208.	5.049	0.75			
243	L22M5	208.	5.787	1.10			
244	L22M6	208.	4.624	0.71			
245	L22B1	208.	6.612	0.62			
300	GEN_SEC	480.	1.998	12.40			
301	ATS_E1B1	480.	12.790	0.65			
302	ATS_E2B1	480.	22.152	1.60			
303	E1B1	480.	10.773	0.56			
304	E1L1	480.	3.143	0.20			
305	E1L2	480.	2.885	0.30			
306	E1BL1	208.	1.787	0.78			
307	E1BL2	208.	1.618	0.70			
308	E2B1	480.	19.271	1.30			
309	E2BL1	208.	2.981	1.10			
310	E2BL2	208.	1.491	0.73			
311	E2BL3	208.	1.005	0.57			
312	E2M1	480.	3.716	0.22			
313	E2B2	480.	2.924	0.35			
314	E2M3	480.	1.911	0.25			
315	E2U1	480.	1.758	0.24			
316	E2B3	480.	1.786	0.29			
317	E2M2	480.	1.137	0.21			
318	E2U2	480.	1.080	0.20			

FAULT STUDY SUMMARY
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

BUS RECORD NO NAME	VOLTAGE		A V A I L A B L E		F A U L T D U T I E S (KA)	
	L-L	3 PHASE	X/R	LINE/GRND	X/R	
=====						
ACC-1	480.	13.109	2.05			
ACC-2	480.	20.489	2.38			
ACC-3	480.	15.894	1.49			
BUS-0002	480.	34.594	8.23			
UTILITY PRI	13200.	80.124	8.00			
UTILITY PRI 2	13200.	80.109	8.00			

110 FAULTED BUSES, 115 BRANCHES, 8 CONTRIBUTIONS

*** SHORT CIRCUIT STUDY COMPLETE ***

APPENDIX D: REFERENCES

I. SUPPLIED DATA


- 1 System Drawings

II. ELECTRICAL CONTRACTOR INFORMATION

- 1 Conductor Run Data
- 2 Other Electrical System Data

III. POWER SYSTEM ENGINEERING

- 1 Trip Dials for Micrologic 6.0, 6.0A, 6.0P, 6.0H
- 2 Trip Dials for H-, J-Frame Micrologic 3.2 & 3.2S
- 3 Trip Dials for L-Frame Micrologic 3.3 & 3.3S
- 4 Trip Dials for Electronic Trip ET1.0 & ET1.0I
- 5 Trip Dials for Molded Case Breakers
- 6 Trip Dials for Ground Fault Relays
- 7 Std AF Study Options - SKM
- 8 Approach Boundaries Table - 70E
- 9 PPE Table - 70E
- 10 Project Recommendation & Action Table



RBB
Architects, Inc.
315 East Mountain Ave.
Suite 100
Fort Collins, CO 80524-2913
T: 970.484.0217
F: 970.484.0284
© 2013 www.rbbarchitects.com

Engineering
1637 CY Ave., Suite #303
Casper, Wyoming 82404
Ph: (307) 266-5033

PROJECT PHASE
95% (GMP) SUBMITTAL
NOT FOR CONSTRUCTION

PROJECT INFORMATION
KELLY WALSH HIGH SCHOOL
NATRONA COUNTY SCHOOL DISTRICT No. 1
3500 EAST 12TH STREET
CASPER, WY 82409

PROJECT # 11-02/12110
ISSUE DATE: MAR 17, 2014

REVISIONS

NO.	DESCRIPTION	DATE
-----	-------------	------

ELECTRICAL DETAILS, ONE-LINES & DIAGRAMS
6.E502

LV ELECTRONIC DEVICES (use with SWGR, SWBDs, MCCs, Panels, Bus Plugs)

NAME (Building or Equip)				MD/G				VOLTAGE				208		REV.#	
LOCATION (Building or Equip)								SWGR CONT CURRENT RATING:						PG. __ OF __	
FED FROM				H1L4				SWGR BUS BRACING:							
DRAWING REF								Section #							
COLLECTED BY								DATE COMPLETED							
BKR I.D. PHOTO #				CIRCUIT BREAKER INFO.			RANGE / SETTING								
				MFG. BREAKER TRIP UNIT	FRAME (AF) SENSOR (AS) (In) PLUG (AP)	INTR. RATING RMS SYM	LTPU (Ir) RANGE SETTING	LTD (tr) RANGE SETTING	STPU (Isd) RANGE SETTING	STD (tsd) RANGE SETTING	INST. (It) RANGE SETTING	GFPU (Ig) RANGE SETTING	GFD (tg) RANGE SETTING		
CELL 2 FEEDS PNL. A				WEST	800	30 kA	.5 - 1.0	2 - 24	2 - S2	.1 - .5	2 - M2	A - K	.1 - 5		
				DSII-308	800		1	20	6	0.2	M2	B	0.2		
				DIGITRIP	800 or ARP#					OUT*			OUT*		
MAIN				MLO											
				(2) 500KCMIL											
G/GA FEEDER				200A	TFJ236200										
				350 KCMIL											
				GGA											
LARGEST FEEDER DIMMER SYSTEM				400A	TJK436F000										
				750KCMIL											
FEEDER TO 1/GB				100A	TED134100										
				#1 AWG											
Area in gray is an example.				* I2T - ON OR OFF, IN OR OUT					NOTES:					PHOTO#	
1. If the breaker uses current-limiting fuse, record fuse data.															
2. If the breaker uses separate ground fault module, record GFP data.															
USE 'A' for Not Applicable ; USE 'B' for Not Accessible															

PANELBOARD/SWITCHBOARD with T-M BKRS

NAME (Equip)						VOLTAGE							REV.#		
LOCATION (Building or Equip)						PANEL/SWBD CONT CURRENT: SWBD (ONLY) BUS BRACING:							PG. __ OF __		
DRAWING REF						Section #									
COLLECTED BY						DATE COMPLETED									
FED FROM															
MAIN BREAKER DATA						FEEDER BREAKER DATA (Note 4)							CABLE (LOAD SIDE)		
MFG. TYPE	CAT# (see Notes)	CONT. CURRENT	INTR (SYM)	RANGE INST.	SETTINGS INST.	I.D.	MFG. TYPE	CAT# (see Notes)	CONT. CURRENT	INTR (SYM)	RANGE INST.	SETTINGS INST.	SIZE	# / PH	LENGTH (FT)
SQD	MA	800	30KA	L0, 2 ,3,	H1	CKT 1	SQD	MA	800	30KA	L0, 2 ,3,	H1	3/0	1	150
OR MLO				4, HI											

Area in gray is an example.

1. If the breaker uses a separate ground fault module, record GFP data.

2. If the breaker uses current-limiting fuse, record the fuse cat. # and amp. rating.

3. If breakers use electronic trip devices, record data on LVCB-E trip sheet

4. Record data for largest and smallest (lowest SC rating) bkr; and bkr feeding subpanels

USE 'A' for Not Applicable; USE 'B' for Not Accessible

For location use building, floor, room ex. Bldg 1, 2nd Floor, RM 208B.

NOTES:

PHOTO #

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
MDPH2	ATS_E2B1	50	1	3/0AWG / PH & Neutral	AL	THHN	EMT
ATS_E2B1	E2B1	20	1	3/0AWG / PH & Neutral	AL	THHN	EMT
E2B1	TE2	100	1	1AWG / PH & Neutral	AL	THHN	EMT
TE2	E2BL1	20	1	250MCM / PH & Neutral	AL	THHN	EMT
E2BL1	E2BL2	450	1	4/0AWG / PH & Neutral	AL	THHN	EMT
E2BL2	E2BL3	290	1	2/0AWG / PH & Neutral	AL	THHN	EMT
E2B1	E2M1	100	1	8AWG / PH & Neutral	Cu	THHN	EMT
E2B1	E2B2	480	1	1/0AWG / PH & Neutral	AL	THHN	EMT
E2B2	314 E2M3	80	1	8AWG / PH & Neutral	Cu	THHN	EMT
E2B2	E2U1	100	1	8AWG / PH & Neutral	Cu	THHN	EMT
E2B2	E2B3	290	1	3AWG / PH & Neutral	Cu	THHN	EMT
E2B3	E2M2	140	1	8AWG / PH & Neutral	Cu	THHN	EMT
E2B3	E2U2	160	1	8AWG / PH & Neutral	Cu	THHN	EMT
Area in gray is an example. * Panelboard, switchboard, and transformer designations, etc.. **Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked. USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u>				Notes			Photo #:

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
XFMR_SDPL22	SDPL22	20	4	500MCM / PH & Neutral	AL	THHN	EMT
SDPL22	L22U1	110	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22U2	130	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22U3	180	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22U4	120	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22U5	140	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22M1	110	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22M2	140	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22M3	140	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22M4	150	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22M5	180	1	300MCM / PH & Neutral	AL	THHN	EMT
SDPL22	L22M6	170		3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL22	L22B1	30	1	6AWG / PH & Neutral	Cu	THHN	EMT
Area in gray is an example.				Notes			Photo #:
<p>* Panelboard, switchboard, and transformer designations, etc..</p> <p>**Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked.</p> <p>USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u></p>							

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
SDPL21	L21U3	130	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL21	L21U4	220	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL21	L21U5	90	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL21	L21M1	270	1	300MCM / PH & Neutral	AL	THHN	EMT
L21M1	L21M11	20	1	1AWG / PH & Neutral	AL	THHN	EMT
SDPL21	L21M2	100	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL21	L21M3	220	1	300MCM / PH & Neutral	AL	THHN	EMT
SDPL21	L21M4	60	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL21	L21B1	10	1	6AWG / PH & Neutral	Cu	THHN	EMT
MDPH2	SDPH22	750	4	600MC / PH & Neutral	AL	THHN	EMT
SDPH22	H22B1	20	1	6AWG / PH & Neutral	Cu	THHN	EMT
SDPH22	H22M1	120	1	6AWG / PH & Neutral	Cu	THHN	EMT
SDPH22	H22U1	120	1	2/0AWG / PH & Neutral	AL	THHN	EMT
SDPH22	XFMR_SDPL22	20	2	500MCM / PH	AL	THHN	EMT
Area in gray is an example.				Notes			Photo #:
<p>* Panelboard, switchboard, and transformer designations, etc..</p> <p>**Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked.</p> <p>USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u></p>							

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
SDPL2	L2B1	30	1	1 AWG / PH & Neutral	AL	THHN	EMT
MDPH2	ACC-1	460	2	300MCM / PH	AL	THHN	EMT
MDPH2	H2M1	100	1	300MCM / PH & Neutral	AL	THHN	EMT
MDPH2	H2M2	150	2	250MCM / PH & Neutral	AL	THHN	EMT
MDPH2	H2B2	30	2	250MCM / PH & Neutral	AL	THHN	EMT
MDPH2	H2B1	40	1	6AWG / PH & Neutral	Cu	THHN	EMT
MDPH2	SDPH21	500	4	350MCM / PH & Neutral	AL	THHN	EMT
SDPH21	H21B1	30	1	6AWG / PH & Neutral	Cu	THHN	EMT
SDPH21	H21M1	80	1	1AWG / PH & Neutral	AL	THHN	EMT
SDPH21	H21U1	120	1	1AWG / PH & Neutral	AL	THHN	EMT
SDPH21	XFMR_SDPL21	30	2	500MCM / PH	AL	THHN	EMT
XFMR_SDPL21	SDPL21	30	4	500MCM / PH & Neutral	AL	THHN	EMT
SDPL21	L21U1	100	1	3/0AWG / PH & Neutral	AL	THHN	EMT
30	L21U2	250	1	3/0AWG / PH & Neutral	AL	THHN	EMT
Area in gray is an example.				Notes			Photo #:
<p>* Panelboard, switchboard, and transformer designations, etc..</p> <p>**Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked.</p> <p>USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u></p>							

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
E1B1	TE1	30	1	6AWG / PH	Cu	THHN	EMT
TE1	E1BL1	20	1	1AWG / PH & Neutral	AL	THHN	EMT
E1BL1	E1BL2	30	1	4AWG / PH & Neutral	Cu	THHN	EMT
GEN SEC	ATS_E1B1	150	1	1AWG / PH & Neutral	AL	THHN	EMT
GEN SEC	MDPH2	200	1	3/0AWG / PH & Neutral	AL	THHN	EMT
UTILITY SEC	UTC_MDPH2	100	9				
UTC_MDPH2	MDPH2	100	16	700MCM / PH & Neutral	AL	THHN	PVC
MDPH2	XFMR_SDPL2	30	2	500MCM / PH & Neutral	AL	THHN	EMT
XFMR_SDPL2	SDPL2	30	4	500MCM / PH & Neutral	AL	THHN	EMT
SDPL2	L2M1	200	4	500MCM / PH & Neutral	AL	THHN	EMT
L2M1	L2M11	40	1	500MCM / PH & Neutral	AL	THHN	EMT
SDPL2	L2M2	120	2	250MCM / PH & Neutral	AL	THHN	EMT
L2M2	L2M21	20	1	6AWG / PH & Neutral	Cu	THHN	EMT
SDPL2	L2B2	100	1	300MCM / PH & Neutral	AL	THHN	EMT
Area in gray is an example.				Notes			Photo #:
<p>* Panelboard, switchboard, and transformer designations, etc..</p> <p>**Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked.</p> <p>USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u></p>							

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
SDPL1	L1L1	80	2	500MCM / PH & Neutral	AL	THHN	EMT
SDPL1	L1L2	130	2	500MCM / PH & Neutral	AL	THHN	EMT
SDPL1	L1L3	170	2	250MCM / PH & Neutral	AL	THHN	EMT
L1L3	L1L31	20	1	3/0AWG / PH & Neutral	AL	THHN	EMT
SDPL1	L1L4	260	1	300MCM / PH & Neutral	AL	THHN	EMT
SDPL1	L1L5	300	1	400MCM/PH & Neutral	AL	THHN	EMT
SDPL1	L1L6	100	1	2/0AWG / PH & Neutral	AL	THHN	EMT
SDPL1	L1B1	40	1	2/0AWG / PH & Neutral	AL	THHN	EMT
SDPL1	L1B2	260	1	1/0AWG / PH & Neutral	AL	THHN	EMT
MDPH1	H1B1	60	1	1AWG / PH & Neutral	AL	THHN	EMT
MDPH1	ATS_E1B1	80	1	1AWG / PH & Neutral	AL	THHN	EMT
ATS_E1B1	E1B1	20	1	1AWG / PH & Neutral	AL	THHN	EMT
E1B1	E1L1	100	1	8AWG / PH & Neutral	Cu	THHN	EMT
E1B1	E1L2	340	1	3AWG / PH & Neutral	Cu	THHN	EMT
Area in gray is an example.				Notes			Photo #:
<p>* Panelboard, switchboard, and transformer designations, etc..</p> <p>**Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked.</p> <p>USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u></p>							

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

CABLE

NAME (Building or Equip)				DRAWING REF			PG. ____ OF ____
LOCATION (See note below)				COLLECTED BY			REV # _____
				DATE COMPLETED			
FROM EQUIP.*	TO EQUIP.*	CONDUCTOR LENGTH IN FEET	NUMBER OF CABLES PER PHASE	CABLE SIZE / PHASE AND NEUTRAL (e.g. AWG, KCMIL)	CONDUCTOR MATERIAL** (if other than CU)	INSULATION TYPE** (if other than THHN)	CONDUIT TYPE** (if other than STEEL)
PANEL H5A	PANEL H5B	125	2	500MCM / PH & Neutral	AL	THW	PVC
UTILITY SEC	UTC	100	9				
UTC	MDPH1	100	16	700MCM / PH & Neutral	AL	THHN	PVC
MDPH1	ACC-3	180	1	4/0 AWG / PH	AL	THHN	PVC
MDPH1	ACC-2	250	2	300MCM / PH	AL	THHN	PVC
MDPH1	H1L1	60	2	250MCM / PH & Neutral	AL	THHN	EMT
MDPH1	H1L2	100	1	3/0AWG / PH & Neutral	AL	THHN	EMT
MDPH1	H1L3	160	1	300MCM/PH & Neutral	AL	THHN	EMT
MDPH1	H1L4	290	2	350MCM/PH & Neutral	AL	THHN	EMT
H1L4	XFMR_MD/G	20	1	4/0AWG / PH	Cu	THHN	EMT
XFMR_MD/G	MD/G	20	2	350MCM / PH & Neutral	Cu	THHN	EMT
MD/G	G/GA	20	1	300MCM / PH & Neutral	AL	THHN	EMT
MDPH1	XFMR_SDPL1	40	4	350MCM / PH	AL	THHN	EMT
XFMR_SDPL1	SDPL1	40	6	600MCM/PH & Neutral	AL	THHN	EMT
SDPL1	L1M1	500	1	250MCM/PH & Neutral	AL	THHN	EMT
Area in gray is an example.				Notes			Photo #:
<p>* Panelboard, switchboard, and transformer designations, etc..</p> <p>**Conductor material, insulation type and conduit type are assumed to be CU, THHN, and Steel unless otherwise marked.</p> <p>USE 'A' for <u>Not Applicable</u>; USE 'B' for <u>Not Accessible</u></p>							

For LOCATION use building, floor, room (ie. Bldg 1, 2nd Floor, RM 208B.)

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

LIGHTING TRANSFORMERS – LOW-VOLTAGE DRY-TYPE

NAME (Building or Equip)						REV.#			
DRAWING REF						PG. __ OF __			
COLLECTED BY						DATE COMPLETED			
I.D.	FROM EQUIP.	TO EQUIP.	LOCATION	MFG. TYPE	CATALOG # OR Series #	KVA	% Z	PRIMARY VOLTAGE & CONN	SECONDARY VOLTAGE & CONN
							TAP (RANGE)		
T-1A	PANEL HA	PANEL LA	Bldg 43	SQD	EE112T3H	112.5	5.6	480 V	208Y/120 V
			Rm 312	DRY TYPE				DELTA	WYE-GND
XFMR_MD/G	H1L4	MD/G	LOWER - E Rm E119			225		480 V DELTA	208Y/120 V WYE-GND
XFMR_TE1	PANEL E1B1	PANEL E1BL1	BASEMENT - D	SQD DRY TYPE	EE45T3H42DB	45	2 - 2.5%, 4 - 2.5%	480V DELTA	208Y/120 V WYE-GND
XFMR_T1	MDPH1	SDPL1	BASEMENT - D	SQD DRY TYPE	EE750T68H61DB	750	2 - 2.5%	480V DELTA	208Y/120 V WYE-GND
XFMR_TE2	PANEL E2B1	PANEL E2BL1	LOWER - F	SQD DRY TYPE	EE75T3H47DB	75	2 - 2.5%, 4 - 2.5%	480V DELTA	208Y/120 V WYE-GND
XFMR_T2	MDPH2	SDPL2	LOWER - F	SQD DRY TYPE	EE500T68H57DB	500	2 - 2.5%	480V DELTA	208Y/120 V WYE-GND
XFMR_T21	SDPH21	SDPL21	CRAWLSPACE - G	SQD DRY TYPE	EE500T68H57DB	500	2 - 2.5%	480V DELTA	208Y/120 V WYE-GND
XFMR_T22	SDPH22	SDPL22	CRAWLSPACE - H	SQD DRY TYPE	EE500T68H57DB	500	2 -2.5%	480V DELTA	208Y/120 V WYE-GND
USE 'A' for <u>Not Applicable</u> ; USE 'B' for <u>Not Accessible</u>					NOTES:				PHOTO#

MOTOR

NAME (Building or Equip)								REV.#			
LOCATION (Building or Equip)								PG. __ OF __			
DRAWING REF											
COLLECTED BY				DATE COMPLETED							
I.D. & FED FROM	MFG. TYPE	# OF MOTORS:	INDIVIDUAL HP or	FLA/S.F.	RPM	LR CODE	VOLTAGE	DRIVE FED? Y OR N	BYPASS? Y OR N	SOFT- START Y OR N	
		INDIVIDUAL	COMBINED HP (CHP)		FREQ						S.F.
		COMBINED	(see note)								
AHU-1	WESTINGHOUSE	1	75	90/1.0	1800	G	480				
MCC-1-1A	INDUCTION	4	100 CHP		60HZ	1.15	480				
ACC-3	MCQUAY						480				
MDPH1					60HZ						
ACC-2	MCQUAY						480				
MDPH1											
ACC-1	MCQUAY						480				
MDPH2											
AHU-1	MCQUAY	1	25		1750		480	Y			
MDPH1		INDIVIDUAL	INDIVIDUAL HP		60HZ						
AHU-1	MCQUAY	1	25		1750		480	Y			
MDPH1		INDIVIDUAL	INDIVIDUAL HP		60HZ						
AHU-2	MCQUAY	2	40		1750		480	Y			
MDPH1		COMBINED	COMBINED HP (CHP)		60HZ						
AHU-3EA	MCQUAY	2	30		1750		480	Y			
MDPH1		COMBINED	COMBINED HP (CHP)		60HZ						
AHU-4EA	MCQUAY	2	40		1750		480	Y			
MDPH1		COMBINED	COMBINED HP (CHP)		60HZ						
AHU-13EA	MCQUAY	2	40		1750		480	Y			
MDPH1		COMBINED	COMBINED HP (CHP)		60HZ						
AHU-6	MCQUAY	2	30		1750		480	Y			
MDPH2		COMBINED	COMBINED HP (CHP)		60HZ						
AHU-5	MCQUAY	2	30		1750		480	Y			
SDPH21		COMBINED	COMBINED HP (CHP)		60HZ						
AHU-7	MCQUAY	1	30		1750		480	Y			
SDPH21		INDIVIDUAL	INDIVIDUAL HP		60HZ						
AHU-7	MCQUAY	1	30		1750		480	Y			
SDPH21		INDIVIDUAL	INDIVIDUAL HP		60HZ						

MOTOR

NAME (Building or Equip)								REV.#			
LOCATION (Building or Equip)								PG. __ OF __			
DRAWING REF											
COLLECTED BY				DATE COMPLETED							
I.D. & FED FROM	MFG. TYPE	# OF MOTORS:	INDIVIDUAL HP or	FLA/S.F.	RPM	LR CODE	VOLTAGE	DRIVE	BYPASS?	SOFT- START	
		INDIVIDUAL	COMBINED HP (CHP)		FREQ			FED?			Y OR N
		COMBINED	(see note)					Y OR N			
AHU-8 SDPH21	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-8 SDPH21	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-9 SDPH22	MCQUAY	2 COMBINED	30 COMBINED HP (CHP)		1750 60HZ		480	Y			
AHU-10 SDPH22	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-10 SDPH22	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-11 SDPH22	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-11 SDPH22	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-12 H1L4	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
AHU-12 H1L4	MCQUAY	1 INDIVIDUAL	30 INDIVIDUAL HP		1750 60HZ		480	Y			
CWP-1 H2B2	ARMSTRONG	1 INDIVIDUAL	40 INDIVIDUAL HP		3600		480	Y			
DC-1 H1L2	TORIT UNIMASTER	1 INDIVIDUAL	30 INDIVIDUAL HP		60HZ		480				
HWP-1/2 H2B2	ARMSTRONG	1 INDIVIDUAL	50 INDIVIDUAL HP		1800		480	Y			
HWP-1/2 H2B2	ARMSTRONG	1 INDIVIDUAL	50 INDIVIDUAL HP		1800		480	Y			
WFC-1 H1L1	TORIT POWERCORE	1 INDIVIDUAL	30 INDIVIDUAL HP				480	Y			

MOTOR

NAME (Building or Equip)								REV.#			
LOCATION (Building or Equip)								PG. __ OF __			
DRAWING REF											
COLLECTED BY				DATE COMPLETED							
I.D. & FED FROM	MFG. TYPE	# OF MOTORS:	INDIVIDUAL HP or	FLA/S.F.	RPM FREQ	LR CODE	VOLTAGE	DRIVE	BYPASS?	SOFT-	
		INDIVIDUAL	COMBINED HP (CHP)			S.F.		FED?			START
		COMBINED	(see note)					Y OR N			Y OR N
PAC-1	GARDNER DENVER	1	27				480				
H2B2		INDIVIDUAL	INDIVIDUAL HP								

Area in gray is an example.

- 1. Individually list motors 25 HP and larger. For motors less than 25 HP, record location and combined HP.
- 2. On individually listed motors, include starter type if other than full voltage non-reversing.

USE 'A' for Not Applicable; USE 'B' for Not Accessible

For location use building, floor, room ex. Bldg 1, 2nd Floor, RM 208B.

For equipment located outside use compass heading and nearest building, grounds Ex. Eastside of Bldg #1 , grounds

NOTES:	PHOTO:

GENERAL ELECTRIC

DRY TYPE OL INDOOR-TYPE OL-WP WEATHERPROOF WITH WP KIT

3 PHASE 60 Hz CLASS AA

MODEL NO. 91251B 3876

SERIAL LN

KVA 150

150°C RISE

HV 480

VOLTS LINE TO LINE

LV 208

VOLTS LINE TO LINE

LV 120

VOLTS LINE TO NEUTRAL


APPROX. HEIGHT

946

LBS.

5.55

% IMP.



JUMPER CONNECTIONS EACH PHASE

VOLTS	TAP	VOLTS	TAP
480	1	156	5
440	2	144	6
400	3	132	7
360	4		

THIS TRANSFORMER MAY BE INSTALLED WITH ACCESSORIES LISTED ON DWG. 3330039AA

BEFORE HANDLING, INSTALLING AND OPERATING SEE INSTRUCTIONS GEK 33276

TRANSFORMER

MADE IN U.S.A.

X0 HAS BEEN INTERNALLY GROUNDED TO THE FRAME AT THE FACTORY. GROUND CONNECTION MAY BE REMOVED WHEN NOT REQUIRED.

N.P. 183894

137 of 155

LISTED

ALTERNATOR DATA

200kW ALTERNATOR 60 Hz

Alternator Ratings (Series Wye Testing)

kW	200
kVA	250
Type	Brushless/PMG
Connections	12 Lead
Efficiency @ 1.0 Power Factor	208/240 480/600
20% Load	88.45 89.8
40% Load	89.14 90.5
60% Load	89.54 90.9
80% Load	89.44 90.8
100% Load	89.24 90.6
100% @ 0.8 PF	88.75 90.1

Machine Parameters Continued

Waveform Distortion	<5%
Telephone Influence Factor	<50
Synchronous Speed	1800 rpm
Maximum Overspeed	3300 rpm
Number of Bearings	1 Sealed Ball
Insulation System	Class H
Excitation System	Class H

Temperature Rise vs Output (0.8 pf)

kW Rating	Temp Rise ° C	Temperature Rise is based
153	80 °	40° C Ambient
183	105 °	
200	120 °	

Machine Parameters @ Max kW Ratings

Subtransient Reactance p.u.	0.15
Transient Reactance	0.23
Synchronous Reactance	2.05
Negative Sequence Reactance	0.26
Zero Sequence Reactance	0.07
Short Circuit Ratio	0.28
Excitation Voltage	190
Excitation Current @ Rated kW	5.0A
Lamination Type	520


Instantaneous Voltage Dip

Voltage	10%	15%	20%	25%	30%	35%
208, 240	140	210	280	350	420	490
480	187	280	373	467	560	653
600						

Options - - - - - Antifungal Coating
Alternator Heater

Alt Damage - - - - -
3-Ø Short Circuit Current - - - - -
All data at 480 volt

ALTERNATOR DECREMENT CURVE



KELLY WALSH HIGH SCHOOL

200KW ~~150KW~~ STANDBY NATURAL GAS GENERATOR SYSTEM SUBMITTALS

BILL OF MATERIALS

Quantity (1) Generac industrial gas engine driven generator, turbocharged, aftercooled, 6 cylinder 12.9L engine, consisting of the following features and accessories:

- Fuel system - Natural gas
- SG0150KG20129N18HPSYE
- Stationary Emergency-Standby rated
- 200KW • ~~150~~ kW Rating, synchronous alternator, wired for 277/480 VAC 3 Phase, 60 HZ
- Permanent magnet excitation
- H-100 Control Panel
 - Meets NFPA 99 and 110 requirements
 - Temp Range -40 to 70 degrees C
 - Digital microprocessor:
 - Two 4 line x 20 displays, full system status
 - 3 phase sensing, +/-0.25% digital voltage regulation
 - RS232, RS485 and Canbus remote ports
 - Waterproof connections
 - All engine sensors are 4-20 ma for minimal interference
 - Programmable I/O
 - Built-in PLC for special applications
 - Engine function monitoring and control:
 - Full range standby operation; Programmable auto crank, Emergency Stop, Auto-Off-Manual switch
 - Isochronous governor, +/-0.25% frequency regulation
 - Full system status on all AC output and engine function parameters
 - Service reminders, trending, fault history (alarm log)
 - I2T function for full generator protection
 - Selectable low-speed exercise
 - 2-wire start controls for any 2-wire transfer switch
- Electronic governor Frequency regulation, isochronous Steady state regulation +/- 0.25%
- 150A • ~~100A~~ UL CB, 100% Rated
 - Thermal/Mag w/ST & Contacts, LH
- 100A UL CB, 100% Rated
 - Thermal/Mag w/ST & Contacts., RH
- Sound attenuated, Level 1 Acoustic enclosure
 - Industrial Grey enclosure, powder paint finish
- 225AH, 1155 CCA, 8D battery
 - installed
- 10AMP battery charger-installed
- Battery heating pad, installed
- Battery charging alternator
- Battery cables
- Battery tray
- Fuel shut-off solenoid valve
- Solenoid activated starter motor

CIRCUIT BREAKER DATA

EATON CIRCUIT BREAKERS 100% RATED THERMAL-MAGNETIC

AMPS	VOLTS	ACCESSORIES	EATON #	SERIES	FRAME	GENERAC #
70	600	No Accessories	JGE3070FAGC	G	JG-FRAME	0H9302TH00
		Shunt Trip & Aux. Contacts	JGE3070FAGCA2() ²			0H9302TH() ³
80	600	No Accessories	JGE3080FAGC	G	JG-FRAME	0J0841TH00
		Shunt Trip & Aux. Contacts	JGE3080FAGCA2() ²			0J0841TH() ³
90	600	No Accessories	JGE3090FAGC	G	JG-FRAME	0J0837TH00
		Shunt Trip & Aux. Contacts	JGE3090FAGCA2() ²			0J0837TH() ³
100	600	No Accessories	JGE3100FAGC	G	JG-FRAME	0H9314TH00
		Shunt Trip & Aux. Contacts	JGE3100FAGCA2() ²			0H9314TH() ³
125	600	No Accessories	JGE3125FAGC	G	JG-FRAME	0J0231TH00
		Shunt Trip & Aux. Contacts	JGE3125FAGCA2() ²			0J0231TH() ³
150	600	No Accessories	JGE3150FAGC	G	JG-FRAME	0H9315TH00
		Shunt Trip & Aux. Contacts	JGE3150FAGCA2() ²			0H9315TH() ³
175	600	No Accessories	JGE3175FAGC	G	JG-FRAME	0H9316TH00
		Shunt Trip & Aux. Contacts	JGE3175FAGCA2() ²			0H9316TH() ³
200	600	No Accessories	JGE3200FAGC	G	JG-FRAME	0J0232TH00
		Shunt Trip & Aux. Contacts	JGE3200FAGCA2() ²			0J0232TH() ³
225	600	No Accessories	JGE3225FAGC	G	JG-FRAME	0H9317TH00
		Shunt Trip & Aux. Contacts	JGE3225FAGCA2() ²			0H9317TH() ³
250	600	No Accessories	JGE3250FAGC	G	JG-FRAME	0H9318TH00
		Shunt Trip & Aux. Contacts	JGE3250FAGCA2() ²			0H9318TH() ³
300	600	No Accessories	LGE3300FAGC	G	LG-FRAME	0H9319TH00
		Shunt Trip & Aux. Contacts	LGE3300FAGCA2() ²			0H9319TH() ³
350	600	No Accessories	LGE3350FAGC	G	LG-FRAME	0H9320TH00
		Shunt Trip & Aux. Contacts	LGE3350FAGCA2() ²			0H9320TH() ³
400	600	No Accessories	LGE3400FAGC	G	LG-FRAME	0H9321TH00
		Shunt Trip & Aux. Contacts	LGE3400FAGCA2() ²			0H9321TH() ³
500	600	No Accessories	LGE3500FAGC	G	LG-FRAME	0H9323TH00
		Shunt Trip & Aux. Contacts	LGE3500FAGCA2() ²			0H9323TH() ³
600	600	No Accessories	LGE3600FAGC	G	LG-FRAME	0H9324TH00
		Shunt Trip & Aux. Contacts	LGE3600FAGCA2() ²			0H9324TH() ³
700 ¹	600	No Accessories	CMDLB3800T33W	C	M-FRAME	0H9325TH00
		Shunt Trip & Aux. Contacts	CMDLB3800T33WA13S02			0H9325THB0
800 ¹	600	No Accessories	CMDLB3800T33W	C	M-FRAME	0H9326TH00
		Shunt Trip & Aux. Contacts	CMDLB3800T33WA13S02			0H9326THB0
900 ¹	600	No Accessories	CND312T33W	C	N-FRAME	0H9327TH00
		Shunt Trip & Aux. Contacts	CND312T33WA12S03			0H9327THB0
1000 ¹	600	No Accessories	CND312T33W	C	N-FRAME	0H9328TH00
		Shunt Trip & Aux. Contacts	CND312T33WA12S03			0H9328THB0
1200 ¹	600	No Accessories	CND312T33W	C	N-FRAME	0H9329TH00
		Shunt Trip & Aux. Contacts	CND312T33WA12S03			0H9329THB0
1400 ¹	600	No Accessories	CRD316T33W	C	R-FRAME	0H9360TH00
		Shunt Trip & Aux. Contacts	CRD316T33WA12S21			0H9360THB0
1600 ¹	600	No Accessories	CRD316T33W	C	R-FRAME	0H9361TH00
		Shunt Trip & Aux. Contacts	CRD316T33WA12S21			0H9361THB0
2000 ¹	600	No Accessories	CRD320T33W	C	R-FRAME	0H9367TH00
		Shunt Trip & Aux. Contacts	CRD320T33WA12S21			0H9367THB0

¹LS-type electronic trip breaker


²S4 = 12VDC

³B0 = 12VDC

²S1 = 24VDC

³C0 = 24VDC

TRIP ADJUSTMENT DIALS FOR MICROLOGIC 6.0, 6.0A, 6.0P, & 6.0H TRIP UNITS



Notes

ln = sensor
lr = long time pickup setting
tr = long time delay setting
lsd = short time pickup setting
tsd = short time delay setting
li = instantaneous setting

lg = ground fault pickup setting
tg = ground fault delay setting

- 1) Eight interchangeable rating plugs are available to limit the long-time pickup setting range for greater versatility. (Type A is the standard plug and corresponds to settings shown above.)
- 2) P and H trip units also have protective relay features and selectable long-time delay bands such as I²T. These settings are programmed in through a keypad or computer link.

Trip Dials for H-, J-Frame Micrologic 3.2 & 3.2S

The following dial descriptions may be applicable for Micrologic 3.2 & 3.2S trip units.



Sensor rating is **In**

Long-time pickup protection adjustment dial **Ir**

Long-time delay protection adjustment dial **tr**

Short-time pickup protection adjustment dial **Isd**

Instantaneous protection adjustment dial **Ii**



For more information on how to set these trip units, please refer to the User Guide 48940-313-01.

Trip Dials for L-Frame Micrologic 3.3 & 3.3S

The following dial descriptions may be applicable for Micrologic 3.3 & 3.3S trip units.



Sensor rating is **In**

Long-time pickup protection adjustment dial **Ir**

Long-time delay protection adjustment dial **tr**


Short-time pickup protection adjustment dial **Isd**

Instantaneous protection adjustment dial **Ii**




For more information on how to set these trip units, please refer to the User Guide 48940-313-01.

TRIP ADJUSTMENT DIAL FOR M-FRAME, ET1.0



TRIP ADJUSTMENT DIAL FOR P- AND R-FRAME, ET1.0I










Notes

li = instantaneous setting

MOLDED CASE CIRCUIT BREAKERS

MAGNETIC (INSTANTANEOUS) TRIP ADJUSTMENT DIALS
(ON FRONT OF BREAKER)




NOTE: THE "LO" AND "HI" MARKINGS APPEAR ON THE DIAL FACES.
THE MARKINGS IN PARENTHESES DO NOT.


SETTINGS SHOWN ARE FOR ILLUSTRATION ONLY

GROUND FAULT MODULE TRIP ADJUSTMENT DIALS

GFM100 AND GFM250




GROUND - CENSOR



NOTE: THE MARKINGS IN PARENTHESES DO NOT APPEAR ON THE DIAL FACE
SETTINGS SHOWN ARE FOR ILLUSTRATION ONLY

STANDARD ARC FLASH STUDY OPTIONS – SKM



Arc Flash - Study Options

Standard and Unit | Fault Current | Report Options

Standard

☒ NFPA 70E 2012 Annex D.7
 IEEE 1584 - Preferred Method
 (CSA-Z462 Annex D.7)

☐ NFPA 70E 2012 Annex D.5
 (CSA-Z462 Annex D.5)

☐ NESC 2012 Edition

☐ DC Systems
 Arc Flash Evaluation

DC Short Circuit:

☒ ANSI

☐ IEC

 Options...

Flash Boundary Calculation Adjustments

Above 1 kV, Trip Time ≤ 0.1 s: Use 1.2 cal/cm² (5.0 J/cm²) for Boundary Ca

Equipment Below 1 kV: Use Incident Energy Equation to Calculate Boundary

< 240 V

 Report as Category 0 if Fed by XFMR < 125 kVA (NFPA 70E-2009)

Units

☒ English

☐ Metric

Incident Energy:

☐ J/cm²


☒ cal/cm²

Distance and Boundary:

☒ in

☐ feet

OK Cancel Help



Arc Flash - Study Options

Standard and Unit | Fault Current | Report Options

Max Arcing Duration

☒ Use Global Max Arcing Time

 > 240 Volts: 2 sec

 ≤ 240 Volts: 2 sec

☐ Enter for Each Bus

 Max Arcing Time for Each Bus...

Arcing Tolerances...

 Pre-Fault Voltage...

 Utility and Impedance Tolerance...

 Fixed or Movable for Each Bus...

☐ Include Transformer Tap

☒ Include Transformer Phase Shift

 Define Grounded as SLG/3P Fault \geq : 5.0 %

Reduce Generator / Synchronous Motor Fault Contribution To

300.0 % of Rated Current after 10.0 cycles

☒ Apply To Generators

☐ Apply To Synchronous Motor

☒ Recalculate Trip Time Using Reduced Current

Induction Motor Fault Contribution

Include for: 5.0 cycles

☒ Exclude if < 50.0 hp

Treat Fuses As

☐ All Current Limiting

☒ All Standard

☐ Specified in Library

 Use 1/2 or 1/4 cycles trip time if arcing fault is in current limiting range

Arc Flash Equations for Breakers and Fuses

☐ Use Equipment Specific Arc Flash Equation in Protective Device Library

OK Cancel Help

Per the IEEE 1584 Standard, LV arcing fault current tolerances are -15% (Low) and 0% (High).
 No Load with Tap was used for the Pre-fault voltage Option
 No other tolerances were considered, unless written up in this report.

Arc Flash - Study Options

Standard and Unit | Fault Current | Report Options

Report Option

☐ Bus ☐ Worst Case Only

☐ Protective Device Load Side

☐ Protective Device Line Side

☒ Bus + Protective Device Line Side

☐ Bus + Line Side + Load Side

Color One-line


☐ Bus + Prot.

☒ Bus

☐ Prot. Device

Upstream Mis-Coordination Options

☒ Check Upstream devices for mis-coordination

Upstream Levels to Search: 

Mis-Coordination Ratio: %

Line Side + Load Side Fault Contribution Options

☒ Line + Load Sides ☐ Line Side Only

Device to Report in Labels and Summary View

☐ Last Trip Device ☒ Main Device

Report Options when Equipment Evaluation Failed

☒ Report IE/PPE ☐ As Overduty w/o Label

Cleared Fault Threshold: % of Total

Default Label # Prefix:

☒ Auto Update Arc Flash Results

☐ Main device fail to operate, use upstream devices

☐ Use Maintenance Mode function for main device

☐ Increase PPE Level by 1 for high marginal IE

☐ Report PPE Others 1, 2, 3, 4, 5

☐ Report Function Name for multiple functions

PPE Table... Scenarios... Additional Incident Energy and Flash Boundary... Shock Approach Boundary ... Glove Class... Report Data and Order...

OK Cancel Help

Personal Protective Equipment Table

	Incident Energy From (cal/cm ²)	Incident Energy To (cal/cm ²)	IE Low Marginal (cal/cm ²)	IE High Marginal (cal/cm ²)	Hazard Risk Category	PPE Level	Clothing Layers	Required Minimum Arc Rating of PPE (cal/cm ²)	Notes	Category Background Color	Category Foreground Color	Warning Label Text	Head & Eye & Hearing Protection
1	0.0	1.2	0.000	1.190	0	Nonmelting or Untreated Fiber with Weight >= 4.5 oz/sq yd	1	N/A				WARNING	Safety Glasses or Goggles + Ear Canal Inserts
2	1.2	4.0	1.210	3.900	1	Arc-rated shirt & pants or arc-rated coverall	1	4				WARNING	Hardhat + Arc-rated hard hat liner + Safety Glasses or Goggles + Ear Canal Inserts
3	4.0	8.0	4.100	7.800	2	Arc-rated shirt & pants or arc-rated coverall	1 or 2	8				WARNING	Hardhat + Arc-rated hard hat liner + Safety Glasses or Goggles + Ear Canal Inserts
4	8.0	25.0	8.200	24.000	3	Arc-rated shirt & pants + arc-rated coverall + arc-rated arc flash suit	2 or 3	25				WARNING	Hardhat + Arc-rated hard hat liner + Safety Glasses or Goggles + Ear Canal Inserts
5	25.0	40.0	26.000	38.000	4	Arc-rated shirt & pants + arc-rated coverall + arc-rated arc flash suit	3 or more	40				WARNING	Hardhat + Arc-rated hard hat liner + Safety Glasses or Goggles + Ear Canal Inserts
6	40.0	999.0	41.000	998.000	Dangerous!	DO NOT WORK ON LIVE!	DO NOT WORK ON LIVE!	N/A	DO NOT WORK ON LIVE!			DANGER	DO NOT WORK ON LIVE!

IE Low/High Margin... Add Row Save As Default Reset Default OK Cancel Print Help

Project Specific PPE Table Location: C:\PTW32\LIB\VR_Clothing.ss3

Load Save

FROM NFPA 70E – 2012 EDITION

Table 130.4(C)(a) Approach Boundaries to Energized Electrical Conductors or Circuit Parts for Shock Protection for Alternating-Current Systems (All dimensions are distance from energized electrical conductor or circuit part to employee.)

(1)	(2)	(3)	(4)	(5)
Nominal System Voltage Range, Phase to Phase ^a	Limited Approach Boundary ^b		Restricted Approach Boundary ^b ; Includes Inadvertent Movement Adder	Prohibited Approach Boundary ^b
	Exposed Movable Conductor ^c	Exposed Fixed Circuit Part		
Less than 50	Not specified	Not specified	Not specified	Not specified
50 to 300	3.0 m (10 ft 0 in.)	1.0 m (3 ft 6 in.)	Avoid contact	Avoid contact
301 to 750	3.0 m (10 ft 0 in.)	1.0 m (3 ft 6 in.)	0.3 m (1 ft 0 in.)	25 mm (0 ft 1 in.)
751 to 15 kV	3.0 m (10 ft 0 in.)	1.5 m (5 ft 0 in.)	0.7 m (2 ft 2 in.)	0.2 m (0 ft 7 in.)
15.1 kV to 36 kV	3.0 m (10 ft 0 in.)	1.8 m (6 ft 0 in.)	0.8 m (2 ft 7 in.)	0.3 m (0 ft 10 in.)
36.1 kV to 46 kV	3.0 m (10 ft 0 in.)	2.5 m (8 ft 0 in.)	0.8 m (2 ft 9 in.)	0.4 m (1 ft 5 in.)
46.1 kV to 72.5 kV	3.0 m (10 ft 0 in.)	2.5 m (8 ft 0 in.)	1.0 m (3 ft 3 in.)	0.7 m (2 ft 2 in.)
72.6 kV to 121 kV	3.3 m (10 ft 8 in.)	2.5 m (8 ft 0 in.)	1.0 m (3 ft 4 in.)	0.8 m (2 ft 9 in.)
138 kV to 145 kV	3.4 m (11 ft 0 in.)	3.0 m (10 ft 0 in.)	1.2 m (3 ft 10 in.)	1.0 m (3 ft 4 in.)
161 kV to 169 kV	3.6 m (11 ft 8 in.)	3.6 m (11 ft 8 in.)	1.3 m (4 ft 3 in.)	1.1 m (3 ft 9 in.)
230 kV to 242 kV	4.0 m (13 ft 0 in.)	4.0 m (13 ft 0 in.)	1.7 m (5 ft 8 in.)	1.6 m (5 ft 2 in.)
345 kV to 362 kV	4.7 m (15 ft 4 in.)	4.7 m (15 ft 4 in.)	2.8 m (9 ft 2 in.)	2.6 m (8 ft 8 in.)
500 kV to 550 kV	5.8 m (19 ft 0 in.)	5.8 m (19 ft 0 in.)	3.6 m (11 ft 10 in.)	3.5 m (11 ft 4 in.)
765 kV to 800 kV	7.2 m (23 ft 9 in.)	7.2 m (23 ft 9 in.)	4.9 m (15 ft 11 in.)	4.7 m (15 ft 5 in.)

Note: For arc flash boundary, see 130.5(A).

^a For single-phase systems, select the range that is equal to the system's maximum phase-to-ground voltage multiplied by 1.732.

^b See definition in Article 100 and text in 130.4(D)(2) and Annex C for elaboration.

^c This term describes a condition in which the distance between the conductor and a person is not under the control of the person. The term is normally applied to overhead line conductors supported by poles.

FROM INFORMATIVE ANNEX H, NFPA 70E – 2012 EDITION

Table H.3(b) Guidance on Selection of Arc-Rated Clothing and Other Personal Protective Equipment (PPE) for Use When Incident Exposure is Determined by a Hazard Analysis

Incident Energy Exposure	Protective Clothing and PPE
Less than or Equal to 1.2 cal/cm²	
Protective clothing, nonmelting (in accordance with ASTM F 1506-08) or untreated natural fiber	Shirt (long sleeve) and pants (long) or coverall
Other personal protective equipment	Face shield for projectile protection (AN) Safety glasses or safety goggles (SR) Hearing protection Heavy-duty leather gloves or rubber insulating gloves with leather protectors (AN)
Greater than 1.2 to 12 cal/cm²	
Arc-rated clothing and equipment with an arc rating equal to or greater than the incident energy determined in a hazard analysis (<i>See Note 3.</i>)	Arc-rated long-sleeve shirt and arc-rated pants or arc-rated coverall or arc flash suit (SR) (<i>See Note 3.</i>) Arc-rated face shield and arc-rated balaclava or arc flash suit hood (SR) (<i>See Note 1.</i>) Arc-rated jacket, parka, or rainwear (AN)
Other personal protective equipment	Hard hat Arc-rated hard hat liner (AN) Safety glasses or safety goggles (SR) Hearing protection Heavy-duty leather gloves or rubber insulating gloves with leather protectors (SR) (<i>See Note 4.</i>) Leather work shoes
Greater than 12 cal/cm² Task tables in 70E list requirements for protective clothing and other protective equipment when working within the arc flash boundary for incident energy equaling 40 cal/cm² , and below.	
Arc-rated clothing and equipment with an arc rating equal to or greater than the incident energy determined in a hazard analysis (<i>See Note 3.</i>)	Arc-rated long-sleeve shirt and arc-rated pants or arc-rated coverall and/or arc flash suit (SR) Arc-rated arc flash suit hood Arc-rated gloves Arc-rated jacket, parka, or rainwear (AN)
Other personal protective equipment	Hard hat Arc-rated hard hat liner (AN) Safety glasses or safety goggles (SR) Hearing protection Arc-rated gloves or rubber insulating gloves with leather protectors (SR) (<i>See Note 4.</i>) Leather work shoes

AN: As needed [in addition to the protective clothing and PPE required by 130.5(B)(1)].

SR: Selection of one in group is required by 130.5(B)(1).

Notes:

(1) Face shields with a wrap-around guarding to protect the face, chin, forehead, ears, and neck area are required by 130.8(C)(10)(c). For full head and neck protection, use a balaclava or an arc flash hood.



- (2) All items not designated "AN" are required by 130.7(C).
- (3) Arc ratings can be for a single layer, such as an arc-rated shirt and pants or a coverall, or for an arc flash suit or a multi-layer system consisting of a combination of arc-rated shirt and pants, coverall, and arc flash suit.
- (4) Rubber insulating gloves with leather protectors provide arc flash protection in addition to shock protection. Higher class rubber insulating gloves with leather protectors, due to their increased material thickness, provide increased arc flash protection.

PROJECT RECOMMENDATION & ACTION TABLE

Action No.	Recommendation	Action	Person Assigned	Due Date
1	De-energize Equipment	Create a policy to only work on electrical equipment when the system has been de-energized.		
2	Establish Arc Flash Training Program	1) Develop training routine for each employee. 2) Train employees to know the difference between a qualified and an unqualified employee. 3) Post and enforce all arc flash policies based upon customer's training program.		
3	Project Management	Recommend keeping accurate records on system changes and re-evaluate arc flash results every 5 years. Failure to do this may invalidate the arc flash results.		
4	Provide and Train Employees on PPE	Equip all employees with proper PPE and train them about the various types of required PPE to work on energized equipment where an arc flash hazard may be present.		
5	Implement a Formal Maintenance Program	Inspect, test, and maintain all electrical equipment based upon O&M manuals provided with each individual piece of equipment.		
6	System One-Line Diagram Management Program	Establish a routine program of updating all one-line diagrams associated with the electrical system to be used for future reference as well as lockout-tagout procedures and other system maintenance.		

This table is a summary of various recommendations to implement a training and maintenance program for an electrical system. It is to be used in conjunction with NFPA, OSHA, and other industry recommendations for safety and maintenance of an electrical system.

APPENDIX E: SYSTEM STUDY ONE-LINE DIAGRAM



REVISIONS			
7/	DATE	DESCRIPTION	DRAWN BY

Casper, WY

PROJECT NO.
34765053

SHEET NO.

1 OF 2



SCHNEIDER ELECTRIC
ENGINEERING SERVICES, LLC

106 MERCER RD
LEXINGTON, KY 40511

NOTES:

- ALL LOW-VOLTAGE CABLES WERE CONSIDERED TO BE TYPE THHN, SINGLE CONDUCTOR COPPER, RUN IN STEEL CONDUIT, UNLESS OTHERWISE NOTED.
- ALL DEVICES WERE CONSIDERED TO BE THREE-POLE UNLESS OTHERWISE NOTED.
- ★ - DENOTES THE VALUE WAS ASSUMED.
- KVA/m - CONNECTED MOTOR KVA USED FOR FAULT CALCULATIONS (1 HP=1 KVA/m).
- AF DENOTES AMPERE FRAME RATING
AS DENOTES AMPERE SENSOR RATING
AP DENOTES AMPERE PLUG RATING
AT DENOTES AMPERE TRIP RATING
- L DENOTES LONG TIME FUNCTION
S DENOTES SHORT TIME FUNCTION
I DENOTES INSTANTANEOUS FUNCTION
G DENOTES GROUND FUNCTION

REVISIONS

REV	DATE	DESCRIPTION	DRAWN	CHECKED
8				
7				
6				
5				
4				
3				
2				
1				

Kelly Walsh HS

Casper,WY

Additional Info

DRAWN BY:	CB
CHECKED BY:	CB
DATE:	07-18-2014
SCALE:	NTS

PROJECT NO.
34765053

ONE-LINE DIAGRAM

SHEET NO.

2 OF 2

