

ADDENDUM NO. 1

July 25, 2020

RE: **Wingfield High School – Structural & Concrete Repairs**

Jackson Public Schools
Jackson, Mississippi
A/E Project No. 18-032a

FROM: Eley Guild Hardy Architects
329 Capitol Street
Jackson, MS 39201
(601) 354-2572

TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated March 24, 2020. Acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page and 2 pages of 8-1/2”X11” attachments.

CLARIFICATION

1. Pre-Bid Meeting: Find attached the Pre-Bid Meeting sign in sheet for your reference.

CHANGES TO DRAWINGS

1. Sheet AS001 – Overall Existing Site Plan: Delete note reading: *“Brick wall to be removed & replaced – see struct; face brick shall match existing face brick in color, size & texture.”* And replace with note reading *“Double wythe brick wall at this location has fallen; contractor to remove all pieces of fallen brick wall in its entirety from the jobsite; contractor to remove remaining brick course and mortar at existing concrete in its entirety down to the existing concrete surface – grind remnants of mortar on concrete surface off and leave concrete even with adjacent concrete surfaces.”*
2. Sheet AS002 – Site Details & Enlarged Plans: revise the following:
 - a. On Detail ‘7/AS002’: Delete note reading “Portion of brick wall to be removed & replaced – see struct.” And replace with note reading “Brick wall that has fallen; contractor to remove fallen pieces and grind down remaining mortar at concrete slab.”
 - b. On Detail ‘7/AS002’: Delete note reading “Note: New brick shall match existing brick in color, texture, & size.” In its entirety.
 - c. On Detail ‘8/AS002’: Delete this photo and replace with the attached photo.
3. Sheet S101 – Foundation and First Floor Framing Plan – Demo: Delete text reading “Ex Brick Wall to be Removed”.
4. Sheet S102 – Foundation and First Floor Framing Plan – New: Delete text reading “New Masonry Wall”.
5. Sheet S201 – Details: Delete detail “1/S201 in its entirety. (*Note: fallen brick wall is not being replaced*)

END OF ADDENDUM 1

ELEY GUILD HARDY ARCHITECTS

PRINCIPALS

James H. Eley, FAIA
W. Taylor Guild, III, AIA, CCS
David J. Hardy, AIA
Stephen A. Stojich, AIA
Joseph B. Crain, AIA
Mark E. Lishen, AIA, LEED AP
J. Heath Perry, AIA, CSI, CDT
Kyle L. Kish, AIA, LEED AP
Jennifer L. Seymour, AIA

18-032A PRE BID MEETING SIGN-IN SHEET

Date: July 23, 2020

Time: 1:00 P.M.

Location: Wingfield Highschool

Project: Wingfield High School – Structural & Concrete Repairs

Participants:

ASSOCIATES

Joseph R. Stevens, Jr., AIA, LEED AP
Eric J. Commarato, AIA
Daniel Hamburg, AIA, LEED AP

NAME	ORGANIZATION	EMAIL	PHONE
Jennifer Seymour	EGH Architects	jseymour@egh.ms	228.424.3079
Mike McBride	JPS Bond Coordinator	mmcbride@jackson.k12.ms.us	601-953-3051
STEVE PHYFER	EGH	sphyfer@egh.ms	601-842-3286
CHRIS CRADDOCK	THRASH	ccraddock@thrashco.com	601-777-3593
ALVIN WILLEY	THRASH	awilley@thrashco.com	601-825-8917
James Anderson	Anderson Const.	James Anderson17637	601-397-0200
Ashley Traxler	Traxler const. LLC	traxcon@yahoo.com	601-260-7969
Omar Ali	Robertson Construction	Omar@Robertsonms.com	601-968-7007
Taylor Pruitt	Robertson Construction	Taylor@Robertsonms.com	601-502-5191
Mitch Simpson	EGH Construction	Mitch@EGHConstructionms.com	601-209-5110
MIKE MCBRIDE			
Nick Kaminer	Mayrant	nich@mayrant.com	601-573-6985

BILOXI OFFICE

1091 Tommy Munro Drive
Biloxi, MS 39532
228.594.2323 P

JACKSON OFFICE

329 East Capitol Street
Jackson, MS 39201
601.354.2572 P

www.egh.ms



FALLEN BRICK
WALL- REMOVE
ALL PIECES AND
MORTAR FROM
SITE

REMOVE REMAINING
BRICK AND MORTAR
FROM EXIST CONCRETE

DETAIL 8/AS002