

Addendum 1 Gym Floor Replacements

1. Under qualifications, B should be MFMA approved as an accredited installer, yet you are not using MFMA Maple. Are you only accepting maple flooring from this one mill Premier? Who is not a member of MFMA. There are six mills that are six mills that are members Acer, Action, Connor, Horner, Robbins, and WD. Please see www.maplefloor.org

You may also use maple from one of the six mills. Bidders should be able to document that they are MFMA accredited.

2. 1.02 Quality Assurance B. Will the HVAC system be able to control the relative humidity below 50% year round? If not your moisture content will exceed 10%.

The owner maintains the HVAC system within certain temperatures annually. The temperatures maintained should be within those limits unless the system is broken.

3. Part 2 Product A.2 according to MFMA grading regulations, who would determine that? The MFMA isn't involved.

The owner is second grade or better for this project. Each bidder should be able to verify that they are using second grade or better.

4. Is a blower system required? A picture is included with no specifications.

The owner is requiring a airflow system. The system should be comparable to the AACER Power Vent. The specifications to the powervent are attached to this addendum.

5. Part 3 3.02 demo at Palmetto remove the existing floor and pour a new slab. This is not possible with the timeline concrete must cure sixty days before a wood floor can be installed on top.

The owner is aware of the timeline for the concrete to cure and adjust the time for Palmetto Middle School to be completed by October 1, 2019.

6. How is the flooring to be installed at the other locations? Is the existing maple flooring to be removed and new flooring installed? If it is your plan to overlay the new maple over the existing that a really bad idea.

The other two locations do not have maple flooring. The new maple flooring will go over the existing flooring at both locations.

7. Do you require a certified bleacher contractor to move and replace the bleachers?

Yes, the owner does require a certified bleacher contractor to move and replace the current bleachers.

8. What are the working hours? With a time frame this tight we would require seven days a week access.

The owner will accommodate the hours that the successful bidder needs.

9. Are there logos and lettering on these floor? Is so how do we price them?

The floors will include 1 large basketball court, a volleyball court, and two side basketball courts. At a minimum the lettering should include what is currently in place.

See attached information on Airflow system specifications.

New timeline

Task	Date
Release of Invitation to Bid	May 17, 2019
Mandatory Pre-Bid Site Visit	May 24, 2019
Last day to receive questions	May 29, 2019
Bid submission date and time	June 10, 2019 11:00 AM
Intent to award notice	June 12, 2019
Execute Contract	To be determined, contingent upon board approval and contract negotiations