

## Attachment L - Results Summary Lead in Water Sample

**School Name: Gloucester City BOE - High School**

| Outlet Code | Sample ID     | Location/Description                            | Result (ppb) | Above AL? |
|-------------|---------------|---|--------------|-----------|
| 1S          | 38-0420-GHS01 | D-25 Sink                                       | 1.29         | No        |
| 2S          | 38-0420-GHS02 | Kitchen Staff Restroom Sink                     | 2.94         | No        |
| 3S          | 38-0420-GHS03 | Kitchen Sink across from Stove                  | ND           | No        |
| 4S          | 38-0420-GHS04 | Kitchen Double Sink under window-right side     | 15.5         | Yes       |
| 5S          | 38-0420-GHS05 | Kitchen Double Sink under window-left side      | 8.51         | No        |
| 6S          | 38-0420-GHS06 | Kitchen Single Sink under window                | 3.98         | No        |
| 7S          | 38-0420-GHS07 | Little Sink across from oven                    | 1.44         | No        |
| 8WF         | 38-0420-GHS08 | Water Fountain across from cafeteria-left side  | ND           | No        |
| 9WF         | 38-0420-GHS09 | Water Fountain across from cafeteria-right side | ND           | No        |
| 10S         | 38-0420-GHS10 | Girls locker Rm; restroom sink-1st one          | 2.15         | No        |
| 11S         | 38-0420-GHS11 | Girls locker Rm; office restroom sink           | 3.54         | No        |
| 12WF        | 38-0420-GHS12 | Water Fountan in Girls Locker Room              | ND           | No        |
| 13WF        | 38-0420-GHS13 | Water Fountain; Girls side of old gym           | ND           | No        |
| 14WF        | 38-0420-GHS14 | Water Fountain; Boys side of old gym            | 10.7         | No        |
| 15S         | 38-0420-GHS15 | C-24; Wall 2 first sink                         | ND           | No        |
| 16S         | 38-0420-GHS16 | C-24; Wall 1 first sink                         | ND           | No        |
| 17S         | 38-0420-GHS17 | C-22 Sink                                       | 5.32         | No        |
| 18S         | 38-0420-GHS18 | Boys locker Rm; Restroom Sink-1st one           | 1.01         | No        |
| 19S         | 38-0420-GHS19 | Boys locker Rm; Office Restroom Sink            | 1.88         | No        |
| 20S         | 38-0420-GHS20 | Boys Coaches loker Rm; Office Sink              | 1.61         | No        |

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

**School Name: Gloucester City BOE - High School**

| Outlet Code | Sample ID     | Location/Description                                   | Result (ppb) | Above AL? |
|-------------|---------------|--|--------------|-----------|
| 21S         | 38-0420-GHS21 | C-29 Trainers Rm Sink                                  | ND           | No        |
| 22I         | 38-0420-GHS22 | C-29 Trainers Rm Ice Machine                           | ND           | No        |
| 23S         | 38-0420-GHS23 | Staff restroom sink; girls-1st one                     | 3.52         | No        |
| 24WF        | 38-0420-GHS24 | C Wing Water Fountain-left side                        | ND           | No        |
| 25WF        | 38-0420-GHS25 | C Wing Water Fountain-right side                       | ND           | No        |
| 26S         | 38-0420-GHS26 | Girls C-wing restroom sink; across from staff restroom | 2.52         | No        |
| 27S         | 38-0420-GHS27 | C-Wing unisex restroom sink; right side                | 1.29         | No        |
| 28S         | 38-0420-GHS28 | C- Wing Staff boys restroom sink across from C-1       | 8.3          | No        |
| 29S         | 38-0420-GHS29 | C-1 First sink left side                               | 5.76         | No        |
| 30S         | 38-0420-GHS30 | C-2 Sink   | 8.63         | No        |
| 31WF        | 38-0420-GHS31 | C-Wing Water Fountain outside of new gym; left side    | ND           | No        |
| 32F         | 38-0420-GHS32 | C-Wing Water Fountain outside of new gym; right side   | ND           | No        |
| 33S         | 38-0420-GHS33 | Boys Restroom sink across from school store-1st one    | 1.42         | No        |
| 34S         | 38-0420-GHS34 | Girls Restroom sink across from school store-1st one   | ND           | No        |
| 35S         | 38-0420-GHS35 | Girls locker room; restroom sink-new gym               | 1.29         | No        |
| 36S         | 38-0420-GHS36 | Girls restroom sink; new gym foyer                     | ND           | No        |
| 37WF        | 38-0420-GHS37 | Water Fountain in new gym foyer; right side            | ND           | No        |
| 38WF        | 38-0420-GHS38 | Water Fountain in new gym foyer; left side             | ND           | No        |
| 39S         | 38-0420-GHS39 | Boys restroom sink; new gym foyer                      | ND           | No        |
| 40S         | 38-0420-GHS40 | Boys locker room; restroom sink in new gym             | 4.36         | No        |

Action Level (AL) ≥15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

**School Name: Gloucester City BOE - High School**

| Outlet Code | Sample ID     | Location/Description                                | Result (ppb) | Above AL? |
|-------------|---------------|---|--------------|-----------|
| 41E         | 38-0420-GHS41 | Exterior faucet outside of fieldhouse               | ND           | No        |
| 42S         | 38-0420-GHS42 | Girls restroom sink near E-2-1st one                | ND           | No        |
| 43WF        | 38-0420-GHS43 | Water Fountain; Right side; bottom of B-Wing        | ND           | No        |
| 44WF        | 38-0420-GHS44 | Water Fountain; Left side; bottom of B-Wing         | ND           | No        |
| 45S         | 38-0420-GHS45 | Boys restroom sink across from Rm B-19-1st one      | 2.17         | No        |
| 46S         | 38-0420-GHS46 | B-19 Restroom Sink                                  | ND           | No        |
| 47S         | 38-0420-GHS47 | Girls staff restroom sink across from the crossover | ND           | No        |
| 48S         | 38-0420-GHS48 | Boys staff restroom sink across from the crossover  | ND           | No        |
| 49WF        | 38-0420-GHS49 | Water Fountain; Top of B-Wing-right side            | ND           | No        |
| 50WF        | 38-0420-GHS50 | Water Fountain; Top of B-Wing-left side             | ND           | No        |
| 51S         | 38-0420-GHS51 | Main Foyer girls restroom sink-1st one              | ND           | No        |
| 52S         | 38-0420-GHS52 | Main Foyer boys restroom sink-1st one               | 4.42         | No        |
| 53WF        | 38-0420-GHS53 | A-Wing Water Fountain-Right                         | ND           | No        |
| 54WF        | 38-0420-GHS54 | A-Wing Water Fountain-Left                          | ND           | No        |
| 55S         | 38-0420-GHS55 | Main Office restroom sink across from A-8           | ND           | No        |
| 56S         | 38-0420-GHS56 | A-10 Restroom Sink                                  | ND           | No        |
| 57S         | 38-0420-GHS57 | A-12 Restroom Sink                                  | ND           | No        |
| 58S         | 38-0420-GHS58 | A-12 Sink   | 1.11         | No        |
| 59S         | 38-0420-GHS59 | A-7 Sink  | 1.17         | No        |
| 60S         | 38-0420-GHS60 | H-7 Media Ctr girls restroom Sink                   | ND           | No        |

Action Level (AL) ≥15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

**School Name: Gloucester City BOE - High School**

| Outlet Code | Sample ID     | Location/Description                                  | Result (ppb) | Above AL? |
|-------------|---------------|---|--------------|-----------|
| 61S         | 38-0420-GHS61 | H-7 Media Ctr boys restroom Sink                      | 1.17         | No        |
| 62S         | 38-0420-GHS62 | A-15 Station 1 sink; closest to front board           | 39           | Yes       |
| 63S         | 38-0420-GHS63 | A-17 Sink closest to board in front of classroom      | 3.22         | No        |
| 64S         | 38-0420-GHS64 | Prep Room Sink between A-17 & A-19                    | 1.52         | No        |
| 65S         | 38-0420-GHS65 | A-19 Student station sink closest to door; right side | 9.88         | No        |
| 66EW        | 38-0420-GHS66 | A-19 Eyewash Station                                  | 13.5         | No        |
| 67EW        | 38-0420-GHS67 | A-17 Eyewash Station                                  | 41.7         | Yes       |
| 68EW        | 38-0420-GHS68 | A-15 Eyewash Station                                  | 14.8         | No        |
| 69WF        | 38-0420-GHS69 | Water Fountain next to A-19; left                     | ND           | No        |
| 70WF        | 38-0420-GHS70 | Water Fountain next to D-11; right                    | ND           | No        |
| 71S         | 38-0420-GHS71 | D-3 Sink; left side                                   | ND           | No        |
| 72S         | 38-0420-GHS72 | D-7B; middle sink near D-3 Side                       | ND           | No        |
| 73S         | 38-0420-GHS73 | D-7A; Middle sink near D-7B side                      | ND           | No        |
| 74S         | 38-0420-GHS74 | Boys restroom sink next o control room; 1st one       | 1.83         | No        |
| 75S         | 38-0420-GHS75 | Girls restroom sink next o control room; 1st one      | 1.01         | No        |
| 76S         | 38-0420-GHS76 | D-8; teachers station sink                            | 12.9         | No        |
| 77E         | 38-0420-GHS77 | D-8; eyewash station                                  | 3.51         | No        |
| 78S         | 38-0420-GHS78 | Maintenance Rom; restroom sink                        | 2.67         | No        |
| 79S         | 38-0420-GHS79 | D-12; teachers station sink                           | 2.78         | No        |
| 80EW        | 38-0420-GHS80 | D-12; Eyewash station                                 | 14.2         | No        |

Action Level (AL) ≥15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - High School

| Outlet Code | Sample ID     | Location/Description                      | Result (ppb) | Above AL? |
|-------------|---------------|---|--------------|-----------|
| 81I         | 38-0420-GHS81 | D-14; Ice Machine                         | ND           | No        |
| 82S         | 38-0420-GHS82 | Girls restroom sink across from cafeteria | ND           | No        |
| 83S         | 38-0420-GHS83 | Boys restroom sink across from cafeteria  | ND           | No        |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |
|             |               |   |              |           |

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)