

BCS Heating and Cooling Set Points

BCS heating and cooling standards:

Heating			Cooling		
<u>Mode</u>	<u>Set Point</u>	<u>Range</u>	<u>Mode</u>	<u>Set Point</u>	<u>Range</u>
Occupied	72° F	70°-73° F	Occupied	73° F	71°-74° F
Unoccupied	55° F	53°-57° F	Unoccupied	85° F (1)	

Note (1) – At the discretion of Executive Director of Auxiliary Services.

Schools with Energy Management control systems have the following set points:

JSS - 70° heating and 74° cooling

NES - 70° F heating and 73° F cooling

PSJ - 69° F heating and 72° F cooling

SSH - 70° F heating and 72° F cooling

SWS - 71° F heating and 74° F cooling

WHS - 73° F heating/cooling

*Note. Set points may vary by locations due to building envelope and humidity level control issues.