

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for December 2023

**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER****DISCHARGE MONITORING REPORT (DMR)**NAME: **MONTICAU SCH DIST**ADDRESS: **1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220**FACILITY: **MONTICAU JR SR HIGH SCHOOL**LOCATION: **1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220**STAGE: **Final Effluent**PA0091341
PERMIT NUMBER

001

OUTFALL NUMBER

Reporting Frequency: **Annually**DMR Effective From: **01/01/2023**DMR Effective To: **12/31/2023**Permit Expires: **01/31/2028**Permit Application Due: **08/04/2027**No Discharge: ☐

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
2023	01	01	2023	12	31

FROM

PARAMETER	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***	***	1.02	***	mg/L	1/year	Grab
	PERMIT REQUIREMENT	***	***	Monitor & Report Ann'l Avg	***	mg/L	1/year	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***	***	.11	***	mg/L	1/year	Grab
	PERMIT REQUIREMENT	***	***	Monitor & Report Ann'l Avg	***	mg/L	1/year	Grab
E. Coli (51040)	SAMPLE MEASUREMENT	***	***	<1.0	***	No./100 ml	1/year	Grab
	PERMIT REQUIREMENT	***	***	Monitor & Report MAX	***	No./100 ml	1/year	Grab
Facility Comments								

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

2 messages

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, Jan 24, 2024 at 10:29 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Annually
Report Type: DMR
Reporting Period: 01/01/2023-12/31/2023
Report Due Date: 01/28/2024

Submitted By: Jeffrey Campbell
Submission Id: 437033
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, Jan 24, 2024 at 10:34 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 12/01/2023-12/31/2023
Report Due Date: 01/28/2024

Submitted By: Jeffrey Campbell
Submission Id: 437037
Submission Status: Received

[Quoted text hidden]



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

001
 OUTFALL NUMBER

Reporting Frequency: Monthly

DMR Effective From: 12/01/2023

DMR Effective To: 12/31/2023

Permit Expires: 01/31/2028

Permit Application Due: 08/04/2027

No Discharge: ☐

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	12	01	2023	12	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING				QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.83		***		***		Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		4.0	Daily Min	***		***		Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.21		***		7.80		Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		6.0	Daily Min	***		9.0	Daily Max	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***		***		<5.0		2/month	Grab
	PERMIT REQUIREMENT	***		***		30.0	Avg Mo	60.0	IMAX	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		***		<.165		***		2/month	Grab
	PERMIT REQUIREMENT	***		***		Monitor & Report	Avg Mo	***		2/month	Grab
Ultraviolet light intensity (43607)	SAMPLE MEASUREMENT	***		***		5.39		***		Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		***		Monitor & Report	Avg Mo	***		Daily when Discharging	Grab
Flow (50050)	SAMPLE MEASUREMENT	.00532		***		***		***		1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report	MGD	***		***		***		1/week	Measured
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***		<1.0		<1.0		2/month	Grab
	PERMIT REQUIREMENT	***		***		2000	Geo Mean	10000	IMAX	2/month	Grab

**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

PARAMETER		QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD ₅) (80082)	SAMPLE MEASUREMENT	***		***		<2.00		2/month	Grab
	PERMIT REQUIREMENT	***		***		25.0 Avg Mo	50.0 MAX	2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

2 messages

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, Jan 24, 2024 at 10:29 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Annually
Report Type: DMR
Reporting Period: 01/01/2023-12/31/2023
Report Due Date: 01/28/2024

Submitted By: Jeffrey Campbell

Submission Id: 437033

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, Jan 24, 2024 at 10:34 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 12/01/2023-12/31/2023
Report Due Date: 01/28/2024

Submitted By: Jeffrey Campbell

Submission Id: 437037

Submission Status: Received

[Quoted text hidden]

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: December 2023

Flow	8,314,128 8,297,614 > 16,514 TOTAL ÷ 31 DAYS : 532.71 Daily Avg		
UV Light	113.2 ÷ 21 : 5.39 Daily Avg		
		Basin #	Date
PH Low	7.21	# 1	12/19/23
PH High	7.80	# 1	12/12/23
D. O. Low	7.83	# 1	12/14/23
D. O. High	9.02	# 2	12/8/23

Date:	12/7/23	12/21/23	SUB TOTAL	÷ 2	Report
Total Nitrogen	1.02	3.41	4.43	2.215	2.22
TSS	<5	<5	—	—	<5
TKN	<0.625	<0.615	<0.124	<0.620	<0.620
Nitrate/Nitrate	1.02	3.41	4.43	2.215	2.22
Phos	0.11	0.32	0.43	0.215	0.22
CBOD	<2.00	<2.00	—	—	<2.00
Fecal	<1	<1	—	—	<1
Ammonia	<0.165	<0.165	—	—	<0.165



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L0848
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23L0848-01	Waste Water	12/07/2023 10:00	12/7/23 14:45	
Annual Effluent	23L0848-02	Waste Water	12/07/2023 10:00	12/7/23 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/28/2023 12:53

Lab Sample ID#: 23L0848-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 12/07/2023 10:00
Receipt Date: 12/07/2023 14:45

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	1.02	mg/L			0.729	AW	12/19/23 09:04	12/19/23 09:04
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	12/13/23 20:52	12/13/23 20:52
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	12/19/23 09:04	12/19/23 09:04
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	MM	12/14/23 08:19	12/14/23 15:53
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.02	mg/L			0.104	AW	12/18/23 14:16	12/18/23 14:16
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	0.11	mg/L			0.10	JMS	12/26/23 10:34	12/27/23 18:26
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L			2.00	ATJ	12/08/23 10:15	12/13/23 07:27
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	12/07/23 15:04	12/08/23 11:50



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00362

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/28/2023 12:53

Lab Sample ID#: 23L0848-02
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Annual Effluent

Sample Date: 12/07/2023 10:00
Receipt Date: 12/07/2023 14:45

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Microbiology								
			Analytical Method: SM9223 B-16			Prep Method: No Prep - Micro		
E. Coli	<1	MPN/100 mL			1	JP	12/07/23 14:50	12/08/23 15:56

SAMPLE REQUEST & CHAIN OF CUSTODY

251.0848

71

FOR INTERNAL LABORATORY USE ONLY

[illegible]

SAMPLE RECEIPT AND REVIEW FORM

Page 5 of 5

Client: Monteem SD Wc  23L0848 (Ink)

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____ Date/Time Received: ____/____/____

Method of Delivery: Client Drop-Off ESL Courier Other: _____ Received on Ice? YES NO

Sample Receipt Temperature: _____ °C IR Gun ID: _____

Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: A400382 Samples Received on Ice? (YES) NO

Date/Time Received: 12/7/13 1445 Date Sampled: 12/7/13

Method of Delivery: FedEx UPS Client Drop off (ESL courier) Other: _____

Sample Receipt Temperature: 3.9 °C IR Gun ID: 3

Sample State of Collection: (PA) NY OH WV Other: _____ PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details

Completed (if different from above): _____

Sample Receipt Criteria	Signature	Date	Time
Chain of custody documents included with samples?	YES NO		
COC form is properly signed in relinquished/received sections?	YES NO		
Sample containers intact and sealed?	YES NO		
Number of containers received matches number indicated on COC?	YES NO		
Sample IDs on COC match IDs on bottles?	YES NO		
Date and time on COC match date and time on bottles?	YES NO		
Samples received within holding time?	YES NO		
Samples received at appropriate pH for analysis requested?	YES NO		
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO		
Adequate sample volume received?	YES NO		
VOA vial headspace < 6 mm?	YES NO N/A		
Other Comments:			

Comments/Qualifiers (Required for Non-Conforming Items)

Comments:

Comments:

Circle Applicable: Damaged Container Leaking Container
Custody Seal Broken Other: _____

Sample IDs and Containers Affected:

Sample IDs and Containers Affected:

Sample IDs and Containers Affected:

Sample IDs and Containers Affected:

Sample IDs and Containers Affected and Observed pH:

For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.

Analyses Affected:

Sample IDs and Containers Affected:

Deficiency Log Created: YES (NO)

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

04 January 2024

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L2317
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23L2317-01	Waste Water	12/21/2023 10:00	12/21/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

- X Continuing Calibration Blank was below the RPL, but above limitation of being 1/2 the RPL specified in the SOP.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Benfeyville Road
Van Voorhis, PA 16366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 01/04/2024 15:27

Lab Sample ID#: 231.2317-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 12/21/2023 10:00
Receipt Date: 12/21/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry								
			Analytical Method: *** DEFAULT SPECIFIC METHOD			Prep Method: [CALC]		
Total Nitrogen	3.41	mg/L			0.729	AW	01/03/24 12:45	01/03/24 12:45
General Chemistry								
			Analytical Method: ASTM D6919-17			Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	12/28/23 07:04	12/28/23 23:28
General Chemistry								
			Analytical Method: EPA 351.2 2.0			Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	01/03/24 09:08	01/03/24 09:08
General Chemistry								
			Analytical Method: SM 2540 D-15			Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	TLA	12/27/23 17:27	12/28/23 15:07
General Chemistry								
			Analytical Method: SM 4500-NO3 E-16 (discrete)			Prep Method: No Prep - WetChem		
Nitrate/Nitrite	3.41	mg/L	N		0.104	AW	01/03/24 12:45	01/03/24 12:45
General Chemistry								
			Analytical Method: SM 4500-P E-11			Prep Method: SM 4500 P B		
Phosphorus	0.32	mg/L			0.10	JMS	01/02/24 18:27	01/02/24 18:27
General Chemistry								
			Analytical Method: SM 5210 B-16			Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L			2.00	TW	12/22/23 11:49	12/27/23 07:54
Microbiology								
			Analytical Method: Colilert-18			Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 ml.			1	JP	12/21/23 14:13	12/22/23 10:38

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

FAX: (570) 321-1957
ATORY USE ONLY

NORTHWAY
950 Main St
Sharpsville
(724) 463-
FAX: (724) 465-4209



251.2317

FOR INTERNAL LABORATORY USE ONLY

FAX: (724) 465-4209

[illegible]



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montana SD</u>	W: <u>23L2317</u>	(here)
---------------------------	-------------------	--------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: <u> / / </u>
Method of Delivery: Client Drop-Off ESL Courier Other: <u> </u>	Received on Ice? YES NO
Sample Receipt Temperature: <u> </u> °C	IR Gun ID: <u> </u>
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>AR/00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>12/21/23</u> <u> </u>	Date Sampled: <u>12/21/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: <u> </u>	
Sample Receipt Temperature: <u>3.9</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: <u> </u>	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): / /

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO			Comments:
COC form is properly signed in relinquished/received sections?	YES NO			Comments:
Sample containers intact and sealed?	YES NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: <u> </u>
Number of containers received matches number indicated on COC?	YES NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO			Sample IDs and Containers Affected:
Samples received within holding time?	YES NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO			Analyses Affected:
VOA vial headspace < 6 mm?	YES NO N/A			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO₃+NO₂, Alkalinity, Total Phosphorus, and all Organics methods

GP.25.A r2 Sample Receipt Log

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for December 2023

MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	Fri	49.9	9.38								
2	SAT		8,297,614	1.08	1.09	7.1	0.02	0	1.08	Jeff C	7:00 AM
3	SUN										
4	Mon	49.7	8,297,614	1.08	1.10	7.1	0.02	0	1.08	Jeff C	7:00 AM
5	Tues	55.6	8,320,892	1.10	1.17	7.1	0.03	0	1.08	Jeff C	7:00 AM
6	Wed	54.0	8,322,975	1.10	1.19	7.1	0.03	0	1.06	Jeff C	7:00 AM
7	Thurs	54.0	8,327,388	1.02	1.10	7.1	0.02	0	1.02	Jeff C	2:00 PM
8	Fri	55.2	8,336,420	1.01	1.09	7.1	0.02	0	1.27	Jeff C	9:00 AM
9	SAT										
10	SUN										
11	Mon	55.0	8,332,781	1.00	1.09	7.1	0.02	0	1.22	Jeff C	10:30 AM
12	Tues	55.1	8,240,652	1.06	1.16	7.1	0.02	0	1.19	Jeff C	1:30 PM
13	Wed	55.0	8,365,721	1.05	1.15	7.1	0.02	0	1.12	Jeff C	1:30 PM
14	Thurs	53.0	8,365,721	1.04	1.12	7.1	0.02	0	1.12	Jeff C	7:00 AM
15	Fri	55.0	8,365,721	1.04	1.12	7.1	0.02	0	1.12	Seth C	7:30 PM
16	SAT										
17	SUN										
18	Mon	57.1	8,294,604	0.99	1.07	7.0	0.03	0	1.18	Jeff C	10:00 AM
19	Tues	54.0	8,305,262	0.98	1.05	7.0	0.02	0	1.16	Jeff C	7:00 AM
20	Wed	54.1	8,305,262	0.50	0.55	7.0	0.02	0	1.12	Jeff C	8:00 AM
21	Thurs	54.0	8,305,262	0.50	0.55	7.0	0.02	0	1.12	Jeff C	1:00 PM
22	Fri										
23	SAT	Holiday	Closed								
24	SUN										
25	Mon										
26	Tues	55.1	8,314,128	0.53	0.58	7.0	0.02	0	1.16	Jeff C	7:00 AM
27	Wed	56.0	8,314,128	0.53	0.58	7.0	0.02	0	1.16	Jeff C	8:00 AM
28	Thurs										
29	Fri										
30	SAT										
31	SUN										

- Sewage Samples

- Water Samples

11/30/23 Meter Reading
8,297,614



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L0859
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23L0859-01	Drinking Water	12/07/2023 12:40	12/7/23 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/13/2023 10:24

Lab Sample ID#: 23L0859-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 12/07/2023 12:40
Receipt Date: 12/07/2023 14:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11							
Chlorine, Free	1.10	mg/L		0.200	PS	12/07/23 12:40	12/07/23 12:40
Prep Method: No Prep - Field							
Microbiology							
Analytical Method: SM 9223 B-16							
Total Coliform	Absent	per 100 mL		1	JP	12/07/23 15:23	12/08/23 15:56
E. Coli	Absent	per 100 mL		1	JP	12/07/23 15:23	12/08/23 15:56
Prep Method: No Prep - Micro							

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
803 Philadelphia St
Philadelphia, PA 19101
(215) 463-1000
FAX: (215) 463-4209

SOUTHERN DIVISION
1276 Bantleyville Road
Van Vleet, PA 15366
(724) 258-1000
FAX: (724) 258-4376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-8003
FAX: (570) 321-1957

NORTHWEST DIVISION
850 Main Street
Shippensburg, PA 17150
(724) 463-1000
FAX: (724) 463-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

CIRCLE ONE:

704 KITCHEN MAIN SINK
802 ROOM 204 SINK

23L0859 ESL#

Sample Type

Grab

Matrix

of Bottles

Container Type
Preservative

Analysis Requested

Date

Time

DW

1

STERILE PLASTIC
NA THIO

TC/EC

Free Chlorine 1.10

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

23L0859

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Monticau Jr/Sr - Monthly

Sampled By: (Signature)

12/22/88 12:40

Date/Time

Relinquished By: (Signature)

12/23/88 14:55

Date/Time

Relinquished By: (Signature)

Date/Time

Relinquished By: (Signature)

Date/Time

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature 36.4/3

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

MONTICAU SCHOOL DISTRICT

1810 WEST SUNBURY ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

5100324

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.1	120723	802		120723	D	1240	32382	23L0859-01	BROWNKA_282
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1240	32382	23L0859-01	BROWNKA_301



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L1690
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23L1690-01	Drinking Water	12/14/2023 11:33	12/14/23 13:26	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/18/2023 14:37

Lab Sample ID#: 23L1690-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 12/14/2023 11:33
Receipt Date: 12/14/2023 13:26

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
	1.06	mg/L		0.200	PS	12/14/23 11:33	12/14/23 11:33

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

EADQUARTER
803 Philadelphia St.
Adams, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Shapsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 251616	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: 704	2	12/14/03	1135	DW	Field	Field	Free Chlorine 1.06 mg/L
ROTATION WK 1 - 704 Kitchen Sink WK 2 - 802 Room 204 Sink WK 3 - 803 Admin Sink WK 4 - 804 400 Hall RR Sink WK 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW). 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <i>[Signature]</i> Date/Time 12/14/03 1135 Relinquished By: (Signature) <i>[Signature]</i> Date/Time 12/14/03 1326				Company Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@monteau.org Billing Address: 5100324 PWSID:			
Relinquished By: (Signature) _____ Date/Time _____ Relinquished By: (Signature) _____ Date/Time _____ Correct Preservations: <i>[Signature]</i> Correct Containers: <i>[Signature]</i> Receipt Temperature: 7				Notes/Special Instructions:			

231.1690

Drinking Water Monteau Jr/Sr - Weekly

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.06	121423	704		121423	D	1133	32382	23L1690-01	BROWNKA_840
5100324	1013	FREE CHLORINE	301	1.1	120723	802		120723	D	1240	32382	23L0859-01	BROWNKA_282
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1240	32382	23L0859-01	BROWNKA_301



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

26 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L2323
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23L2323-01	Drinking Water	12/21/2023 11:05	12/21/23 14:11	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Reported: 12/26/2023 14:45

Sample Date: 12/21/2023 11:05
Receipt Date: 12/21/2023 14:11

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11						
Chlorine, Free	0.460	mg/L		0.200	PS	12/21/23 11:05	12/21/23 11:05
	Prep Method: No Prep - Field						

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

[illegible]

ROTATION

Wk 1 - 704 Kitchen Sink

WK 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

WK 4 - 804 400 Hall RR Sink

WK 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) 		Date/ Time 12/21/83 8:1105	
Relinquished By: (Signature)		Date/ Time 12/21/83 9:1305	
Relinquished By: (Signature)		Date/ Time	
Received By: (Signature) 		Date/ Time 12/21/83 1411 (3038)	
Contact Person:		Address:	
Phone Number:		Company/Name:	
Call Phone:		391 HOOKER ROAD	
Email Address: icampbell@montieau.org		WEST SUNBURY, PA 16061	
Billing Address:		JEFFREY CAMPBELL	
PWSID: 5100324		724-406-4426	

5100324: MONITEAU JR/SR HIGH SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.06	121423	704		121423	D	1133	32382	23L1690-01	BROWNKA_840
5100324	1013	FREE CHLORINE	301	1.1	120723	802		120723	D	1240	32382	23L0859-01	BROWNKA_282
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1240	32382	23L0859-01	BROWNKA_301
5100324	1013	FREE CHLORINE	301	0.46	122123	803		122123	D	1105	32382	23L2323-01	BROWNKA_1245



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-8002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L2787
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23L2787-01	Drinking Water	12/28/2023 10:46	12/28/23 13:29	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monroeville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/29/2023 15:37

Lab Sample ID#: 23L2787-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 12/28/2023 10:46
Receipt Date: 12/28/2023 13:29

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.950	mg/L		0.200	PS	12/28/23 10:46	12/28/23 10:46

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.06	121423	704		121423	D	1133	32382	23L1690-01	BROWNKA_840
5100324	1013	FREE CHLORINE	301	1.1	120723	802		120723	D	1240	32382	23L0859-01	BROWNKA_282
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1240	32382	23L0859-01	BROWNKA_301
5100324	1013	FREE CHLORINE	301	0.46	122123	803		122123	D	1105	32382	23L2323-01	BROWNKA_1245
5100324	1013	FREE CHLORINE	301	0.95	122823	804		122823	D	1046	32382	23L2787-01	BROWNKA_1620

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER 803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	☒	SOUTHERN DIVISION 1276 Bentleyville Road Van Vleet, PA 15386 (724) 268-TEST FAX: (724) 298-8376	☐	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1857	☐	NORTHWEST DIVISION 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209	☐
--	-------------------------------------	--	--------------------------	--	--------------------------	---	--------------------------

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SOIL</u>	23L2787	12/28/03	1646	DW	Field	Field	Free Chlorine <u>0.45</u> mg/L

ROTATION

WK 1 - 704 Kitchen Sink
 WK 2 - 802 Room 204 Sink
 WK 3 - 803 Admin Sink
 WK 4 - 804 400 Hall RR Sink
 WK 5 - 804 400 Hall RR Sink


THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Monteau Jr/Sr - Weekly

23L2787



Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>12/28/03 1646</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>12/28/03 1834</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>[Signature]</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>[Signature]</u> Correct Preservations <u>Y/N/NA</u> Correct Containers <u>Y/N/NA</u> Receipt Temperature <u>6.9#4</u>	Company/Name: MONTTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: 724-406-4426 Email Address: jcambell@monteau.org Billing Address: 5100324 PWSID:
--	--

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for December 2023

Dassa McKinney Elementary School Water Treatment Facility										
Month	Dec.	2023								
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Fri	8.7	0.02	0.80	0.87	2.96	14527500	Jeff R	3:30P	2700
2	Sat									
3	Sun									
4	Mon	8.7	0.03	0.74	0.82	2.28	14531400	Jeff R	3:30P	3900
5	Tues	8.7	0.01	0.77	0.86	2.37	14535100	Jeff R	3:30P	3700
6	Wed	8.7	0.02	0.65	0.72	2.55	14538700	Jeff R	3:30P	3600
7	Thurs	8.7	0.03	0.80	0.91	2.53	14542500	Jeff R	3:30P	3800
8	Fri	8.7	0.04	0.79	0.88	2.64	14546100	Jeff R	3:30P	3600
9	Sat									
10	Sun									
11	Mon	8.7	0.00	0.71	0.81	2.81	14549800	Jeff R	3:30P	3700
12	Tues	8.7	0.01	0.74	0.82	3.04	14553900	Jeff R	3:30P	4100
13	Wed	8.7	0.02	0.72	0.80	3.16	14557600	Jeff R	3:30P	3700
14	Thurs	8.7	0.02	0.70	0.78	2.45	14562000	Jeff R	3:30P	4400
15	Fri	8.7	0.01	0.69	0.78	2.53	14565500	Jeff R	3:30P	3500
16	Sat									
17	Sun									
18	Mon	8.7	0.02	0.69	0.77	2.62	14569500	Jeff R	3:30P	4000
19	Tues	8.7	0.00	0.72	0.84	2.41	14573300	Jeff R	3:30P	3800
20	Wed	8.7	0.00	0.80	0.92	2.55	14577200	Jeff R	3:30P	3900
21	Thurs	8.7	0.04	0.73	0.84	3.28	14580700	Jeff R	3:30P	3500
22	Fri									
23	Sat									
24	Sun									
25	Mon									
26	Tues									
27	Wed									
28	Thurs									
29	Fri									
30	Sat						14581700			
31	Sun									

Meter Reading 11/30/23 - 14524800



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 83-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L0860
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23L0860-01	Drinking Water	12/07/2023 12:20	12/7/23 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/13/2023 10:24

Lab Sample ID#: 23L0860-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 12/07/2023 12:20
Receipt Date: 12/07/2023 14:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.830	mg/L		0.200	PS	12/07/23 12:20	12/07/23 12:20
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	JP	12/07/23 15:23	12/08/23 15:56
E. Coli	Absent	per 100 mL		1	JP	12/07/23 15:23	12/08/23 15:56

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
433 Broad Street
Montboursville, PA 17754
(570) 321-9003
FAX: (570) 321-1967

NORTHWEST DIVISION
960 Main Street
Shippensburg, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2310860	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
801 KITCHEN-SINK 802 ROOM 617 SINK	01	12/23	12:23	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.83 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec



2310860

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) Date/ Time Relinquished By: (Signature) Date/ Time Relinquished By: (Signature) Date/ Time Correct Preservations Y/N / N/A Correct Containers Y/N / N/A Receipt Temperature 3.50 C #3	Company/Name: Address: Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID:
12/21 8:10:00 12/23 0 14:55 12/23 14:45 12/11/23 14:45 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcambell@monteau.org 5100316	MONTEAU SCHOOL DISTRICT

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	120723	802		120723	D	1220	32382	23L0860-01	BROWNKA_283
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1220	32382	23L0860-01	BROWNKA_300



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L1691
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23L1691-01	Drinking Water	12/14/2023 11:12	12/14/23 13:26	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/18/2023 14:36

Lab Sample ID#: 23L1691-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 12/14/2023 11:12
Receipt Date: 12/14/2023 13:26

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.760	mg/L		0.200	PS	12/14/23 11:12	12/14/23 11:12

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

 HEADQUARTER
803 Philadelphia St.
Sharon, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

 SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15365
(724) 258-TEST
FAX: (724) 258-8376

 NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

 NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 25461	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 801	801	12/14/85	1112	DW	Field	Field	Free Chlorine 0.76 mg/L 18 12/14/85 6.76

ROTATION

 WK 1 - 801 Kitchen Sink
 WK 2 - 802 Room 617 Sink
 WK 3 - 803 Room 606 Sink
 WK 4 - 804 Room 408 Sink
 WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (15% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly



231691

Sampled By: (Signature) <i>[Signature]</i>	Date/ Time 12/14/85 1112	Company/Name: MONTTEAU SCHOOL DISTRICT
Relinquished By: (Signature) <i>[Signature]</i>	Date/ Time 12/14/85 1112	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID:
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)
Correct Preservations Y/N/NA	Correct Containers Y/N/NA	Receipt Temperature 2.1 #3

ilc



E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.76	121423	801		121423	D	1112	32382	23L1691-01	BROWNKA_839
5100316	1013	FREE CHLORINE	301	0.83	120723	802		120723	D	1220	32382	23L0860-01	BROWNKA_283
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1220	32382	23L0860-01	BROWNKA_300



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

26 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L2325
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23L2325-01	Drinking Water	12/21/2023 10:33	12/21/23 14:09	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04890

850 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/26/2023 14:45

Lab Sample ID#: 23L2325-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 12/21/2023 10:33
Receipt Date: 12/21/2023 14:09

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.650	mg/L		0.200	PS	12/21/23 10:33	12/21/23 10:33

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

SAMPLE REQUEST & CHAIN OF CUSTODY

1031

EASTQUARTER		SOUTHERN DIVISION		NORTHERN DIVISION		NORTHWEST DIVISION	
903 Philadelphia St. Adana, PA 15701	☒	1276 Bentleyville Road Van Voorhis, PA 15065	☐	435 Broad Street Montoursville, PA 17754	☐	950 Main Street Sharpsburg, PA 16	☐
(724) 463-TEST		(724) 256-TEST		(570) 321-8003		(724) 463-TEST	
FAX: (724) 466-4209		FAX: (724) 256-8376		FAX: (570) 321-1957		FAX: (724) 466-4209	

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2362325	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: 803	01	12/19/83	1633	DW	Field	Field	Free Chlorine 0.65 mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

23L2325

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (1% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW);

Sampled By: (Signature) 		Date/ Time 12-21-83 8 1633	Company/Name: Address: Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PW/SID:	MONITEAU SCHOOL DISTRICT	
Relinquished By: (Signature)	Date/ Time 12-21-83 8 1985	(00312)		391 HOOKER ROAD	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature) 		WEST SUNBURY, PA 16061	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)		JEFFREY CAMPBELL	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Phone Number:	724-406-4426	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Cell Phone:		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Email Address:	jcampbell@moniteau.org	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Billing Address:		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	PW/SID:	5100316	
Correct Preservations Y/N/NA	Correct Containers Y/N/NA	Receipt Temperature			



E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.76	121423	801		121423	D	1112	32382	23L1691-01	BROWNKA_839
5100316	1013	FREE CHLORINE	301	0.83	120723	802		120723	D	1220	32382	23L0860-01	BROWNKA_283
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1220	32382	23L0860-01	BROWNKA_300
5100316	1013	FREE CHLORINE	301	0.65	122123	803		122123	D	1033	32382	23L2325-01	BROWNKA_1244



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 December 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23L2790
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23L2790-01	Drinking Water	12/28/2023 10:13	12/28/23 13:39	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Monteale School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/29/2023 15:36

Lab Sample ID#: 23L2790-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 12/28/2023 10:13
Receipt Date: 12/28/2023 13:39

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.400	mg/L		0.200	PS	12/28/23 10:13	12/28/23 10:13

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.76	121423	801		121423	D	1112	32382	23L1691-01	BROWNKA_839
5100316	1013	FREE CHLORINE	301	0.83	120723	802		120723	D	1220	32382	23L0860-01	BROWNKA_283
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120823	802		120723	D	1220	32382	23L0860-01	BROWNKA_300
5100316	1013	FREE CHLORINE	301	0.65	122123	803		122123	D	1033	32382	23L2325-01	BROWNKA_1244
5100316	1013	FREE CHLORINE	301	0.4	122823	804		122823	D	1013	32382	23L2790-01	BROWNKA_1619

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER 803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 463-4209	☒	SOUTHERN DIVISION 1276 Benlleyville Road Van Vorth, PA 15386 (724) 256-TEST FAX: (724) 256-3376	☐	NORTHERN DIVISION 435 Broad Street Monroeville, PA 17754 (570) 321-9003 FAX: (570) 321-1857	☐	NORTHWEST DIVISION 930 Main Street Sharpsville, PA 161 (724) 463-TEST FAX: (724) 463-4209	☐
--	-------------------------------------	--	--------------------------	--	--------------------------	--	--------------------------

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: 804	2312790		12/28/13	DW	Field	Field	Free Chlorine 0.40 mg/L

ROTATION

WK 1 - 801 Kitchen Sink
 WK 2 - 802 Room 617 Sink
 WK 3 - 803 Room 606 Sink
 WK 4 - 804 Room 408 Sink
 WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Drinking Water Dassa McKinney - Weekly

Notes/Special Instructions:.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) <i>[Signature]</i> Date/ Time 12/28/13 1013 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 12/28/13 1201 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time Relinquished By: (Signature) <i>[Signature]</i> Date/ Time Relinquished By: (Signature) <i>[Signature]</i> Date/ Time Correct Preservations <i>[Signature]</i> Y/N/NA Correct Containers <i>[Signature]</i> Y/N/NA Receipt Temperature 6.2#4	Company/Name: MONTICAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: 724-406-4426 Cell Phone: jcampbell@monticau.org Email Address: 5100316 Billing Address:
--	---



2312790