

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for February 2023



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Thu, Mar 2, 2023 at 10:44 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 02/01/2023-02/28/2023
Report Due Date: 03/28/2023

Submitted By: Jeffrey Campbell
Submission Id: 382131
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST

ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

FACILITY: MONTEAU JR SR HIGH SCHOOL

LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

STAGE: Final Effluent

PA0091341	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly

DMR Effective From: 02/01/2023

DMR Effective To: 02/28/2023

Permit Expires: 01/31/2028

Permit Application Due: 08/04/2027

No Discharge: ☐

MONITORING PERIOD			
YEAR	MO	DAY	TO
2023	02	01	28

FROM

PARAMETER	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	UNITS	VALUE	VALUE	UNITS	VALUE		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	7.92	***	***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***	4.0	***	***	***	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	***	7.21	***	8.01	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***	6.0	***	9.0	S.U.	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	Daily Min	***	Daily Max	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	<5.0	***	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***	***	***	30.0	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	Avg Mo	MAX	2/month	Grab
Ultraviolet light intensity (43607)	SAMPLE MEASUREMENT	***	***	***	329	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	Monitor & Report	***	2/month	Grab
Flow (50050)	SAMPLE MEASUREMENT	***	***	***	Avg Mo	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***	***	***	5.46	***	Daily when Discharging	Grab
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***	***	Monitor & Report	***	1/week	Measured
	PERMIT REQUIREMENT	***	***	***	Avg Mo	***	1/week	Measured
	SAMPLE MEASUREMENT	***	***	***	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	<1.0	10000	2/month	Grab
	SAMPLE MEASUREMENT	***	***	***	Geo Mean	IMAX	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	<1.0	10000	2/month	Grab

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)		***	***		***	<2.00	<2.00	mg/L	2/month	Grab
		***	***		***	25.0	50.0	mg/L	2/month	Grab
Avg Mo										
IMAX										
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: FEB 2023

Flow	$86,969 \div 28$: <u>3,106</u> Daily Avg		
UV Light	$109.2 \div 20$: <u>5.46</u> Daily Avg		
		Basin #	Date
PH Low	7.21	1	2/9/23
PH High	8.01	1	2/11/23
D. O. Low	7.92	1	2/8/23
D. O. High	11.35	2	2/20/23

Date:	2/2/23	2/16/23	TOTAL	$\div 2$	Avg TOTAL
Total Nitrogen	1.33	11.8	13.13	6.56	6.56
TSS	< 5	< 5	—	—	< 5
TKN	< 0.625	2.62	3.245	1.62	1.62
Nitrate/Nitrate	1.33	9.14	10.47	5.235	5.235
Phos	0.47	1.5	1.97	0.985	0.985
CBOD	< 2.00	< 2.00	—	—	< 2.00
Fecal	< 1	< 1	—	—	< 1
Ammonia	< 0.329	< 0.329	0.658	0.329	0.329



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B0232
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23B0232-01	Waste Water	02/02/2023 10:00	2/2/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/14/2023 09:59

Lab Sample ID#: 23B0232-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 02/02/2023 10:00
Receipt Date: 02/02/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry								
Analytical Method: *** DEFAULT SPECIFIC METHOD						Prep Method: [CALC]		
Total Nitrogen	1.33	mg/L			0.729	DAA	02/08/23 12:14	02/09/23 08:14
General Chemistry								
Analytical Method: ASTM6919-17						Prep Method: No Prep - WetChem		
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	02/08/23 03:21	02/08/23 03:21
General Chemistry								
Analytical Method: EPA 351.2 2.0						Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	DAA	02/08/23 06:35	02/09/23 08:14
General Chemistry								
Analytical Method: SM2540 D-15						Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	APC	02/08/23 09:40	02/08/23 12:00
General Chemistry								
Analytical Method: SM4500-NO3 E-16 (discrete)						Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.33	mg/L			0.104	AW	02/08/23 12:14	02/08/23 12:14
General Chemistry								
Analytical Method: SM4500-P E-11						Prep Method: No Prep - WetChem		
Phosphorus	0.47	mg/L			0.10	AW	02/07/23 14:40	02/07/23 14:40
General Chemistry								
Analytical Method: SM5210 B-16						Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L			2.00	ATJ	02/03/23 13:49	02/08/23 09:48
Microbiology								
Analytical Method: Colilert-18						Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	AMB	02/02/23 14:55	02/03/23 11:29

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Page 3 of 4

HEADQUARTERS 1803 Philadelphia St Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209		SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15386 (724) 258-TEST FAX: (724) 258-8376		NORTHERN DIV 435 Broad Street Montoursville, Pa (570) 321-8003 FAX: (570) 321-	 23B0232	NO. 10 9 
---	---	--	---	---	--	---

FOR INTERNAL LABORATORY USE ONLY

[illegible]



SAMPLE RECEIPT AND REVIEW FORM

Client: Monterey

Work Order:

23B0232

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>PA/100382</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>2/2 P3 1400</u>	Date Sampled: <u>2/2/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>4.3</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	☒ YES ☐ NO			Comments:
COC form is properly signed in relinquished/received sections?	☒ YES ☐ NO			Comments:
Sample containers intact and sealed?	☒ YES ☐ NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	☒ YES ☐ NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	☒ YES ☐ NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	☒ YES ☐ NO			Sample IDs and Containers Affected:
Samples received within holding time?	☒ YES ☐ NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	☒ YES ☐ NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	☒ YES ☐ NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	☒ YES ☐ NO			Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES ☒ NO			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES ☒ NO

Effective Date:

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B0232
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23B0232-01	Waste Water	02/02/2023 10:00	2/2/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/14/2023 09:59

Lab Sample ID#: 23B0232-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 02/02/2023 10:00
Receipt Date: 02/02/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry								
			Analytical Method: *** DEFAULT SPECIFIC METHOD			Prep Method: [CALC]		
Total Nitrogen	1.33	mg/L			0.729	DAA	02/08/23 12:14	02/09/23 08:14
General Chemistry								
			Analytical Method: ASTM6919-17			Prep Method: No Prep - WetChem		
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	02/08/23 03:21	02/08/23 03:21
General Chemistry								
			Analytical Method: EPA 351.2 2.0			Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	DAA	02/08/23 06:35	02/09/23 08:14
General Chemistry								
			Analytical Method: SM2540 D-15			Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	APC	02/08/23 09:40	02/08/23 12:00
General Chemistry								
			Analytical Method: SM4500-NO3 E-16 (discrete)			Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.33	mg/L			0.104	AW	02/08/23 12:14	02/08/23 12:14
General Chemistry								
			Analytical Method: SM4500-P E-11			Prep Method: No Prep - WetChem		
Phosphorus	0.47	mg/L			0.10	AW	02/07/23 14:40	02/07/23 14:40
General Chemistry								
			Analytical Method: SM5210 B-16			Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L			2.00	ATJ	02/03/23 13:49	02/08/23 09:48
Microbiology								
			Analytical Method: Colilert-18			Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	AMB	02/02/23 14:55	02/03/23 11:29



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montevu</u>	Work Order:
------------------------	-------------



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>PA 100382</u>	Samples Received on Ice? (YES) NO
Date/Time Received: <u>7/27/23 1400</u>	Date Sampled: <u>7/27/23</u>
Method of Delivery: FedEx UPS Client Drop off (ESL courier) Other: _____	
Sample Receipt Temperature: <u>4.3</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: (PA) NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES (NO)

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	(YES) NO			Comments:
COC form is properly signed in relinquished/received sections?	(YES) NO			Comments:
Sample containers intact and sealed?	(YES) NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	(YES) NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	(YES) NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	(YES) NO			Sample IDs and Containers Affected:
Samples received within holding time?	(YES) NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	(YES) NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	(YES) NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	(YES) NO			Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES (NO)			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES (NO)

Effective Date:

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

27 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1798
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23B1798-01	Waste Water	02/16/2023 10:30	2/16/23 15:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/27/2023 11:20

Lab Sample ID#: 23B1798-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 02/16/2023 10:30
Receipt Date: 02/16/2023 15:10

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	11.8	mg/L			1.14	DAA	02/22/23 06:40	02/22/23 16:15
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	02/23/23 04:18	02/23/23 04:18
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	2.62	mg/L			0.625	DAA	02/22/23 06:40	02/22/23 16:15
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	APC	02/23/23 10:38	02/23/23 16:09
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	9.14	mg/L			0.520	AW	02/21/23 13:10	02/21/23 13:10
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem		
Phosphorus	1.5	mg/L			0.50	AW	02/21/23 13:40	02/21/23 13:40
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G		2.00	EMH	02/17/23 14:39	02/22/23 15:21
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	AMB	02/16/23 16:36	02/17/23 12:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376



23B1798

FOR INTERNAL LAB.

NORTHWEST DIVISION
960 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



Sample Identification

ESL# 23B1798

Sample Type
Composite
Date event Time event Date Time

Matrix

of Containers

Container Type
Preservatives

Analysis Requested

Effluent Outfall 001

2

2/16/23 10:30 AM

WW

1

Poly 1000mL

COD, TSS

WW

1

Poly 1000mL

Total Nitrogen, Total Phosphorus

WW

1

Sterile Plastic 125mL

Fecal Coliform

WW

1

Poly 500mL

Ammonia

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 30 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)

2/16/23 10:30 AM

Received By: (Signature)

2-16-23 1300

Relinquished By: (Signature)

2-16-23 155

Received By: (Signature)

2-16-23 1510 0835

Relinquished By: (Signature)

2-16-23 155

Received By: (Signature)

2-16-23 1510 0835

Relinquished By: (Signature)

2-16-23 155

Received By: (Signature)

2-16-23 1510 0835

Correct Preservation Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature

Project Notes:

Wastewater

Company/Name:

MONTICAU SCHOOL DISTRICT

Contact Person:

JEFFREY CAMPBELL

Address:

1810 WEST SUNBURY ROAD

Phone / Cell:

724-406-4426

Email:

jcampbell@monticau.org



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monteau</u>	Work On
	
23B1798	

PART A: GENERAL INFORMATION - SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: ____/____/____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC/EC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION - INDIANA LABORATORY

Received by/Lab ID: <u>JW/00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>2/16/23 12:00</u>	Date Sampled: <u>2/16/23</u>
Method of Delivery: FedEx UPS Client Drop off	Other: <u>ESL courier</u>
Sample Receipt Temperature: <u>3.1</u> °C	IR Gun ID: <u>4</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details

Completed (if different from above): _____

Signature _____ Date ____/____/____ Time _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO	Comments: _____
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments: _____
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH: _____
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected: _____
VOA vials free of headspace (defined as < 5 mm bubble)?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Other Comments: _____		Deficiency Log Created: YES <u>NO</u>

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for February 2023



JEFFREY CAMPBELL <jcampbell@moniteau.org>

MONITORING/REPORTING(5100324) REQUIREMENTS

1 message

jblashaw@pa.gov <jblashaw@pa.gov>
To: JCAMPBELL@moniteau.org

Fri, Feb 17, 2023 at 5:16 AM

NOTICE

This is an automatically generated notice, PLEASE DO NOT REPLY DIRECTLY TO THIS EMAIL.
If you have any questions regarding these changes contact Justin Blashaw at jblashaw@pa.gov

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
SAFE DRINKING WATER PROGRAM
MONITORING/REPORTING REQUIREMENTS FOR NONTRANSIENT NONCOMM SYSTEMS
DEP DISTRICT - NORTH MEADVILLE**

***** PWSID = 5100324 SYSTEM NAME = MONITEAU JR/SR HIGH SCHOOL *****

***** INITIAL YEAR = 1993 POPL = 600 *****

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
TOTAL COLIFORM PRESENCE	3100	TCR	MONTHLY	EACH MONTH	DISTRIBUTION	1
LEAD/COPPER GROUP CONTAMINANT	5000	LCR	THREE YEARS	06/01/2025 THROUGH 09/30/2025	DISTRIBUTION	10
HALOACETIC ACIDS (FIVE)	2456	DDBP	ANNUAL	MAY10 IN THE 2ND QUARTER	DISTRIBUTION 704	1
TRICHALOMETHANES	2950	DDBP	ANNUAL	MAY10 IN THE 2ND QUARTER	DISTRIBUTION 704	1
ARSENIC (IOC)	1005	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
BARIUM (IOC)	1010	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CADMIUM (IOC)	1015	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CHROMIUM (IOC)	1020	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CYANIDE (FREE) (IOC)	1024	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
FLUORIDE (IOC)	1025	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
MERCURY (IOC)	1035	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
NICKEL (IOC)	1036	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
NITRATE	1040	NTRT	ANNUAL	DURING QUARTER WITH HIGHEST HISTORICAL RESULT	ENTRY POINT 101	1
NITRITE	1041	NTRT	ANNUAL	DURING QUARTER WITH HIGHEST	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
				HISTORICAL RESULT		
SELENIUM (IOC)	1045	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
ANTIMONY (IOC)	1074	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
BERYLLIUM (IOC)	1075	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
THALLIUM (IOC)	1085	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
ASBESTOS	1094	IOC	NINE YEARS	01/01/2029 THROUGH 12/31/2031	ENTRY POINT 101	1
ENDRIN (SOC)	2005	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
LINDANE (SOC)	2010	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
METHOXYCHLOR (SOC)	2015	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
TOXAPHENE (SOC)	2020	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DALAPON (SOC)	2031	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DIQUAT (SOC)	2032	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ENDOTHALL (SOC)	2033	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
GLYPHOSATE (SOC)	2034	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
DI (2-ETHYLHEXYL) ADIPATE (SOC)	2035	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
OXYMAL (VYDATE) (SOC)	2036	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
SIMAZINE (SOC)	2037	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DI (2-ETHYLHEXYL) PHTHALATE (S	2039	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
PICLORAM (SOC)	2040	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DINOSEB (SOC)	2041	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
HEXACHLOROCYCLOPENTADIENE(SOC)	2042	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
CARBOFURAN (SOC)	2046	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ATRAZINE (SOC)	2050	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ALACHLOR (SOC)	2051	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
2,3,7,8-TCDD (DIOXIN) (SOC)	2063	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
HEPTACHLOR (SOC)	2065	SOC	THREE YEARS	REQUIRED DURING SECOND	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
HEPTACHLOR EPOXIDE (SOC)	2067	SOC	THREE YEARS	QUARTER OF 2023 REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
2,4 - D (SOC)	2105	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
2,4,5 - TP SILVEX (SOC)	2110	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
HEXACHLOROBENZENE (SOC)	2274	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
BENZO(A)PYRENE (SOC)	2306	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
PENTACHLOROPHENOL (SOC)	2326	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
PCBS (SOC)	2383	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
1,2-DIBROMO,3-CHLOROPROP(SOC)	2931	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ETHYLENE DIBROMIDE (EDB) (SOC)	2946	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
CHLORDANE (SOC)	2959	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
VINYL CHLORIDE	2976	VOC	REQUIRED IF 2-CARBON COMPOUND DETECTED		ENTRY POINT 101	1
20 REGULATED VOCS	VOC1	VOC	ANNUAL (PREV.)	DURING QUARTER	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
			DET.)	WITH HIGHEST HISTORICAL RESULT		

*** For Schedule 4 Systems still collecting Stage 1 TTHM/HAA5 samples, at least 25 percent of TTHM/HAA5 samples must be maximum residence samples.**

*** The monitoring requirements listed above are subject to change based on routine monitoring results.**

*** Disclaimer: This information is provided as an assistance tool, it may not dictate all monitoring requirements for all systems and DOES NOT supersede DEP regulatory requirements.**

***Asbestos monitoring may be required in 2022. If you have not received a waiver from asbestos monitoring at both the entry point and in the distribution system contact your local office for more information.**

MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT											
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME		
1	Wed	44.6	9.75	7,537,590	0.68	0.74	7.0	0.00	0	1.47	Jeff C	9:00 AM	
2	Thurs	45.0	8.61	7,537,590	0.68	0.74	7.0	0.00	0	1.45	Jeff C	8:00 AM	
3	Fri	47.1	11.54	7,548,071	0.74	0.77	7.0	0.00	0	0.99	Jeff C	8:30 AM	
4	SAT												
5	SUN												
6	Mon	43.5	8.94	7,548,071	0.74	0.77	7.0	0.00	0	0.97	Jeff C	9:30 AM	
7	Tues	50.0	11.78	7,558,810	0.71	0.77	7.1	0.02	0	1.06	Jeff C	9:00 AM	
8	Wed	49.9	9.71	7,558,810	0.71	0.77	7.1	0.01	0	1.07	Jeff C	10:00 AM	
9	Thurs	51.1	8.11	7,558,810	0.71	0.77	7.1	0.01	0	1.06	Seth C	4:30 PM	
10	Fri	49.0	11.10	7,570,505	0.71	0.78	7.0	0.02	0	1.31	Seth C	4:30 PM	
11	SAT												
12	SUN												
13	Mon	49.1	8.95	7,570,505	0.71	0.78	7.0	0.02	0	1.33	Jeff C	10:00 AM	
14	Tues	54.2	10.73	7,580,510	0.72	0.77	7.0	0.00	0	1.12	Jeff C	3:00 PM	
15	Wed	53.6	10.05	7,580,510	0.72	0.78	7.0	0.00	0	1.11	Jeff C	8:00 AM	
16	Thurs	55.2	8.69	7,580,510	0.73	0.79	7.0	0.00	0	1.09	Jeff C	9:00 AM	
17	Fri	58.3	0.90	7,591,441	0.77	0.84	7.0	0.02	0	0.86	Jeff C	10:00 AM	
18	SAT												
19	SUN												
20	Mon	52.0	8.81	7,591,441	0.77	0.84	7.0	0.01	0	0.87	Jeff C	10:00 AM	
21	Tues	55.0	11.35	7,601,719	0.83	0.90	7.0	0.00	0	0.90	Jeff C	2:00 PM	
22	Wed	52.3	10.00	7,601,719	0.82	0.89	7.0	0.00	0	0.90	Jeff C	1:30 PM	
23	Thurs	52.7	8.65	7,601,719	0.83	0.89	7.0	0.00	0	0.90	Jeff C	8:00 AM	
24	Fri	50.0	10.70	7,614,424	0.79	0.83	7.2	0.02	0	1.05	Jeff C	5:00 AM	
25	SAT												
26	SUN												
27	Mon	50.2	8.72	7,614,424	0.78	0.83	7.2	0.02	0	1.05	Jeff C	10:00 AM	
28	Tues	54.2	11.45	7,624,559	0.79	0.83	7.0	0.00	0	1.17	Jeff C	10:00 AM	
29													
30													
31													

Merice Reading 1/31/23

7,537,590

Sewage Testing

Water Testing



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B0340
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23B0340-01	Drinking Water	02/02/2023 11:35	2/2/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 11:08

Lab Sample ID#: 23B0340-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler:
Client Sample ID: 802 Room 204 Sink

Sample Date: 02/02/2023 11:35
Receipt Date: 02/02/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.750	mg/L		0.200	PS	02/02/23 11:35	02/02/23 11:35
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13
E. Coli	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376



23B0340

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	23B0340 01	Grab	Time	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.75

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS D.L.O.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Monthly

Notes/Special Instructions:

Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>2-2-23 1135</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>2-2-23 1340</u>		Received By: (Signature) <u>[Signature]</u> Date/ Time <u>2/2/23 1345</u>	
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____	
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____	
Correct Preservations <u>Y/N/NA</u>		Receipt Temperature <u>2.8#3</u>	
Company/Name: MONITEAU SCHOOL DISTRICT Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.org Billing Address: 5100324 PWSID:			



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	23B1122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	23B0340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1135	32382	23B0340-01	BROWNKA_233



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B0340
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23B0340-01	Drinking Water	02/02/2023 11:35	2/2/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 11:08

Lab Sample ID#: 23B0340-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler:
Client Sample ID: 802 Room 204 Sink

Sample Date: 02/02/2023 11:35
Receipt Date: 02/02/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.750	mg/L		0.200	PS	02/02/23 11:35	02/02/23 11:35
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13
E. Coli	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER

1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION

1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8378



23B0340

NORTHWEST DIVISION

950 Main Street
Sharpville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	23B0340			DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.75

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (14% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Monthly

Notes/Special Instructions:

Sampled By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time

Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time

Company Name:	MONITEAU SCHOOL DISTRICT
Address:	1810 WEST SUNBURY ROAD
Contact Person:	WEST SUNBURY, PA 16061
Phone Number:	JEFFREY CAMPBELL
Call Phone:	724-406-4426
Email Address:	jcampbell@moniteau.org
Billing Address:	
PWID:	5100324

Correct Preservations	Y/N / NA	Correct Containers	Y/N / NA	Receipt Temperature	0.8 #3
-----------------------	----------	--------------------	----------	---------------------	--------

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	2381122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	2380340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1135	32382	2380340-01	BROWNKA_233



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1122
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704	23B1122-01	Drinking Water	02/09/2023 11:13	2/9/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monloursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 14:10

Lab Sample ID#: 23B1122-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704

Sample Date: 02/09/2023 11:13
Receipt Date: 02/09/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.640	mg/L		0.200	PS	02/09/23 11:13	02/09/23 11:13


ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

QUEST DIVISION



FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification		ESL# 23B1122		Sample Type Grab		Matrix		# of Bottles		Container Type Preservative		Analysis Requested	
Distribution: 704		01		Date: 2/23/03 Time: 11:13		DW		Field		Field		Free Chlorine 0.64 mg/L	
ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink													
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.													
Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly													
Sampled By: (Signature) Relinquished By: (Signature) Relinquished By: (Signature) Relinquished By: (Signature)				Received By: (Signature) Received By: (Signature) Received By: (Signature)				Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: 724-406-4426 jcampbell@moniteau.org Phone Number: 5100324 Cell Phone: Email Address: Billing Address: PWSID:					
Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature													

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	23B1122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	23B0340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1135	32382	23B0340-01	BROWNKA_233



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1122
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704	23B1122-01	Drinking Water	02/09/2023 11:13	2/9/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 14:10

Lab Sample ID#: 23B1122-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704


Sample Date: 02/09/2023 11:13
Receipt Date: 02/09/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	PS	02/09/23 11:13	02/09/23 11:13


ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorth, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



WEST DIVISION
23B1122

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 204	23B1122	Date	Time			Preservative	
	01	2923	1113	DW	Field	Field	Free Chlorine 0.64 mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Weekly

Notes/Special Instructions:

Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Correct Preservations Y/N (NA)	Correct Containers Y/N (NA)	Receipt Temperature	

Company/Name: MONITEAU SCHOOL DISTRICT

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcampbell@moniteau.org

5100324

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	23B1122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	23B0340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1135	32382	23B0340-01	BROWNKA_233



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1803
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23B1803-01	Drinking Water	02/16/2023 13:00	2/16/23 15:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15365
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/20/2023 13:23

Lab Sample ID#: 23B1803-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Shawn Semsick
Client Sample ID: 803 Admin Sink

Sample Date: 02/16/2023 13:00
Receipt Date: 02/16/2023 15:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.790	mg/L		0.200	SES	02/16/23 13:00	02/16/23 13:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 of 4

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Berkeyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8076

NORTH
435 B.
Montic
(570)
FAX:



23B1803

VISION
209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23B1803	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date/Time				
Distribution: B03	a	2-16-23	1300	DW	Field	Field	Free Chlorine 0.29 mg/L
ROTATION							
Wk 1 - 704 Kitchen Sink							
Wk 2 - 802 Room 204 Sink							
Wk 3 - 803 Admin Sink							
Wk 4 - 804 400 Hall RR Sink							
Wk 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (11% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)							
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.							
Plum Sink 2-16-23 1300 Sample By: (Signature) Date/Time Relinquished By: (Signature) 2-16-23 1500 Relinquished By: (Signature) Date/Time Relinquished By: (Signature) Date/Time Relinquished By: (Signature) Date/Time Relinquished By: (Signature) Date/Time Relinquished By: (Signature) Date/Time Correct Preservations Y/N (NA) Correct Containers Y/N (NA) Receipt Temperature --							
Notes/Special Instructions: Drinking Water Monticau Jr/Sr - Weekly Company Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: 724-406-4426 Cell Phone: jcampbell@monticau.org Billing Address: 5100324 PWSID:							

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	23B1122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	23B0340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1135	32382	23B0340-01	BROWNKA_233
5100324	1013	FREE CHLORINE	301	0.79	021623	803		021623	D	1300	32382	23B1803-01	BROWNKA_740



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1803
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23B1803-01	Drinking Water	02/16/2023 13:00	2/16/23 15:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-8002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/20/2023 13:23

Lab Sample ID#: 23B1803-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Shawn Semsick
Client Sample ID: 803 Admin Sink

Sample Date: 02/16/2023 13:00
Receipt Date: 02/16/2023 15:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.790	mg/L		0.200	SES	02/16/23 13:00	02/16/23 13:00

Page 1 of 1

209

FOR INTERNAL LABORATORY USE ONLY

Analysis Requested

online 79 mail

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

2. THE UNDERBONDED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Sampled By (Signature)	Date/Time
<i>Theresa Hunt</i>	2-16-23 1300

Requisitioned By: (Signature) [Signature] Date/Time 2-16-23 7:10

Relinquished By: (Signature) _____
 Date/Time _____

Requisitioned By: (Signature)	Date/Time
Relinquished By: (Signature)	Date/Time

Correct Preservations	Y / N / NA	Correct Containers	Y

Company/Name: MONTEAU SCHOOL DISTRICT

Address:
391 HOOKER ROAD

Contact Person: JEFFREY CAMPBELL

Cell Phone: 724-406-4426

PWS/D: 510032A

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	23B1122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	23B0340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1135	32382	23B0340-01	BROWNKA_233
5100324	1013	FREE CHLORINE	301	0.79	021623	803		021623	D	1300	32382	23B1803-01	BROWNKA_740



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B2433
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804	23B2433-01	Drinking Water	02/23/2023 09:46	2/23/23 13:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1967
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/24/2023 09:44

Lab Sample ID#: 23B2433-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804

Sample Date: 02/23/2023 09:46
Receipt Date: 02/23/2023 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.760	mg/L		0.200	PS	02/23/23 09:46	02/23/23 09:46

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	020923	704		020923	D	1113	32382	23B1122-01	BROWNKA_234
5100324	1013	FREE CHLORINE	301	0.75	020223	802		020223	D	1135	32382	23B0340-01	BROWNKA_232
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020323	D	1135	32382	23B0340-01	BROWNKA_233
5100324	1013	FREE CHLORINE	301	0.79	021623	803		021623	D	1300	32382	23B1803-01	BROWNKA_740
5100324	1013	FREE CHLORINE	301	0.76	022323	804		022323	D	0946	32382	23B2433-01	BROWNKA_1509

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 4 of 4

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 463-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Bird Street
Morkousville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL# 23B2433

Distribution: 804

Sample Type
Grab Date Time

Matrix

of Bottles

Container Type
Preservative

Analysis Requested

Free Chlorine 0.76 mg/L

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Monteau Jr/Sr - Weekly

Sampled By: (Signature)

2.23.23

Date/Time

946

Relinquished By: (Signature)

2.23.23

Date/Time

Received By: (Signature)

Date/Time

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

MONTICAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcambell@monticau.org

5100324

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for February 2023

Dassa McKinney Elementary School Water Treatment Facility

Month	Feb	2023										
Date	Day	PH	Iron	C12 Free	C12 Total	Hardness	Meter Reading	Operator	Time	Notes		
1	Wed	8.7	0.02	0.61	0.68	2.88	13923900	JEFF R	4:30P	3800		
2	Thurs	8.7	0.02	0.63	0.72	2.92	13927900	JEFF R	4:30P	4000		
3	Fri	8.7	0.00	0.68	0.76	3.14	13931900	JEFF R	4:30P	4000		
4	Sat											
5	Sun											
6	Mon	8.7	0.00	0.71	0.79	3.25	13936000	JEFF R	4:30P	4100		
7	Tues	8.7	0.01	0.66	0.77	2.07	13940200	JEFF R	4:30P	4200		
8	Wed	8.7	0.02	0.71	0.79	2.18	13944100	JEFF R	4:30P	3900		
9	Thurs											
10	Fri											
11	Sat											
12	Sun											
13	Mon	8.7	0.00	0.53	0.61	2.98	13952300	JEFF R	4:00P	8200		
14	Tues	8.7	0.01	0.62	0.71	3.11	13956300	JEFF R	4:30P	4000		
15	Wed	8.7	0.02	0.59	0.68	3.17	13959600	JEFF R	3:00P	3300		
16	Thurs	8.7	0.00	0.72	0.80	2.75	13963800	JEFF R	3:30P	4200		
17	Fri	8.7	0.00	0.81	0.91	2.35	13967600	JEFF R	3:30P	3800		
18	Sat											
19	Sun											
20	Mon	8.7	0.00	0.90	1.00	2.35	13970000	JEFF R	4:00P			
21	Tues	8.7	0.00	0.90	1.00	2.37	13973000	JEFF R	11:00A			
22	Wed	8.7	0.02	0.92	1.01	2.17	13979400	JEFF R	3:30P	11800		
23	Thurs	8.7	0.00	0.96	1.08	2.24	13983600	JEFF R	4:30P	4200		
24	Fri	8.7	0.00	0.91	1.00	2.28	13987200	JEFF R	3:30P	3600		
25	Sat											
26	Sun											
27	Mon	8.7	0.00	0.61	0.66	2.91	13991400	JEFF R	4:30P	4200		
28	Tues	8.7	0.01	0.60	0.68	2.76	13995800	JEFF R	4:30P	4400		
29												
30												
31												

Meter Reading 1/31/23 - 13920100



JEFFREY CAMPBELL <jcampbell@moniteau.org>

MONITORING/REPORTING(5100316) REQUIREMENTS

1 message

jblashaw@pa.gov <jblashaw@pa.gov>

Fri, Feb 17, 2023 at 5:16 AM

To: JCAMPBELL@moniteau.org, JROSELLINI@moniteau.org

NOTICE

This is an automatically generated notice, PLEASE DO NOT REPLY DIRECTLY TO THIS EMAIL.

If you have any questions regarding these changes contact Justin Blashaw at jblashaw@pa.gov

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
SAFE DRINKING WATER PROGRAM
MONITORING/REPORTING REQUIREMENTS FOR NONTRANSIENT NONCOMM SYSTEMS
DEP DISTRICT - NORTH MEADVILLE**

***** PWSID = 5100316 SYSTEM NAME = DASSA MCKINNEY ELEM SCHOOL *****

***** INITIAL YEAR = 1993 POPL = 650 *****

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
TOTAL CHLORINE	1000	DDBP	MONTHLY, IF USED	EACH MONTH	DISTRIBUTION	1
FREE CHLORINE	1013	DDBP	MONTHLY, IF USED	EACH MONTH	DISTRIBUTION	1
TOTAL COLIFORM PRESENCE	3100	TCR	MONTHLY	EACH MONTH	DISTRIBUTION	1
LEAD/COPPER GROUP CONTAMINANT	5000	LCR	THREE YEARS	06/01/2025 THROUGH 09/30/2025	DISTRIBUTION	10
HALOACETIC ACIDS (FIVE)	2456	DDBP	ANNUAL	AUGUST 10 IN THE 3RD QUARTER	DISTRIBUTION 703	1
TRIHALOMETHANES	2950	DDBP	ANNUAL	AUGUST 10 IN THE 3RD QUARTER	DISTRIBUTION 703	1
ARSENIC (IOC)	1005	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
BARIUM (IOC)	1010	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CADMIUM (IOC)	1015	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CHROMIUM (IOC)	1020	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CYANIDE (FREE) (IOC)	1024	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
FLUORIDE (IOC)	1025	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
MERCURY (IOC)	1035	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
NICKEL (IOC)	1036	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
NITRATE	1040	NTRT	ANNUAL	DURING QUARTER WITH HIGHEST	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring/Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
				HISTORICAL RESULT		
NITRITE	1041	NTRT	ANNUAL	DURING QUARTER WITH HIGHEST HISTORICAL RESULT	ENTRY POINT 101	1
SELENIUM (IOC)	1045	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
ANTIMONY (IOC)	1074	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
BERYLLIUM (IOC)	1075	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
THALLIUM (IOC)	1085	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
ASBESTOS	1094	IOC	NINE YEARS	01/01/2029 THROUGH 12/31/2031	ENTRY POINT 101	1
ENDRIN (SOC)	2005	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
LINDANE (SOC)	2010	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
METHOXYCHLOR (SOC)	2015	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
TOXAPHENE (SOC)	2020	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DALAPON (SOC)	2031	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DIQUAT (SOC)	2032	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ENDOTHALL (SOC)	2033	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1



JEFFREY CAMPBELL <jcampbell@moniteau.org>

MONITORING/REPORTING(5100316) REQUIREMENTS

1 message

jblashaw@pa.gov <jblashaw@pa.gov>

Fri, Feb 17, 2023 at 5:16 AM

To: JCAMPBELL@moniteau.org, JROSELLINI@moniteau.org

NOTICE

This is an automatically generated notice, PLEASE DO NOT REPLY DIRECTLY TO THIS EMAIL.

If you have any questions regarding these changes contact Justin Blashaw at jblashaw@pa.gov

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
SAFE DRINKING WATER PROGRAM
MONITORING/REPORTING REQUIREMENTS FOR NONTRANSIENT NONCOMM SYSTEMS
DEP DISTRICT - NORTH MEADVILLE**

***** PWSID = 5100316 SYSTEM NAME = DASSA MCKINNEY ELEM SCHOOL *****

***** INITIAL YEAR = 1993 POPL = 650 *****

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
TOTAL CHLORINE	1000	DDBP	MONTHLY, IF USED	EACH MONTH	DISTRIBUTION	1
FREE CHLORINE	1013	DDBP	MONTHLY, IF USED	EACH MONTH	DISTRIBUTION	1
TOTAL COLIFORM PRESENCE	3100	TCR	MONTHLY	EACH MONTH	DISTRIBUTION	1
LEAD/COPPER GROUP CONTAMINANT	5000	LCR	THREE YEARS	06/01/2025 THROUGH 09/30/2025	DISTRIBUTION	10
HALOACETIC ACIDS (FIVE)	2456	DDBP	ANNUAL	AUGUST 10 IN THE 3RD QUARTER	DISTRIBUTION 703	1
TRIHALOMETHANES	2950	DDBP	ANNUAL	AUGUST 10 IN THE 3RD QUARTER	DISTRIBUTION 703	1
ARSENIC (IOC)	1005	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
BARIUM (IOC)	1010	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CADMIUM (IOC)	1015	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CHROMIUM (IOC)	1020	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
CYANIDE (FREE) (IOC)	1024	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
FLUORIDE (IOC)	1025	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
MERCURY (IOC)	1035	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
NICKEL (IOC)	1036	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
NITRATE	1040	NTRT	ANNUAL	DURING QUARTER WITH HIGHEST	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring/Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
				HISTORICAL RESULT		
NITRITE	1041	NTRT	ANNUAL	DURING QUARTER WITH HIGHEST HISTORICAL RESULT	ENTRY POINT 101	1
SELENIUM (IOC)	1045	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
ANTIMONY (IOC)	1074	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
BERYLLIUM (IOC)	1075	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
THALLIUM (IOC)	1085	IOC	THREE YEARS	01/01/2024 THROUGH 12/31/2024	ENTRY POINT 101	1
ASBESTOS	1094	IOC	NINE YEARS	01/01/2029 THROUGH 12/31/2031	ENTRY POINT 101	1
ENDRIN (SOC)	2005	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
LINDANE (SOC)	2010	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
METHOXYCHLOR (SOC)	2015	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
TOXAPHENE (SOC)	2020	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DALAPON (SOC)	2031	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DIQUAT (SOC)	2032	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ENDOTHALL (SOC)	2033	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
GLYPHOSATE (SOC)	2034	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DI (2-ETHYLHEXYL) ADIPATE (SOC)	2035	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
OXYMAL (VYDATE) (SOC)	2036	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
SIMAZINE (SOC)	2037	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DI (2-ETHYLHEXYL) PHTHALATE (S	2039	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
PICLORAM (SOC)	2040	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
DINOSEB (SOC)	2041	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
HEXACHLOROCYCLOPENTADIENE(SOC)	2042	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
CARBOFURAN (SOC)	2046	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ATRAZINE (SOC)	2050	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ALACHLOR (SOC)	2051	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
2,3,7,8-TCDD (DIOXIN) (SOC)	2063	SOC	THREE YEARS	REQUIRED DURING SECOND	ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
HEPTACHLOR (SOC)	2065	SOC	THREE YEARS	QUARTER OF 2023 REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
HEPTACHLOR EPOXIDE (SOC)	2067	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
2,4 - D (SOC)	2105	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
2,4,5 - TP SILVEX (SOC)	2110	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
HEXACHLOROBENZENE (SOC)	2274	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
BENZO(A)PYRENE (SOC)	2306	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
PENTACHLOROPHENOL (SOC)	2326	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
PCBS (SOC)	2383	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
1,2-DIBROMO,3-CHLOROPROP(SOC)	2931	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
ETHYLENE DIBROMIDE (EDB) (SOC)	2946	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
CHLORDANE (SOC)	2959	SOC	THREE YEARS	REQUIRED DURING SECOND QUARTER OF 2023	ENTRY POINT 101	1
VINYL CHLORIDE	2976	VOC	REQUIRED IF 2-		ENTRY POINT 101	1

Contaminant Name	Contaminant Code	Contaminant Group	Monitoring / Reporting Frequency	Current or Next Sampling Period	Sample Location	No. of Samples
			CARBON COMPOUND DETECTED			
20 REGULATED VOCS	VOC1	VOC	ANNUAL (PREV. DET.)	DURING QUARTER WITH HIGHEST HISTORICAL RESULT	ENTRY POINT 101	1

*** For Schedule 4 Systems still collecting Stage 1 TTHM/HAA5 samples, at least 25 percent of TTHM/HAA5 samples must be maximum residence samples.**

*** The monitoring requirements listed above are subject to change based on routine monitoring results.**

*** Disclaimer: This information is provided as an assistance tool, it may not dictate all monitoring requirements for all systems and DOES NOT supersede DEP regulatory requirements.**

*** Asbestos monitoring may be required in 2022. If you have not received a waiver from asbestos monitoring at both the entry point and in the distribution system contact your local office for more information.**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B0339
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23B0339-01	Drinking Water	02/02/2023 11:20	2/2/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Monroeville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 11:07

Lab Sample ID#: 23B0339-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 02/02/2023 11:20
Receipt Date: 02/02/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.20	mg/L		0.200	PS	02/02/23 11:20	02/02/23 11:20
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13
E. Coli	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

36 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bendleyville Rd
Van Voorhis, PA 1538
(724) 258-TEST
FAX: (724) 258-8376



23B0339



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
804 KITCHEN SINK 802 ROOM 617 SINK	23B0339		9/23	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 1.20 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.5% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) Date/Time 2-23 11:40 Relinquished By: (Signature) Date/Time 2-23 1:34		Company Name: MONTTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@montteau.org Billing Address: 5100316 PWSID:	
Relinquished By: (Signature) Date/Time Relinquished By: (Signature) Date/Time		Received By: (Signature) Date/Time Received By: (Signature) Date/Time	
Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature 2.8 #3			

Department of Environmental Protection

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.74	020923	801		020923	D	1057	32362	23B1121-01	BROWNKA_231
5100316	1013	FREE CHLORINE	301	1.2	020223	802		020223	D	1120	32382	23B0339-01	BROWNKA_229
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1120	32382	23B0339-01	BROWNKA_230



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B0339
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23B0339-01	Drinking Water	02/02/2023 11:20	2/2/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00362

1276 Benleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 11:07

Lab Sample ID#: 23B0339-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 02/02/2023 11:20
Receipt Date: 02/02/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.20	mg/L		0.200	PS	02/02/23 11:20	02/02/23 11:20
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13
E. Coli	Absent	per 100 mL		1	AMB	02/02/23 14:41	02/03/23 16:13

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E _1_ OF _1_

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 465-TEST
FAX: (724) 465-4209

SOUTHERN DIVISIO
1276 Bentleyville Rce
Van Voorhis, PA 1531
(724) 258-TEST
FAX: (724) 258-4376

23B0339

FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION
950 Main Street
Sharsville, PA 16
(724) 465-TEST
FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
804-KITCHEN SINK 802 ROOM 617 SINK	23B0339			DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 1.20 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Company/Name:

MONTTEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person:

Phone Number:

724-406-4426

Cell Phone:

jcampbell@montteau.org

Billing Address:

PWSID:

5100316

Sampled By: (Signature)

2023 11/10

Date/ Time

Relinquished By: (Signature)

2023 12/14

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature 2.8 #3



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.74	020923	801		020923	D	1057	32382	23B1121-01	BROWNKA_231
5100316	1013	FREE CHLORINE	301	1.2	020323	802		020223	D	1120	32382	23B0339-01	BROWNKA_229
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1120	32382	23B0339-01	BROWNKA_230



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1121
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801	23B1121-01	Drinking Water	02/09/2023 10:57	2/9/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 14:09

Lab Sample ID#: 23B1121-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801

Sample Date: 02/09/2023 10:57
Receipt Date: 02/09/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.740	mg/L		0.200	PS	02/09/23 10:57	02/09/23 10:57

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE PERMIT

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benlieville Road
Van Vornhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monrosville, PA 17754
(570) 321-8003
FAX: (570) 321-1957

(724) 463-TEST
FAX: (724) 465-4209

23B1121

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESI # 23B1121

Sample Type

Grab

Date

Time

Matrix

of Bottles

Container Type

Analysis Requested

Distribution: 301

01

2995

1057

DW

Field

Field

Free Chlorine 0.74 mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature)

Date/ Time

2995 1057

Company/Name:

Address:

391 HOOKER ROAD

Relinquished By: (Signature)

Date/ Time

2995 1335

Contact Person:

Phone Number:

JEFFREY CAMPBELL

Relinquished By: (Signature)

Date/ Time

2995 1335

Cell Phone:

724-406-4426

Relinquished By: (Signature)

Date/ Time

2995 1335

Email Address:

jcampbell@monteau.org

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature

PW/SID:

5100316

MONTTEAU SCHOOL DISTRICT

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcampbell@monteau.org

5100316



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PW/SID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.74	020923	801		020923	D	1057	32382	23B1121-01	BROWNIKA_231
5100316	1013	FREE CHLORINE	301	1.2	020223	802		020223	D	1120	32382	23B0339-01	BROWNIKA_229
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1120	32382	23B0339-01	BROWNIKA_230



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1121
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801	23B1121-01	Drinking Water	02/09/2023 10:57	2/9/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monitorsville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2023 14:09

Lab Sample ID#: 23B1121-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801

Sample Date: 02/09/2023 10:57
Receipt Date: 02/09/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.740	mg/L		0.200	PS	02/09/23 10:57	02/09/23 10:57

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE DECONTAMINATION



23B1121

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 483-TEST
FAX: (724) 485-4209

SOUTHERN DIVISION
1276 Bonleyville Road
Van Vleet, PA 15306
(724) 258-TEST
FAX: (724) 258-6376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17154
(570) 321-9003
FAX: (570) 321-1957

(724) 483-TEST
FAX: (724) 485-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: 201	23B1121	01	2005	DW	Field	Field	Free Chlorine 0.74 mg/L
ROTATION Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM ON THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <i>[Signature]</i> 2005 1057 Relinquished By: (Signature) <i>[Signature]</i> 2005 1057 Relinquished By: (Signature) _____ Date/Time _____ Relinquished By: (Signature) _____ Date/Time _____ Relinquished By: (Signature) _____ Date/Time _____ Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____				Notes/Special Instructions: <i>Drinking Water Dassa McKinney - Weekly</i>			
Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcambell@monteau.org 5100316				Contact Person: _____ Phone Number: _____ Cell Phone: _____ Email Address: _____ Billing Address: _____ PWSID: _____			

Department of Environmental Protection

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.74	020923	801		020923	D	1057	32382	23B1121-01	BROWNIKA_231
5100316	1013	FREE CHLORINE	301	1.2	020223	802		020223	D	1120	32382	23B0339-01	BROWNIKA_229
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1120	32382	23B0339-01	BROWNIKA_230



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Monroeville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1801
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23B1801-01	Drinking Water	02/16/2023 12:45	2/16/23 15:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/20/2023 13:24

Lab Sample ID#: 23B1801-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Shawn Semsick
Client Sample ID: 803 Room 606 Sink

Sample Date: 02/16/2023 12:45
Receipt Date: 02/16/2023 15:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.540	mg/L		0.200	SES	02/16/23 12:45	02/16/23 12:45

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8375



23B1801

FOR INTERNAL LABORATORY USE ONLY

FAX: (570) 321-1001

ORTHWEST DIVISION
50 Main Street
Harpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>B.03</u>	<u>23B1801</u>	Grab	DW	Field	Preservative	Free Chlorine <u>0.54</u> mg/L
		Date/Time				

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Weekly

Notes/Special Instructions:

Sampled By: (Signature) <u>[Signature]</u> Date/Time <u>2-16-23 1245</u> Relinquished By: (Signature) <u>[Signature]</u> Date/Time <u>2-16-23 1245</u>		Company Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA JEFFREY CAMP Contact Person: <u>[Signature]</u> Phone Number: <u>724-406-4427</u> Cell Phone: <u>[Signature]</u> Email Address: <u>[Signature]</u> Billing Address: <u>510031</u> PWSID: <u>510031</u>
Relinquished By: (Signature) _____ Date/Time _____ Relinquished By: (Signature) _____ Date/Time _____	Received By: (Signature) _____ Date/Time _____ Received By: (Signature) _____ Date/Time _____	Correct Preservations Y/N <u>NA</u> Correct Containers Y/N <u>NA</u> Receipt Temperature _____

Department of Environmental Protection

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.74	020923	801		020923	D	1057	32382	23B1121-01	BROWNKA_231
5100316	1013	FREE CHLORINE	301	1.2	020223	802		020223	D	1120	32382	23B0339-01	BROWNKA_229
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1120	32382	23B0339-01	BROWNKA_230
5100316	1013	FREE CHLORINE	301	0.54	021623	803		021623	D	1245	32382	23B1801-01	BROWNKA_739



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 February 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23B1801
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23B1801-01	Drinking Water	02/16/2023 12:45	2/16/23 15:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/20/2023 13:24

Lab Sample ID#: 23B1801-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Shawn Semsick
Client Sample ID: 803 Room 606 Sink

Sample Date: 02/16/2023 12:45
Receipt Date: 02/16/2023 15:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.540	mg/L		0.200	SES	02/16/23 12:45	02/16/23 12:45

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208



23B1801

SOUTHERN DIVISION
1276 Bertleyville Road
Van Vochter, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

ORTHWEST DIVISION
50 Main Street
Harpersville, PA 16
(724) 463-TEST
FAX: (724) 465-4208

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 8.03	23B1801	Grab	DW	Field	Field	Free Chlorine 0.54 mg/L
		Date				
		Time				
		2-16-23	1245			

ROTATION

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: Shawn Dunsen Date/Time: 2-16-23 1245
Relinquished By: Shawn Dunsen Date/Time: 2-16-23 1245

Relinquished By: (Signature) _____ Date/Time: _____
Relinquished By: (Signature) _____ Date/Time: _____

Correct Preservations Y/N (NA) Correct Containers Y/N (NA) Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA
JEFFREY CAMP
Contact Person: 724-406-4427
Phone Number: jcampbell
Cell Phone: 724-406-4427
Email Address: jcampbell
Billing Address: 510031
PWSID:

Department of Environmental Protection

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PW/SID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.74	020923	801		020923	D	1057	32382	23B1121-01	BROWNKA_231
5100316	1013	FREE CHLORINE	301	1.2	020223	802		020223	D	1120	32382	23B0339-01	BROWNKA_229
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020323	802		020223	D	1120	32382	23B0339-01	BROWNKA_230
5100316	1013	FREE CHLORINE	301	0.54	021623	803		021623	D	1245	32382	23B1801-01	BROWNKA_739