

Portland, OR Microbiology/Chemistry (c)

Corvallis, OR Microbiology/Chemistry (d)

Bend, OR Microbiology (e)

Page 1 of 1

## **LEAD & COPPER RULE REPORT**

Client Name:

Corbett School District

35800 E. Historic Columbia River Hwy

Corbett, OR 97019

System Name:

System ID Number:

DWP Source Number:

Multiple Sources:

Sample Type:

Sample Purpose: Investigative or Other

County:

Reference Number: 21-40795

Project: Corbett HS Gym

Concession Sink - Retest

Analyst: bj

Date Received: 10/26/2021

Report Date: 11/2/2021

Approved By: anp

Authorized by:

Thanh B Phan Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA#	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
21_78574	10/21/2021	21860105-008SF21C - HS Front Gym Concession Sink	1030	LEAD	2.4	ppb	15	1	200.8	4072	
											**
			-								
		*									
				æ							
		s *.									
		-									

## NOTES:

ND (Not Detected); indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

RL (Reporting Level): Indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.