



Keystone Laboratories - Kansas City  
CERTIFICATE OF ANALYSIS  
3GL0078

Osage County R-1 School District

Project Name: MO Schools

Lyle Best  
614 S. Poplar  
Chamois, MO 65024

Project / PO Number: / Mo Schools Lead Testing  
Received: 12/08/2023  
Reported: 01/12/2024

Analytical Testing Parameters

Client Sample ID: SW Sink  
Sample Matrix: Drink Wtr  
Lab Sample ID: 3GL0078-01

Collection Date: 12/05/2023 6:57

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.5	0.4	ppb	2		01/10/24 1130	01/11/24 0528	RVV

Client Sample ID: NE Sink  
Sample Matrix: Drink Wtr  
Lab Sample ID: 3GL0078-02

Collection Date: 12/05/2023 6:59

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.7	0.4	ppb	2		01/10/24 1130	01/11/24 0533	RVV

Client Sample ID: SE Sink  
Sample Matrix: Drink Wtr  
Lab Sample ID: 3GL0078-03

Collection Date: 12/05/2023 7:01

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.6	0.4	ppb	2		01/10/24 1130	01/11/24 0537	RVV

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Sue Thompson  
Client Services Manager  
01/12/24 10:12



LABORATORIES  
A Microbac Company

600 East 17th Street South  
Newton, IA 50208  
641-782-8451

Page 1 of  
Printed: 11/20/2023 4:00:46P

www.keystoneilabs.com

Page 2 of 2

### SITE INFORMATION

Sampler:

Project:

Mo Schools Lead Testing

Mo Schools Lead Testing

### REPORT TO

Lyle Best  
Osage County R-1 School District  
614 S. Poplar  
Chamois, MO 65024

### INVOICE TO

Lyle Best  
Osage County R-1 School District  
614 S. Poplar  
Chamois, MO 65024

### SPECIAL INSTRUCTIONS

None

Turn Around Time

☐ Standard ☐ RUSH, need by \_\_\_/\_\_\_/\_\_\_

### LAB USE ONLY

Work Order

Temperature

Turn-Cooler:

35100078  
23.3  
No

Custody Seal

Containers Intact

COCLabels Agree

Preservation Confirmed

Received on Ice NA

Number Sample Identification / Client ID

Matrix

Sample Type

Date

Time

Number of Containers

Analyses

Lab Sample Number

-001	SW Snt	Drink Wtr	GRAB	12/15/23	6:57 AM	1	pb-1-200.8	01
-002	NE Snt	Drink Wtr	GRAB	12/15/23	6:59 AM	1	pb-1-200.8	02
-003	SE Snt	Drink Wtr	GRAB	12/15/23	7:04 AM	1	pb-1-200.8	03

Relinquished By

Relinquished By

Date/Time

Remarks:

Received By

Received for Lab By

Date/Time

Original - Lab Copy Yellow - Sampler Copy



3 6 L 0 0 7 8

Osage County R-1 School District  
PM: Carolyn Jackson