



Keystone Laboratories - Kansas City

CERTIFICATE OF ANALYSIS

3GI0054

Osage County R-1 School District

Project Name: Mo Schools Lead Testing

Lyle Best
614 S. Poplar
Chamois, MO 65024

Project / PO Number: / Mo Schools Lead Testing
Received: 09/15/2023
Reported: 09/27/2023

Analytical Testing Parameters

Client Sample ID: Hall Fountain
Sample Matrix: Drink Wtr
Lab Sample ID: 3GI0054-01

Collected By: Unknown
Collection Date: 09/11/2023 6:50

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		09/26/23 1145	09/26/23 1837	RVV

Client Sample ID: Shop Fountain
Sample Matrix: Drink Wtr
Lab Sample ID: 3GI0054-02

Collected By: Unknown
Collection Date: 09/11/2023 6:55

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		09/26/23 1145	09/26/23 1843	RVV

Client Sample ID: SW Sink
Sample Matrix: Drink Wtr
Lab Sample ID: 3GI0054-03

Collected By: Unknown
Collection Date: 09/11/2023 7:00

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	18.2	0.4	ppb	2		09/26/23 1145	09/26/23 1848	RVV

Client Sample ID: NE Sink
Sample Matrix: Drink Wtr
Lab Sample ID: 3GI0054-04

Collected By: Unknown
Collection Date: 09/11/2023 7:03

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	17.2	0.4	ppb	2		09/26/23 1145	09/26/23 1853	RVV

Keystone Laboratories - Kansas City

CERTIFICATE OF ANALYSIS

3GI0054

Client Sample ID: SE Sink
Sample Matrix: Drink Wtr
Lab Sample ID: 3GI0054-05

Collected By: Unknown
Collection Date: 09/11/2023 7:05

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	5.3	0.4	ppb	2		09/26/23 1145	09/26/23 1859	RVV

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:



Sue Thompson
Client Services Manager
09/27/23 17:56



SITE INFORMATION

Sampler:

Project: Mo Schools Lead Testing
PWSID# Mo Schools Lead Testing

SPECIAL INSTRUCTIONS

None

Turn Around Time

☐ Standard ☐ RUSH, need by ____/____/____

REPORT TO

Lyle Best
Osage County R-1 School District
614 S. Poplar
Chambers, MO 65024

INVOICE TO

Lyle Best
Osage County R-1 School District
614 S. Poplar
Chambers, MO 65024

LAB USE ONLY

Work Order

Temperature 24.2

Turn-Cooler:

☐ Custody Seal
☐ Containers Intact
☐ COC/Labels Agree
☐ Preservation Confirmed
☐ Received on Ice

Number	Sample Identification / Client ID	Matrix	Sample Type	Date	Time	Number of Containers	Analyses	Lab Sample Number
01-001	1 Hall fountain	Drink Wtr	GRAB	09/11/23	6:50AM	1	pb-4-200.8	
01-002	1 Shop fountain	Drink Wtr	GRAB	09/11/23	6:55AM	1	pb-4-200.8	
01-003	1 SW Sink	Drink Wtr	GRAB	09/11/23	7:00AM	1	pb-4-200.8	
01-004	1 NE Sink	Drink Wtr	GRAB	09/11/23	7:03AM	1	pb-4-200.8	
01-005	1 SE Sink	Drink Wtr	GRAB	09/11/23	7:05AM	1	pb-4-200.8	
01-006	1	Drink Wtr	GRAB	/ /			pb-4-200.8	
01-007	1	Drink Wtr	GRAB	/ /			pb-4-200.8	

Relinquished By _____ Date/Time _____

Received By _____ Date/Time _____

Relinquished By _____ Date/Time _____
Received for Lab By Kyle Clayton 9-15-23 8:25
Original - Lab Copy Yellow - Sampler Copy

Remarks: Water Bacteria Sample Types
RT Routine RP-UP Repeat Up
SP Special RP-DN Repeat Down
NC New Line Ext (ONLY) RP-OR Repeat Original
RL Replacement RP-OT Repeat Other