

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for July 2023

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST

ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220

FACILITY: MONTEAU JR SR HIGH SCHOOL

LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220

STAGE: Final Effluent

PA0091341	
PERMIT NUMBER	

001	
OUTFALL NUMBER	

Reporting Frequency: Monthly

DMR Effective From: 07/01/2023

DMR Effective To: 07/31/2023

Permit Expires: 01/31/2028

Permit Application Due: 08/04/2027

No Discharge: ☐

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	07	01	2023	07	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.42	***	***	***	mg/L	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		4.0	***	***	***	mg/L	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.07	***	***	8.00	S.U.	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		6.0	***	***	9.0	S.U.	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	***	***	5.0	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	30.0	60.0	mg/L	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		***	***	2.5	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	Avg Mo	MAX	mg/L	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	***	Monitor & Report	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	Avg Mo	***	mg/L	Daily when Discharging	Grab
Flow (50050)	SAMPLE MEASUREMENT	0.01256		***	***	Monitor & Report	5.01	µm/cm ²	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		***	***	Avg Mo	***	µm/cm ²	1/week	Measured
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	***	***	***	No./100 ml	1/week	Measured
	PERMIT REQUIREMENT	***		***	***	<1.0	1000	No./100 ml	2/month	Grab
		***		***	***	Geo Mean	MAX	No./100 ml	2/month	Grab

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING				QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	UNITS	VALUE	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD ₅) (80082)	SAMPLE MEASUREMENT	***	***			***	<2.00	<2.00		2/month	Grab
	PERMIT REQUIREMENT	***	***			***	25.0 Avg Mo	50.0 IMAX	mg/L	2/month	Grab
Facility Comments											

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Thu, Aug 17, 2023 at 7:40 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 07/01/2023-07/31/2023
Report Due Date: 08/28/2023

Submitted By: Jeffrey Campbell
Submission Id: 409728

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: July 2023

Flow	38,969 ÷ 31 : <u>1256.94</u> Daily Avg		
UV Light	90.2 ÷ 18 : <u>5.01</u> Daily Avg		
		Basin #	Date
PH Low	7.07	#1	7/10/23
PH High	8.00	#2	7/17/23
D. O. Low	7.42	#2	7/6/23
D. O. High	8.55	#2	7/17/23

Date:	7/6/23	7/20/23	Sub Total	Total	
Total Nitrogen	1.17	10.5	11.67	5.835	
TSS	< 5	5	5	2.5	
TKN	< 0.625	0.647	1.272	0.636	
Nitrate/Nitrate	1.17	9.90	11.07	5.535	
Phos	0.40	1.7	2.1	1.05	
CBOD	< 2.00	< 2.00		< 2.00	
Fecal	< 1.	< 1		< 1	
Ammonia	< 0.165	< 0.165		< 0.165	



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0520
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23G0520-01	Waste Water	07/06/2023 11:00	7/6/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/20/2023 12:22

Lab Sample ID#: 23G0520-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/06/2023 11:00
Receipt Date: 07/06/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	1.17	mg/L			0.729	AW	07/14/23 13:44	07/14/23 13:44
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	07/17/23 23:14	07/17/23 23:14
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	07/13/23 12:18	07/13/23 12:18
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	AH	07/10/23 14:36	07/11/23 13:55
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.17	mg/L			0.104	AW	07/14/23 13:44	07/14/23 13:44
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	0.40	mg/L			0.20	JMS	07/18/23 18:50	07/18/23 18:50
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS		2.00	TW	07/07/23 14:41	07/12/23 11:00
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	DAA	07/06/23 14:57	07/07/23 12:30

SAMPLE REQUEST & CHAIN OF CUSTODY

HEADQUARTERS 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	☒	SOUTHERN DIVISION 1276 Bentleyville Road Van Vleet, PA 15386 (724) 258-TEST FAX: (724) 258-8376	☐	NORTHERN 435 Broad S Montoursville (570) 321-9 FAX: (570) ...	NORTHWEST DIVISION 321 PA 16150 1ST 465-4208
--	--	--	--------------------------	--	---



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montevu</u>	Work Order: <u>23G0520</u>
------------------------	----------------------------



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JND/00382</u>	Samples Received on Ice? (YES) NO
Date/Time Received: <u>7/6/23 1530</u>	Date Sampled: <u>7/6/23</u>
Method of Delivery: FedEx UPS Client Drop off (ESL courier) Other: _____	
Sample Receipt Temperature: <u>3.7</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: (PA) NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES (NO)

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	(YES) NO	Comments:
COC form is properly signed in relinquished/received sections?	(YES) NO	Comments:
Sample containers intact and sealed?	(YES) NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	(YES) NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	(YES) NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	(YES) NO	Sample IDs and Containers Affected:
Samples received within holding time?	(YES) NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	(YES) NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	(YES) NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	(YES) NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES (NO)	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES (NO)

Effective Date:

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2509
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23G2509-01	Waste Water	07/20/2023 10:00	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

LL Laboratory control sample below acceptance criteria, result may be biased low.
G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/02/2023 15:22

Lab Sample ID#: 23G2509-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/20/2023 10:00
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	10.5	mg/L			1.66	AW	07/31/23 12:31	07/31/23 12:31
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/01/23 04:14	08/01/23 04:14
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	0.647	mg/L			0.625	AW	07/31/23 12:31	07/31/23 12:31
General Chemistry	Analytical Method: SM 2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	5	mg/L	LL		5	AH	07/25/23 13:04	07/25/23 13:04
General Chemistry	Analytical Method: SM 4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	9.90	mg/L			1.04	AW	07/28/23 14:45	07/28/23 14:45
General Chemistry	Analytical Method: SM 4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	1.7	mg/L			1.0	JMS	08/01/23 13:20	08/01/23 13:20
General Chemistry	Analytical Method: SM 5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G		2.00	TW	07/21/23 17:00	07/26/23 13:04
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	07/20/23 14:39	07/21/23 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-9376


NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type			Matrix	# of Containers	Container Type Preservative	Analysis Requested
		Composite Date on/ot	Grab Date	Time Time				
Effluent Outfall 001	7502509	7/20/23	7/20/23	10:00 AM	WW	1	Poly 1000mL None	CBOD, TSS
		7/20/23	7/20/23	10:00 AM	WW	1	Poly 500mL H2SO4	Ammonia, Total Nitrogen, Total Phosphorus
		7/20/23	7/20/23	10:00 AM	WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform
		7/20/23	7/20/23	10:00 AM				
 23G2509								
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.								
Wastewater Company/Name: MONITEAU SCHOOL DISTRICT Contact Person: JEFFREY CAMPBELL Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 Phone / Cell: 724-406-4426 Email: jcambell@moniteau.org								
Signature: <i>[Signature]</i> Date/ Time: 7/20/23 10:00 AM Signature: <i>[Signature]</i> Date/ Time: 7/20/23 11:50 Signature: <i>[Signature]</i> Date/ Time: 7/20/23 11:50 Signature: <i>[Signature]</i> Date/ Time: 7/20/23 11:50								
Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature								



SAMPLE RECEIPT AND REVIEW FORM

Client: Monterey



23G2509

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other:	Received on Ice? YES NO
Sample Receipt Temperature: °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JD / 05382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>7/20/23 1400</u>	Date Sampled: <u>7/20/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other:	
Sample Receipt Temperature: <u>3.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other:	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria		Signature	Date	Time
Chain of custody documents included with samples?	<u>YES</u> NO	Comments/Qualifiers (Required for Non-Conforming Items)		
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments:		
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other:		
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected:		
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:		
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:		
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected:		
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH:		
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.		
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected:		
VOA vial headspace < 6 mm?	YES NO <u>N/A</u>	Sample IDs and Containers Affected:		
Other Comments:		Deficiency Log-Created: YES <u>NO</u>		

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.

GP.25.A r2 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2509
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23G2509-01	Waste Water	07/20/2023 10:00	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

LL	Laboratory control sample below acceptance criteria, result may be biased low.
G	CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
RL	Reporting Limit
CFU	Colony Forming Units
MDL	Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/02/2023 15:22

Lab Sample ID#: 23G2509-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/20/2023 10:00
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	10.5	mg/L			1.66	AW	07/31/23 12:31	07/31/23 12:31
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/01/23 04:14	08/01/23 04:14
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	0.647	mg/L			0.625	AW	07/31/23 12:31	07/31/23 12:31
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	5	mg/L	LL		5	AH	07/25/23 13:04	07/25/23 13:04
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	9.90	mg/L			1.04	AW	07/28/23 14:45	07/28/23 14:45
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	1.7	mg/L			1.0	JMS	08/01/23 13:20	08/01/23 13:20
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G		2.00	TW	07/21/23 17:00	07/26/23 13:04
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	07/20/23 14:39	07/21/23 11:20

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST

FAX: (724) 465-4709

FAX: (724) 258-8375

FAX: (570) 321-1957

FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

[illegible]

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH OR THE MAXIMUM ALLOWED BY LAW.

3. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY

ATTORNEY FOR COLLECTION REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

7/20/20 10:00 AM

Sampled By: (Signature) _____ Date/Time _____

110

5/21/11 5:12 PM

Relinquished By: (Signature) _____ Date/ Time _____

2000

15031

Relinquished By (Signature) _____ Date/ Time _____

9

[illegible]

Relinquished By: (Signature)

Date/ Time

[illegible]

Correct Preservations	Y / N / NA	Correct
-----------------------	------------	---------



SAMPLE RECEIPT AND REVIEW FORM

Client: Minitec



23G2509

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other:	Received on Ice? YES NO
Sample Receipt Temperature: °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>50 / 00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>7/20/23 1400</u>	Date Sampled: <u>7/20/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other:	
Sample Receipt Temperature: <u>3.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other:	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO			Comments:
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO			Comments:
Sample containers intact and sealed?	<u>YES</u> NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other:
Number of containers received matches number indicated on COC?	<u>YES</u> NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>YES</u> NO			Sample IDs and Containers Affected:
Samples received within holding time?	<u>YES</u> NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO			Analyses Affected:
VOA vial headspace < 6 mm?	<u>YES</u> NO <u>N/A</u>			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log-Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO₃+NO₂, Alkalinity, Total Phosphorus, and all Organics methods.

GP.25.A r2 Sample Receipt Log

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for July 2023

MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1 SAT											
2 SUN											
3 Mon	Closed		Holiday								
4 Tues	Closed		Holiday								
5 WED	72.0	11.34	8,164,391	0.67	0.74	7.1	0.02	0	0.99	Jeff C	6:00 PM
6 Thurs	73.6	10.97	8,164,391	0.67	0.75	7.1	0.02	0	0.99	Jeff C	10:00 AM
7 Fri	74.5	9.99	8,164,391	0.67	0.74	7.1	0.02	0	0.99	Jeff C	1:00 PM
8 SAT											
9 SUN											
10 Mon	76.4	9.42	8,164,391	0.67	0.72	7.1	0.01	0	0.98	Jeff C	1:00 PM
11 Tues	77.9	8.97	8,164,391	0.67	0.72	7.1	0.01	0	0.98	Jeff C	2:00 PM
12 Wed	80.0	8.37	8,164,391	0.67	0.72	7.1	0.01	0	0.98	Jeff C	3:00 PM
13 Thurs	70.0	11.80	8,175,942	0.75	0.78	7.2	0.03	0	1.20	Jeff C	11:00 AM
14 Fri	Closed										
15 SAT											
16 SUN											
17 Mon	77.5	9.54	8,175,942	0.75	0.79	7.2	0.02	0	1.19	Jeff C	2:00 PM
18 Tues	77.9	9.03	8,175,942	0.75	0.78	7.2	0.02	0	1.20	Jeff C	2:00 PM
19 Wed	69.3	11.74	8,191,769	0.63	0.66	7.2	0.03	0	2.29	Jeff C	2:00 PM
20 Thurs	70.2	11.09	8,191,769	0.62	0.66	7.2	0.03	0	2.29	Jeff C	9:30 AM
21 Fri	Closed										
22 SAT											
23 SUN											
24 Mon	75.1	9.23	8,191,769	0.62	0.66	7.2	0.02	0	2.25	Jeff C	2:00 AM
25 Tues	77.3	8.16	8,191,769	0.61	0.66	7.2	0.03	0	2.25	Jeff C	2:00 AM
26 Wed	77.9	8.05	8,191,769	0.61	0.65	7.2	0.03	0	2.21	Jeff C	7:00 AM
27 Thurs	69.5	11.52	8,203,356	0.55	0.58	7.3	0.03	0	1.31	Jeff C	2:00 PM
28 Fri	Closed										
29 SAT											
30 SUN											
31 Mon	78.0	8.53	8,203,356	0.53	0.55	7.3	0.03	0	1.26	Jeff C	3:00 PM

 = Sewage Samples
  = Water Samples



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0641
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23G0641-01	Drinking Water	07/06/2023 11:15	7/6/23 14:32	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/12/2023 08:43

Lab Sample ID#: 23G0641-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 07/06/2023 11:15
Receipt Date: 07/06/2023 14:32

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.910	mg/L		0.200	PS	07/06/23 11:15	07/06/23 11:15
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00
E. Coli	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTH
435 Bro
Montau
(570) 31
FAX: (570) 311-1111



23G0641

ION
30
30

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23G0641	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
CIRGETE ONE: 704 KITCHEN MAIN SINK 802-ROOM 204 SINK	SN	7/03	11:15	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.91

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Monteau Jr/Sr - Monthly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name:

MONTTEAU SCHOOL DISTRICT

Address:

1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Contact Person:

JEFFREY CAMPBELL

Phone Number:

Cell Phone:

724-406-4426

Email Address:

jcambell@montiteau.org

Billing Address:

PWSID:

5100324

Sampled By: (Signature)

Date/ Time

7/03 09:15

Relinquished By: (Signature)

Date/ Time

7/03 02:13

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations (Y) N / NA

Correct Containers (Y) N / NA

Receipt Temperature 3.6 #3

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 237



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0516
Project: Drinking Water Moniteau Jr/Sr - Annual
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101	23G0516-01	Drinking Water	07/06/2023 11:20	7/6/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/11/2023 15:43

Lab Sample ID#: 23G0516-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: Entry Point 101

Sample Date: 07/06/2023 11:20
Receipt Date: 07/06/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry		Analytical Method: EPA300.0 2.1			Prep Method: No Prep - WetChem		
Nitrate	<0.100	mg/L		0.100	TLL	07/07/23 02:12	07/07/23 02:12
Nitrite	<0.100	mg/L		0.100	TLL	07/07/23 02:12	07/07/23 02:12

3E 1 OF 1

23G0516

5100324



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work On:  23G0516
-------------------------	---

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JND / 00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>7/6/23 1330</u>	Date Sampled: <u>7/6/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>4.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: <u>YES</u> NO

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments:
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES <u>NO</u>	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES <u>NO</u>

Effective Date:

GP.25.A-1 Sample Receipt Log

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 237



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G1717
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23G1717-01	Drinking Water	07/13/2023 12:12	7/13/23 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/18/2023 17:05

Lab Sample ID#: 23G1717-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 07/13/2023 12:12
Receipt Date: 07/13/2023 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-II				Prep Method: No Prep - Field			
Chlorine, Free	0.920	mg/L		0.200	PS	07/13/23 12:12	07/13/23 12:12

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

23G1717

FAX: (510) 321-1357
FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

Sample Identification

ESL#
23G1717

Distribution: 802

Sample Type
Grab
Date Time
7/13/25 12:00

Matrix
DW
of Bottles
Field
Field
Container Type
Preservative
Field

Analysis Requested
Free Chlorine 0.29 mg/L

ROTATION

Wk 1 - 704 Kitchen Sink
Wk 2 - 802 Room 204 Sink
Wk 3 - 803 Admin Sink
Wk 4 - 804 400 Hall RR Sink
Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Monteau Jr/Sr - Weekly

Sampled By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

Company Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PW/SID:

MONTICAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcambell@monticau.org

5100324

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112
5100324	1013	FREE CHLORINE	301	0.92	071323	802		071323	D	1212	32382	23G1717-01	BROW 557

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 237



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 256-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

27 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2650
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23G2650-01	Drinking Water	07/20/2023 11:50	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Reported: 07/27/2023 10:42

Lab Sample ID#: 23G2650-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 07/20/2023 11:50
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysts	Analytical Method: SM4500-Cl G-II				Prep Method: No Prep - Field		
Chlorine, Free	0.800	mg/L		0.200	PS	07/20/23 11:50	07/20/23 11:50

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112
5100324	1013	FREE CHLORINE	301	0.92	071323	802		071323	D	1212	32382	23G1717-01	BROW 557
5100324	1013	FREE CHLORINE	301	0.8	072023	804		072023	D	1150	32382	23G2650-01	BROW 1965

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 237

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NI
43
Mk
(51
FA

FOR INTERNAL LABORATORY USE



23G2650

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>23G2650</u>	Date: <u>7/20/03</u>	Time: <u>1150</u>	DW	Field	Field	Free Chlorine <u>0.80</u>

ROTATION
Wk 1 - 704 Kitchen Sink
Wk 2 - 802 Room 204 Sink
Wk 3 - 803 Admin Sink
Wk 4 - 804 400 Hall RR Sink
Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (10% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 7/20/03 1150
Relinquished By: (Signature) [Signature] Date/ Time 7/20/03 1300

Relinquished By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Company Name: **MONITEAU SCHOOL DISTRICT**
Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
Contact Person: **JEFFREY CAMPBELL**
Phone Number: **724-406-4426**
Cell Phone: **724-406-4426**
Email Address: **jcampbell@moniteau.org**
Billing Address: **JEFFREY CAMPBELL**
PWSID: **5100324**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

01 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G3417
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23G3417-01	Drinking Water	07/27/2023 11:15	7/27/23 13:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/01/2023 13:39

Lab Sample ID#: 23G3417-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 07/27/2023 11:15
Receipt Date: 07/27/2023 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.720	mg/L		0.200	PS	07/27/23 11:15	07/27/23 11:15

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Recon
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112
5100324	1013	FREE CHLORINE	301	0.92	071323	802		071323	D	1212	32382	23G1717-01	BROW 557
5100324	1013	FREE CHLORINE	301	0.8	072023	804		072023	D	1150	32382	23G2650-01	BROW 1965
5100324	1013	FREE CHLORINE	301	0.72	072723	804		072723	D	1115	32382	23G3417-01	BROW 2838

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Recon
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 237

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for July 2023

Dassa McKinney Elementary School Water Treatment Facility										
Month	July	2023								
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sat									
2	Sun									
3	Mon									
4	Tues									
5	Wed	8.7	0.06	1.18	1.26	3.12	14254300	Jeff R	1:30P	
6	Thurs	8.7	0.03	1.06	1.14	3.25	14254500	Jeff R	1:30P	200
7	Fri	8.7	0.02	1.00	1.07	2.44	14254700	Jeff R	1:30P	200
8	Sat									
9	Sun									
10	Mon	8.7	0.01	1.02	1.08	2.45	14255000	Jeff R	3:30P	300
11	Tues	8.7	0.02	0.98	1.06	2.38	14255200	Jeff R	3:30P	200
12	Wed	8.7	0.02	0.92	1.00	2.49	14255500	Jeff R	3:30P	300
13	Thurs									
14	Fri									
15	Sat									
16	Sun									
17	Mon	8.7	0.02	0.41	0.47	2.30	14256900	Jeff R	3:30P	1400
18	Tues	8.7	0.02	0.54	0.62	2.35	14257300	Jeff R	3:30P	400
19	Wed	8.7	0.04	0.52	0.60	2.58	14258000	Jeff R	11:00A	700
20	Thurs	8.7	0.03	0.81	0.61	2.69	14258600	Jeff R	2:00P	600
21	Fri									
22	Sat									
23	Sun									
24	Mon	8.7	0.02	0.41	0.45	2.26	14258800	Jeff R	3:30P	200
25	Tues	8.7	0.00	0.78	0.86	2.31	14259000	Jeff R	3:30P	200
26	Wed	8.7	0.03	0.60	0.68	2.48	14259300	Jeff R	2:00P	300
27	Thurs									
28	Fri									
29	Sat									
30	Sun									
31	Mon	8.7	0.02	0.46	0.54	2.67	14260300	Jeff R	3:30P	1000



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0517
Project: Drinking Water Dassa McKinney - Annual
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101	23G0517-01	Drinking Water	07/06/2023 11:05	7/6/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/11/2023 15:42

Lab Sample ID#: 23G0517-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: Entry Point 101

Sample Date: 07/06/2023 11:05
Receipt Date: 07/06/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: EPA300.0 2.1				Prep Method: No Prep - WetChem		
Nitrate	<0.100	mg/L		0.100	TLL	07/07/23 01:53	07/07/23 01:53
Nitrite	<0.100	mg/L		0.100	TLL	07/07/23 01:53	07/07/23 01:53



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monterey</u>	Work Order: <u>23G0517</u>
-------------------------	----------------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>(N/A)</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JND / 00382</u>	Samples Received on Ice? <u>(YES)</u> NO
Date/Time Received: <u>7/6/23 1330</u>	Date Sampled: <u>7/6/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>(ESL courier)</u> Other: _____	
Sample Receipt Temperature: <u>4.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: <u>(YES)</u> NO

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>(YES)</u> NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>(YES)</u> NO	Comments:
Sample containers intact and sealed?	<u>(YES)</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>(YES)</u> NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>(YES)</u> NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>(YES)</u> NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>(YES)</u> NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>(YES)</u> NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>(YES)</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>(YES)</u> NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES <u>(NO)</u>	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES <u>(NO)</u>

Effective Date:

GP.25.A-1 Sample Receipt Log

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW111

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0640
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23G0640-01	Drinking Water	07/06/2023 11:00	7/6/23 14:32	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/12/2023 08:43

Lab Sample ID#: 23G0640-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 07/06/2023 11:00
Receipt Date: 07/06/2023 14:32

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	PS	07/06/23 11:00	07/06/23 11:00
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00
E. Coli	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHEAST DIVISION
435 Bldg.
Montour
(570) 32
FAX: (570) 32

FOR INTERNAL LABORATORY

23G0640



Sample Identification	ESL# 23G0640	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
801 KITCHEN SINK 802-ROOM 617 SINK			7/23	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.64 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (1.5% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) <i>[Signature]</i> Date/ Time 7/23 PM 1:00 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 7-23 PM 1:33 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 7-23 PM 1:43 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 7-23 PM 1:43 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 7-23 PM 1:43 Correct Preservations (Y/N/NA) Correct Containers (Y/N/NA) Receipt Temperature 3.6 #3	Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@monteau.org Billing Address: 5100316 PWSID:
---	---

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G1718
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23G1718-01	Drinking Water	07/13/2023 12:00	7/13/23 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/18/2023 17:04

Lab Sample ID#: 23G1718-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 07/13/2023 12:00
Receipt Date: 07/13/2023 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.530	mg/L		0.200	PS	07/13/23 12:00	07/13/23 12:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 161
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23G018	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: <u>See</u>				DW	Field	Field	Free Chlorine <u>0.53</u> mg/L

ROTATION

Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 617 Sink



23G1718

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW);
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

MONTICAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

Company/Name:
Address:
Contact Person:

Phone Number:

724-406-4426

Cell Phone:

jeffcampbell@monticau.org

Email Address:

Billing Address:

PWSID:

5100316

Sampled By: (Signature)

Date/ Time

7/13/03 08:12:05

Relinquished By: (Signature)

Date/ Time

7/13/03 (19) 14:55

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111
5100316	1013	FREE CHLORINE	301	0.53	071323	802		071323	D	1200	32382	23G1718-01	BROW 556

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2649
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23G2649-01	Drinking Water	07/20/2023 11:35	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/21/2023 16:22

Lab Sample ID#: 23G2649-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink


Sample Date: 07/20/2023 11:35
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.400	mg/L		0.200	PS	07/20/23 11:35	07/20/23 11:35

ENVIRONMENTAL SERVICE LABORATORIES, INC.

CAMPBELL REQUEST & RETURN OF CONTAINER

SE 1 OF 1



23G2649

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 256-TEST
FAX: (724) 256-8376

FOR INTERNAL LABOR

Sample Identification

ESL# 23G2649

Distribution: 804

Sample Type	Grab		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	Date	Time				
	7/20/03	11:36	DW	Field	Field	Free Chlorine 0.40 mg/L

ROTATION

- WK 1 - 801 Kitchen Sink
- WK 2 - 802 Room 617 Sink
- WK 3 - 803 Room 606 Sink
- WK 4 - 804 Room 408 Sink
- WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:.

Drinking Water Dassa McKinney - Weekly

MONTTEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

Company/Name:
Address:
Contact Person:
Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

724-406-4426

jcambell@montiteau.org

5100316

Sampled By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations

Correct Containers

Receipt Temperature

Signature

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111
5100316	1013	FREE CHLORINE	301	0.53	071323	802		071323	D	1200	32382	23G1718-01	BROW 556
5100316	1013	FREE CHLORINE	301	0.4	072023	804		072023	D	1135	32382	23G2649-01	BROW 1964

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

01 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G3418
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23G3418-01	Drinking Water	07/27/2023 10:55	7/27/23 13:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/01/2023 13:39

Lab Sample ID#: 23G3418-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 07/27/2023 10:55
Receipt Date: 07/27/2023 13:15

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.580	mg/L		0.200	PS	07/27/23 10:55	07/27/23 10:55

E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111
5100316	1013	FREE CHLORINE	301	0.53	071323	802		071323	D	1200	32382	23G1718-01	BROW 556
5100316	1013	FREE CHLORINE	301	0.4	072023	804		072023	D	1135	32382	23G2649-01	BROW 1964
5100316	1013	FREE CHLORINE	301	0.58	072723	804		072723	D	1055	32382	23G3418-01	BROW 2837

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW 236