

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for June 2023

**COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST

ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

FACILITY: MONITEAU JR SR HIGH SCHOOL

LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

STAGE: Final Effluent

PA0091341	
PERMIT NUMBER	

001	
OUTFALL NUMBER	

Reporting Frequency:	Monthly
DMR Effective From:	06/01/2023
DMR Effective To:	06/30/2023
Permit Expires:	01/31/2028
Permit Application Due:	08/04/2027
No Discharge:	☐

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	06	01	2023	06	30

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.71	***	***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		4.0	***	***	***	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.17	***	8.34	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		6.0	***	9.0	***	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		Daily Min	***	Daily Max	S.U.	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		***	5.5	5.5	***	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		***	30.0	60.0	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	Avg Mo	IMAX	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	<165	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		***	Monitor & Report	***	***	2/month	Grab
Flow (50050)	SAMPLE MEASUREMENT	002069		***	Avg Mo	***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	Monitor & Report		***	Monitor & Report	***	***	Daily when Discharging	Grab
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	***		***	***	***	***	1/week	Measured
		***		***	<1.0	<1.0	No./100 ml	2/month	Grab
		***		***	200	1000	***	2/month	Grab
		***		***	Geo Mean	IMAX	***	2/month	Grab

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (60082)	SAMPLE MEASUREMENT	***	***		***	<2.00	<2.00	2/month	Grab
	PERMIT REQUIREMENT	***	***		25.0 Avg Mo	50.0 MAX	mg/L	2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>

Mon, Jul 17, 2023 at 9:30 AM

To: jcampbell@moniteau.org, mcafoose92@hotmail.com

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 06/01/2023-06/30/2023

Report Due Date: 07/28/2023

Submitted By: Jeffrey Campbell

Submission Id: 402987

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: June 2023

Flow	$62,095 \div 30 =$: <u>2,069</u> Daily Avg		
UV Light	$135.4 \div 22 =$: <u>6.15</u> Daily Avg		
		Basin #	Date
PH Low	<u>7.17</u>	<u>1</u>	<u>6/19</u>
PH High	<u>8.34</u>	<u>1</u>	<u>6/28</u>
D. O. Low	<u>7.71</u>	<u>1</u>	<u>6/14</u>
D. O. High	<u>9.62</u>	<u>1</u>	<u>6/5</u>

Date:	<u>6/1</u>	<u>6/15</u>	Sub Total	$\div 2$	Report
Total Nitrogen	<u>40.5</u>	<u>9.54</u>	<u>50.04</u>	<u>25.02</u>	<u>25.02</u>
TSS	<u>6</u>	<u>5</u>	<u>11</u>	<u>5.5</u>	<u>5.5</u>
TKN	<u>0.677</u>	<u><0.165</u>	<u>0.842</u>	<u>0.421</u>	<u>0.421</u>
Nitrate/Nitrate	<u>39.9</u>	<u>9.54</u>	<u>49.44</u>	<u>24.72</u>	<u>24.72</u>
Phos	<u>3.8</u>	<u>1.4</u>	<u>5.2</u>	<u>2.6</u>	<u>2.6</u>
CBOD	<u><2.00</u>	<u><2.00</u>		<u><2.00</u>	<u><2.00</u>
Fecal	<u><1</u>	<u><1</u>		<u><1</u>	<u><1</u>
<u>Ammonia</u>	<u><0.165</u>	<u><0.165</u>		<u><0.165</u>	<u><0.165</u>

Moniteau High School Sewage Treatment Plant
Permit # D00001242

Permit # PA0091341

Permit # P40001312

Daily Operations Worksheet

Permit # PA0091341										Daily Operations Worksheet									
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	UV	Meter Reading	Time	Operator									
6/11	Thurs	7.41	7.99	7.61	8.04	JUNE	6.7		10:00 AM	JEFF C									
6/12	Fri	7.74	8.48	7.41	8.47		5.9		6:00 AM	JEFF C									
6/15	Mon	8.04	9.62	7.22	8.77		5.7		1:30 PM	JEFF C									
6/16	Tues	8.07	9.40	7.29	8.68		5.5		2:00 PM	JEFF C									
6/17	Wed	8.09	9.31	7.46	8.83		5.7		9:00 AM	JEFF C									
6/18	Thurs	8.01	9.17	7.66	8.95		5.5		5:00 AM	JEFF C									
6/19	Fri	7.80	8.79	7.62	8.99		5.6		9:00 AM	JEFF C									
6/112	Mon	7.64	7.87	7.58	9.71		5.9		7:00 AM	JEFF C									
6/113	Tues	7.57	7.90	7.43	9.24		5.7		5:00 AM	JEFF C									
6/114	Wed	7.46	7.71	7.52	8.70		6.0		10:00 AM	JEFF C									
6/115	Thurs	7.42	7.73	7.49	8.93		6.2		10:00 AM	JEFF C									
6/116	Fri	7.40	7.67	7.42	8.91		6.1		7:00 AM	JEFF C									
6/119	Mon	7.17	8.59	7.24	8.88		6.0		8:00 AM	JEFF C									
6/120	Tues	7.08	8.32	7.30	8.46		6.7		1:00 PM	JEFF C									
6/121	Wed	8.00	8.93	8.11	8.76		6.8		1:00 PM	JEFF C									
6/122	Thurs	7.97	8.81	8.03	8.68		6.9		1:00 PM	JEFF C									
6/123	Fri	7.84	8.63	8.00	8.49		6.8		1:00 PM	JEFF C									
6/126	Mon	7.67	8.14	7.82	8.23		6.9		1:00 PM	JEFF C									
6/127	Tues	AERATION		7.74	8.11		6.7		2:30 AM	JEFF C									
6/128	Wed	8.34	9.42	8.32	9.02		6.4		3:00 AM	JEFF C									
6/129	Thurs	8.22	9.01	8.24	8.93		6.0		3:00 AM	JEFF C									
6/130	Fri	8.18	8.91	8.08	8.80		5.7		3:00 PM	JEFF C									
	</																		



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F0094
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23F0094-01	Waste Water	06/01/2023 10:30	6/1/23 14:30	
Fish Tank	23F0094-02	Waste Water	05/25/2023 13:00	6/1/23 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Fish Tank fecal sample not received. Notified client via email.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
R Received out of recommended hold time. Sample does not meet hold time requirements of 40 CFR Part 136.
H Analyzed out of recommended hold time. Sample does not meet hold time requirements of 40 CFR Part 136.
G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/21/2023 14:44

Lab Sample ID#: 23F0094-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/01/2023 10:30
Receipt Date: 06/01/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	40.5	mg/L			2.70	AW	06/07/23 09:06	06/07/23 09:06
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	06/06/23 14:40	06/07/23 08:30
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	0.677	mg/L			0.625	AW	06/07/23 09:06	06/07/23 09:06
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	6	mg/L			5	AH	06/05/23 15:23	06/06/23 13:19
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	39.9	mg/L			2.08	AW	06/05/23 13:23	06/05/23 13:23
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem		
Phosphorus	3.8	mg/L			2.0	AW	06/07/23 11:20	06/07/23 11:20
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G, SS		2.00	ATJ	06/02/23 11:49	06/07/23 07:20
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	AMB	06/01/23 14:59	06/02/23 11:40



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/21/2023 14:44

Lab Sample ID#: 23F0094-02
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Fish Tank

Sample Date: 05/25/2023 13:00
Receipt Date: 06/01/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry								
			Analytical Method: SM2540 D-15			Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L	H		5	AH	06/05/23 09:45	06/05/23 15:13
General Chemistry								
			Analytical Method: SM4500-H+ B-11			Prep Method: No Prep - WetChem		
pH	7.40	S.U.	H,R			AW	06/06/23 13:54	06/06/23 13:54
Temp at time of pH, °C	21.2		H,R			AW	06/06/23 13:54	06/06/23 13:54

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

HEADQUARTERS
1903 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376



23F0094

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Grab				
		Date	Time				
Effluent Outfall 001	01	6/1/23	10:30 AM	WW	1	Poly 1000mL	CBOD, TSS
				WW	1	Poly 1000mL	
				WW	1	H2SO4	
				WW	1	Sterile Plastic 125mL	
				WW	1	Na2S2O3	Fecal Coliform
				WW	1		Ammenix
		5/23/23	1:00 PM	WW	1		PH / TSS / Fecal

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Signed By: (Signature) *[Signature]* Date/Time 6/1/23 10:30 AM

Relinquished By: (Signature) *[Signature]* Date/Time 6/1/23 12:00

Relinquished By: (Signature) *[Signature]* Date/Time 6-1-23 05:14

Relinquished By: (Signature) *[Signature]* Date/Time

Received By: (Signature) *[Signature]* Date/Time 6-1-23 05:14

Received By: (Signature) *[Signature]* Date/Time 6/1/23 12:30

Received By: (Signature) *[Signature]* Date/Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receiving Temperature

Company/Name:

Wastewater

Project Notes:

Contact Person:

Address:

Phone / Cell:

Email:

MONTICAU SCHOOL DISTRICT

JEFFREY CAMPBELL

1810 WEST SUNBURY ROAD

WEST SUNBURY, PA 16061

724-406-4426

jcambell@monticau.org



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monteau</u>	Work Order: _____
------------------------	-------------------



23F0094

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: ____/____/____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>Jm 100382</u>	Samples Received on Ice? (YES) NO
Date/Time Received: <u>6/1/23 1430</u>	Date Sampled: <u>6/1/23</u>
Method of Delivery: FedEx UPS Client Drop off (ESL courier) Other: _____	
Sample Receipt Temperature: <u>4.9</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: (PA) NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES (NO)

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	(YES) NO	Comments: _____
COC form is properly signed in relinquished/received sections?	(YES) NO	Comments: _____
Sample containers intact and sealed?	(YES) NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	(YES) NO	Sample IDs and Containers Affected: _____
Sample IDs on COC match IDs on bottles?	(YES) NO	Sample IDs and Containers Affected: _____
Date and time on COC match date and time on bottles?	(YES) NO	Sample IDs and Containers Affected: _____
Samples received within holding time?	(YES) (NO)	Sample IDs and Containers Affected: <u>Fecal</u>
Samples received at appropriate pH for analysis requested?	(YES) NO	Sample IDs and Containers Affected and Observed pH: _____
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	(YES) NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	(YES) NO	Analyses Affected: _____
VOA vials free of headspace (defined as < 6 mm bubble)?	YES (NO)	Sample IDs and Containers Affected: _____
Other Comments: _____		Deficiency Log Created: (YES) (NO) <u>Jm 6/1/23</u>

Effective Date: _____

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

05 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1839
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23F1839-01	Waste Water	06/15/2023 10:00	6/15/23 14:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/05/2023 14:48

Lah Sample ID#: 23F1839-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/15/2023 10:00
Receipt Date: 06/15/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry Analytical Method: *** DEFAULT SPECIFIC METHOD Prep Method: [CALC]								
Total Nitrogen	9.54	mg/L			1.66	AW	06/26/23 14:45	06/26/23 14:45
General Chemistry Analytical Method: ASTM D6919-17 Prep Method: No Prep - WetChem								
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	06/21/23 14:05	06/21/23 23:30
General Chemistry Analytical Method: EPA 351.2 2.0 Prep Method: SM 4500-Norg B								
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	06/19/23 12:03	06/19/23 12:03
General Chemistry Analytical Method: SM2540 D-15 Prep Method: No Prep - WetChem								
Total Suspended Solids	5	mg/L			5	AH	06/20/23 14:19	06/21/23 14:30
General Chemistry Analytical Method: SM4500-NO3 E-16 (discrete) Prep Method: No Prep - WetChem								
Nitrate/Nitrite	9.54	mg/L			1.04	AW	06/26/23 14:45	06/26/23 14:45
General Chemistry Analytical Method: SM5210 B-16 Prep Method: No Prep - WetChem								
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS		2.00	ATJ	06/15/23 16:04	06/20/23 12:01
Microbiology Analytical Method: Colilert-18 Prep Method: No Prep - Micro								
Fecal Coliforms	<1	MPN/100 mL			1	AMB	06/15/23 14:57	06/16/23 11:50

Lab Sample ID#: 23F1839-01RE1
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/15/2023 10:00
Receipt Date: 06/15/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry Analytical Method: SM4500-P E-11 Prep Method: No Prep - WetChem								
Phosphorus	1.4	mg/L			0.20	JMS	06/30/23 17:26	06/30/23 17:26

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type Preservative	Analysis Requested
		Composite	Grab	Date	Time				
Effluent Outfall 001	01					WW	1	Poly 1000mL None	CBOD, TSS Total Nitrogen, Total Phosphorus Fecal Coliform
						WW	1	Poly 1000mL H2SO4	
						WW	1	Sterile Plastic 125mL Na2S2O3	
						BW	1		
23F1839									
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.									
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) ON THE MAXIMUM ALLOWED BY LAW.									
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, RESPONSIBLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.									
Project Notes:									
Wastewater									
Company/Name:									
MONTICELLO SCHOOL DISTRICT									
Contact Person:									
JENNIFER CAMPBELL									
Address:									
1810 WEST SUNBURY ROAD									
WEST SUNBURY, PA 16061									
Phone / Cell:									
724-406-4426									
Email:									
jcampbell@monticello.org									



SAMPLE RECEIPT AND REVIEW FORM

Client: Monteau



23F1839

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>AL 100382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>6/15/23</u> <u>1440</u>	Date Sampled: <u>6/15/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.4</u> °C	IR Gun ID: _____
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO	Comments: _____
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments: _____
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected: _____
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH: _____
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected: _____
VOA vials free of headspace (defined as < 6 mm bubble)?	YES <u>NO</u>	Sample IDs and Containers Affected: _____
Other Comments: _____		Deficiency Log Created: YES <u>NO</u>

Effective Date: _____

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

05 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1839
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23F1839-01	Waste Water	06/15/2023 10:00	6/15/23 14:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/05/2023 14:48

Lab Sample ID#: 23F1839-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/15/2023 10:00
Receipt Date: 06/15/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry Analytical Method: *** DEFAULT SPECIFIC METHOD Prep Method: [CALC]								
Total Nitrogen	9.54	mg/L			1.66	AW	06/26/23 14:45	06/26/23 14:45
General Chemistry Analytical Method: ASTM D6919-17 Prep Method: No Prep - WetChem								
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	06/21/23 14:05	06/21/23 23:30
General Chemistry Analytical Method: EPA 351.2 2.0 Prep Method: SM 4500-Norg B								
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	06/19/23 12:03	06/19/23 12:03
General Chemistry Analytical Method: SM2540 D-15 Prep Method: No Prep - WetChem								
Total Suspended Solids	5	mg/L			5	AH	06/20/23 14:19	06/21/23 14:30
General Chemistry Analytical Method: SM4500-NO3 E-16 (discrete) Prep Method: No Prep - WetChem								
Nitrate/Nitrite	9.54	mg/L			1.04	AW	06/26/23 14:45	06/26/23 14:45
General Chemistry Analytical Method: SM5210 B-16 Prep Method: No Prep - WetChem								
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS		2.00	ATJ	06/15/23 16:04	06/20/23 12:01
Microbiology Analytical Method: Colilert-18 Prep Method: No Prep - Micro								
Fecal Coliforms	<1	MPN/100 mL			1	AMB	06/15/23 14:57	06/16/23 11:50

Lab Sample ID#: 23F1839-01RE1
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/15/2023 10:00
Receipt Date: 06/15/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry Analytical Method: SM4500-P E-11 Prep Method: No Prep - WetChem								
Phosphorus	1.4	mg/L			0.20	JMS	06/30/23 17:26	06/30/23 17:26

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

[illegible]



SAMPLE RECEIPT AND REVIEW FORM

Client: Monteau



23F1839

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>AL 100382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>6/15/23</u> <u>1440</u>	Date Sampled: <u>6/15/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.4</u> °C	IR Gun ID: _____
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments:
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES <u>NO</u>	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES <u>NO</u>

Effective Date:

GP.25.A-1 Sample Receipt Log



INVOICE

2313928

Invoice To

Jeffrey Campbell
Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Remit To

Accounts Receivable
Environmental Service Laboratories, Inc.
1802 Philadelphia Street
Indiana, PA 15701

Sample Received

06/15/2023

PO Number

Invoiced On

07/05/2023

Project Manager

Kirsten Conoran

Terms

Due Upon Receipt

Project Description(s)

Wastewater

Project(s)

Wastewater

Work Order(s)		Work Order(s)	Total Cost
23F1839		\$160.13	\$160.13
Additional Items			
Quantity	Description	Item Cost	Total Cost
1	7% Inflationary Adjustment		\$11.42
1	Aqueous Sample Disposal Fee, per Work Order	\$3.00	\$3.00
Invoice Total:			\$174.55

During the past year ESL, like so many companies, has experienced rising costs across our supply chain, including raw material and services. Although ESL has been absorbing cost increases through 2021, effective January 1, 2022 we will need to pass along a price appreciation on some products and services that may apply to you.

ESL continues to focus on providing superior quality and outstanding customer care. Our entire team at ESL sincerely appreciates your continued support.

Standard Rush Charges: 1-2days 100%, 3-4days 75%, 5-6days 50%, 7-8days 25%

Interest on past due balances at 18% APR.

Please direct inquiries to Accounts Receivable at ar@envlabs.com or (724) 463-8378.

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for June 2023

MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1 Thurs	69.0	9.95	8,030,993	0.99	1.10	7.1	0.02	0	1.00	JEFF C	12:00
2 FRI	69.5	8.15	8,030,993	0.99	1.11	7.1	0.02	0	0.99	JEFF C	4:00 PM
3 SAT											
4 SUN											
5 Mon	69.9	7.10	8,030,993	0.99	1.11	7.1	0.02	0	0.99	JEFF C	9:00 AM
6 Tues	65.6	11.22	8,074,477	0.83	0.88	7.1	0.01	0	1.17	JEFF C	1:00 PM
7 Wed	68.0	8.16	8,074,477	0.83	0.89	7.1	0.01	0	1.15	JEFF C	1:00 PM
8 Thurs	65.2	11.90	8,086,434	1.00	1.08	7.1	0.00	0	0.97	JEFF C	8:30 AM
9 FRI	66.7	9.52	8,086,434	1.01	1.08	7.1	0.00	0	0.97	JEFF C	9:00 AM
10											
11											
12 Mon	69.8	8.00	8,086,434	0.99	1.05	7.1	0.00	0	0.98	JEFF C	7:30 AM
13 Tues	66.1	9.20	8,096,467	1.01	1.06	7.1	0.01	0	1.08	JEFF C	5:00 PM
14 Wed	65.0	10.20	8,112,025	1.07	1.12	7.1	0.03	0	1.38	JEFF C	9:00 AM
15 Thurs	64.1	8.64	8,112,025	1.08	1.12	7.1	0.03	0	1.38	JEFF C	7:30 AM
16 FRI	Closed										
17 SAT											
18 SUN											
19 Mon	67.7	10.76	8,129,245	1.05	1.11	7.1	0.01	0	1.19	JEFF C	1:00 PM
20 Tues	68.4	8.61	8,129,245	1.04	1.10	7.1	0.01	0	1.20	JEFF C	2:00 PM
21 Wed	67.4	11.62	8,142,605	0.96	1.00	7.1	0.02	0	1.25	JEFF C	10:00 AM
22 Thurs	68.9	10.41	8,142,605	0.96	1.00	7.1	0.02	0	1.24	JEFF C	9:00 AM
23 FRI	Closed										
24 SAT											
25 SUN											
26 Mon	67.5	11.77	8,153,638	0.95	0.99	7.1	0.02	0	1.19	JEFF C	9:00 AM
27 Tues	69.1	10.93	8,153,638	0.95	0.98	7.1	0.02	0	1.19	JEFF C	3:00 PM
28 Wed	71.0	9.42	8,153,638	0.95	0.98	7.1	0.02	0	1.18	JEFF C	3:00 PM
29 Thurs	71.9	8.61	8,153,638	0.93	0.96	7.1	0.02	0	1.18	JEFF C	1:00 PM
30 FRI	Closed										
31											

Sewage Samples

Water Samples



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1857
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 483-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F0110
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23F0110-01	Drinking Water	06/01/2023 11:55	6/1/23 14:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 08:57

Lab Sample ID#: 23F0110-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 06/01/2023 11:55
Receipt Date: 06/01/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	1.14	mg/L			Client	06/01/23 11:55	06/01/23 11:55
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55
E. Coli	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

23F0110

HEADQUARTER
1800 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorths, PA 15366
(724) 256-TEST
FAX: (724) 256-8376

NORTHERN DIVISION
435 Broad Street
Montaursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIV
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
CIRCLE ONE: 704 KITCHEN MAIN-SINK 802 ROOM 204 SINK	ES# 23F0110 Q1	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 1.14

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.02% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Drinking Water Monticau Jr/Sr - Monthly

Sampled By: (Signature) 	Date/ Time 6-22-05 11:55	Company/Name: MONTEAU SCHOOL DISTRICT
Relinquished By: (Signature) 	Date/ Time 6-23-05 14:45	Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID:
Relinquished By: (Signature)	Date/ Time	724-406-4426 jcampbell@monticau.org
Correct Preservations (Y/N/NA)	Correct Containers (Y/N/NA)	Receipt Temperature 2.4

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.14	060123	802		060123	D	1155	32382	23F0110-01	BROWNKA_35
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1155	32382	23F0110-01	BROWNKA_36



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F0110
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23F0110-01	Drinking Water	06/01/2023 11:55	6/1/23 14:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 08:57

Lab Sample ID#: 23F0110-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 06/01/2023 11:55
Receipt Date: 06/01/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	1.14	mg/L			Client	06/01/23 11:55	06/01/23 11:55
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55
E. Coli	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 463-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIV
950 Main Street
Shippensburg, PA 17
(724) 463-TEST
FAX: (724) 463-4

23F0110

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
CIRCLE ONE: 704 KIRCHEN MAIN-SINK 802 ROOM 204 SINK	23F0110			DW	1	STERILE PLASTIC PRESERVATIVE NA THIO	TC/EC Free Chlorine 1.14

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Monthly

Sampled By: (Signature) 	Date/ Time 6-2-93 11:55	Company/Name: MONITEAU SCHOOL DISTRICT
Relinquished By: (Signature) 	Date/ Time 6-10-93 14:45	Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061
Relinquished By: (Signature)	Date/ Time	Contact Person: JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Phone Number: 724-406-4426
Relinquished By: (Signature)	Date/ Time	Cell Phone: jcampbell@moniteau.org
Correct Preservations (Y)N/NA	Correct Containers (Y)N/NA	Billing Address: 5100324

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.14	060123	802		060123	D	1155	32382	23F0110-01	BROWNKA_35
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1155	32382	23F0110-01	BROWNKA_36



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1278 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montourville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1055
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23F1055-01	Drinking Water	06/08/2023 12:05	6/8/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04680

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 11:10

Lab Sample ID#: 23F1055-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 06/08/2023 12:05
Receipt Date: 06/08/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	1.09	mg/L		0.200	PS	06/08/23 12:05	06/08/23 12:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 256-TEST
FAX: (724) 258-8376

NORTHERN DIV
435 Broad Street
Montoursville, PA
(570) 321-8003
FAX: (570) 321-



23F1055

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL # 23F1055	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 204	204	1/28/05	1205	DW	Field	Field	Free Chlorine 1.09 mg/L
ROTATION WK 1 - 204 Kitchen Sink WK 2 - 802 Room 204 Sink WK 3 - 803 Admin Sink WK 4 - 804 400 Hall RR Sink WK 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 30 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.02% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.							
Sampled By: (Signature) <i>[Signature]</i> Date/Time 1/28/05 1344		Received By: (Signature) <i>[Signature]</i> Date/Time 1/28/05 1345		Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD Contact Person: WEST SUNBURY, PA 16061 Phone Number: JEFFREY CAMPBELL Cell Phone: 724-406-4426 Email Address: jcampbell@monteau.org Billing Address: 5100324 PWSID: 5100324			
Retinquished By: (Signature) Date/Time		Received By: (Signature) Date/Time		Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature			

Drinking Water Monteau Jr/Sr - Weekly

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.09	060823	704		060823	D	1205	32382	23F1055-01	BROWNKA_256
5100324	1013	FREE CHLORINE	301	1.14	060123	802		060123	D	1155	32382	23F0110-01	BROWNKA_35
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1155	32382	23F0110-01	BROWNKA_36



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1055
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23F1055-01	Drinking Water	06/08/2023 12:05	6/8/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 11:10

Lab Sample ID#: 23F1055-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 06/08/2023 12:05
Receipt Date: 06/08/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	1.09	mg/L		0.200	PS	06/08/23 12:05	06/08/23 12:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 463-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 259-TEST
FAX: (724) 259-8376

NORTHERN DIV
435 Broad Street
Montoursville, Pa.
(570) 321-8003
FAX: (570) 321-



23F1055

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL#
23F1055

Distribution: 264

on

Sample Type

Grab

Matrix

of Bottles

Container Type
Preservative

Analysis Requested

Free Chlorine 1.09 mg/L

ROTATION

WK 1 - 304 Kitchen Sink

WK 2 - 802 Room 204 Sink

WK 3 - 803 Admin Sink

WK 4 - 804 400 Hall RR Sink

WK 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Monticau Jr/Sr - Weekly

Company/Name:

MONTEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD

Contact Person:

WEST SUNBURY, PA 16061

Phone Number:

JEFFREY CAMPBELL

Cell Phone:

724-406-4426

Email Address:

jcambell@monticau.org

Billing Address:

5100324

PWSID:

Sampled By: (Signature)

Date/ Time

6-8-23 13:44

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.09	060823	704		060823	D	1205	32382	23F1055-01	BROWNKA_256
5100324	1013	FREE CHLORINE	301	1.14	060123	802		060123	D	1155	32382	23F0110-01	BROWNKA_35
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1155	32382	23F0110-01	BROWNKA_36

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vornis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17134
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	23E0716		5-4-23 1232	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.61



23E0716

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Notes/Special Instructions:

Drinking Water Monteau Jr/Sr - Monthly

MONTEAU SCHOOL DISTRICT

1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcambell@monteau.org

5100324

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

Date/ Time

5-4-23 1232 SES

Date/ Time

5-4-23 1440 SES

Date/ Time

Date/ Time

Received By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature 2.473



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1956
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23F1956-01	Drinking Water	06/15/2023 11:40	6/15/23 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/19/2023 11:42

Lah Sample ID#: 23F1956-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 06/15/2023 11:40
Receipt Date: 06/15/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	1.06	mg/L		0.200	PS	06/15/23 11:40	06/15/23 11:40

SAMPLE REQUEST & CHAIN OF CUSTODY

SEE 1 OF 1

23F1956




ROTATION
Wk 1 - 704 Kitchen Sink
Wk 2 - 802 Room 204 Sink
Wk 3 - 803 Admin Sink
Wk 4 - 804 400 Hall RR Sink
Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

3. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)  61523 05 1440		Company/Name: MONITEAU SCHOOL DISTRICT	
Relinquished By: (Signature)  61523 01 1440		Address: 391 HOOKER ROAD	
Relinquished By: (Signature)  61523 01 1440		Contact Person: WEST SUNBURY, PA 16061	
Relinquished By: (Signature)  61523 01 1440		Phone Number: JEFFREY CAMPBELL	
Relinquished By: (Signature)  61523 01 1440		Cell Phone: 724-406-4426	
Relinquished By: (Signature)  61523 01 1440		Email Address: jcampbell@moniteau.org	
Relinquished By: (Signature)  61523 01 1440		Billing Address: 5100324	
Relinquished By: (Signature)  61523 01 1440		PWSID: 5100324	



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.06	06/15/23	803		06/15/23	D	1140	32382	23F1956-01	BROWN 325



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F2765
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23F2765-01	Drinking Water	06/22/2023 11:00	6/22/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/28/2023 13:14

Lab Sample ID#: 23F2765-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 06/22/2023 11:00
Receipt Date: 06/22/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	1.09	mg/L		0.200	PS	06/22/23 11:00	06/22/23 11:00



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.06	061523	803		061523	D	1140	32382	23F1956-01	BROWN 325
5100324	1013	FREE CHLORINE	301	1.09	062223	804		062223	D	1100	32382	23F2765-01	BROWN 752

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1


HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15386 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	--	--	---

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>804</u>	23 F2765	Date	Grab			Preservative	
	01	6/22/03	1100	DW	Field	Field	Free Chlorine <u>1.09</u> mg

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) Relinquished By: (Signature)	Date/ Time 6/22/03 1300 6/22/03 1330
---	--

Relinquished By: (Signature) Relinquished By: (Signature)	Date/ Time 6/22/03 1330 6/22/03 1330
--	--

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature

Company/Name:	MONITEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD
Contact Person:	WEST SUNBURY, PA 16061
Phone Number:	JEFFREY CAMPBELL
Cell Phone:	724-406-4426
Email Address:	jcampbell@moniteau.org
Billing Address:	
PWSID:	5100324



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

30 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F3446
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23F3446-01	Drinking Water	06/29/2023 09:50	6/29/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/30/2023 15:51

Lab Sample ID#: 23F3446-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 06/29/2023 09:50
Receipt Date: 06/29/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.980	mg/L		0.200	PS	06/29/23 09:50	06/29/23 09:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-8003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL# 23F3446

Distribution: 804

Sample Type
Grab
Date Time

Matrix
DW

of Bottles
Field

Container Type
Preservative
Field

Analysis Requested
Free Chlorine 0.98 mg/l

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)

Date/ Time

6-29-03 PM 6:50

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature

COMPANY/NAME: MONTEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

Contact Person:

Phone Number:

Cell Phone:

Email Address: jcampbell@monteau.org

Billing Address:

PWSID: 5100324





E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.06	061523	803		061523	D	1140	32382	23F1956-01	BROWN1325
5100324	1013	FREE CHLORINE	301	1.09	062223	804		062223	D	1100	32382	23F2765-01	BROWN1752
5100324	1013	FREE CHLORINE	301	0.98	062923	804		062923	D	0950	32382	23F3446-01	BROWN1053

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for June 2023

Dassa McKinney Elementary School Water Treatment Facility										
Month	June	2023								
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Thurs	8.7	0.02	0.58	0.66	2.75	14246900	Jeff R	3:30P	1800
2	Fri	8.7	0.00	0.75	0.79	2.47	14247000	Jeff R	12:00P	100
3	Sat									
4	Sun									
5	Mon	8.7	0.01	0.71	0.80	2.68	14248000	Jeff R	4:30P	1000
6	Tues	8.7	0.00	0.76	0.85	2.91	14248500	Jeff R	4:30P	500
7	Wed	8.7	0.02	0.79	0.88	2.69	14248900	Jeff R	2:00P	400
8	Thurs	8.7	0.01	0.70	0.80	3.20	14249600	Jeff R	3:30P	700
9	Fri	Closed								
10	Sat									
11	Sun									
12	Mon	8.7	0.01	0.48	0.59	2.22	14249700	Jeff C	5:00P	
13	Tues	8.7	0.01	0.31	0.47	1.74	14250300	Jeff C	1:00P	
14	Wed									
15	Thurs									
16	Fri	Closed								
17	Sat									
18	Sun									
19	Mon	8.7	0.00	1.20	1.29	1.65	14251700	Jeff C	9:00A	
20	Tues	8.7	0.00	1.21	1.30	1.68	14251700	Jeff C	1:00P	
21	Wed									
22	Thurs									
23	Fri									
24	Sat									
25	Sun									
26	Mon									
27	Tues									
28	Wed									
29	Thurs									
30	Fri									
31										

Meter Reading - 5/31/23 - 14,245,100



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F0109
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23F0109-01	Drinking Water	06/01/2023 11:35	6/1/23 14:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





ENVIRONMENTAL
SERVICE LABORATORIES, INC.

1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 08:43

Lab Sample ID#: 23F0109-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 06/01/2023 11:35
Receipt Date: 06/01/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysts Date/Time
Field Analysis							
Chlorine, Free	0.730	mg/L			Client	06/01/23 11:35	06/01/23 11:35
Microbiology							
Analytical Method: SM 9223 B-16							
Total Coliform	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55
E. Coli	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-1EST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Vleet, PA 15396 (724) 258-1EST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	NORTH 950 Main Sharpsville (724) 46 FAX: (72
---	--	--	---

FOR INTERNAL LABORATORY USE ONLY



23F0109

Sample Identification	EST#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK	23F0109	6-1-23	1135	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.73 mg/L
802 ROOM 617 SINK	01						

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) Date/ Time 6-1-23 1135	Company/Name: MONITEAU SCHOOL DISTRICT
Relinquished By: (Signature) Date/ Time 6-1-23 1440	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061
Relinquished By: (Signature) Date/ Time	Contact Person: JEFFREY CAMPBELL
Relinquished By: (Signature) Date/ Time	Phone Number: 724-406-4426
Relinquished By: (Signature) Date/ Time	Email Address: jcampbell@moniteau.org
Relinquished By: (Signature) Date/ Time	Billing Address: 5100316
Correct Preservations Y/N/NA	Correct Containers Y/N/NA
Correct Temperature 2.4	Receipt Temperature

Department of Environmental Protection

E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.73	060123	802		060123	D	1135	32382	23F0109-01	BROWNKA_33
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1135	32382	23F0109-01	BROWNKA_34



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F0109
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23F0109-01	Drinking Water	06/01/2023 11:35	6/1/23 14:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 08:43

Lab Sample ID#: 23F0109-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 06/01/2023 11:35
Receipt Date: 06/01/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.730	mg/L			Client	06/01/23 11:35	06/01/23 11:35
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55
E. Coli	Absent	per 100 mL		1	AMB	06/01/23 15:08	06/02/23 15:55

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN



23F0109

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17134
(570) 321-8003
FAX: (570) 321-1957

NORTH
950 Main
Sharpsville
(724) 46-
FAX: (7-

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23F0109	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK		6-1-85	1135	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.73 mg/L
802 ROOM 617 SINK							

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) 	Date/ Time 6-1-85 1135	Company/Name: MONTEAU SCHOOL DISTRICT
Retest/Relinquished By: (Signature) 	Date/ Time 6-1-85 1135	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061
Relinquished By: (Signature)	Date/ Time	Contact Person: JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Phone Number: 724-406-4426
Relinquished By: (Signature)	Date/ Time	Cell Phone: icampbell@monteau.org
Relinquished By: (Signature)	Date/ Time	Billing Address: 5100316
Correct Preservations Y/N/NA	Correct Containers Y/N/NA	Receipt Temperature 2.4

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.73	060123	802		060123	D	1135	32382	23F0109-01	BROWNKA_33
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1135	32382	23F0109-01	BROWNKA_34



1603 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Monroeville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

850 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1056
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23F1056-01	Drinking Water	06/08/2023 11:55	6/8/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/12/2023 11:12

Lab Sample ID#: 23F1056-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 06/08/2023 11:55
Receipt Date: 06/08/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.550	mg/L		0.200	PS	06/08/23 11:55	06/08/23 11:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bontleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montaukville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street

FOR INTERNAL LABORATORY USE ONLY

23F1056

Analysis Requested

Sample Identification

ESL#

Sample Type

Matrix

of Bottles

Container Type

Free Chlorine

Distribution: SC1

23F1056

6-8-83 1155

DW

Field

Field

0.55 mg/L

Monteau School District

Administrative Offices
100 West Sunbury Road
West Sunbury, PA 16061
(724) 537-2117
Fax: (724) 637-3862

W-1 - 804 Kitchen Sink
W-2 - 802 Room 617 Sink
W-3 - 803 Room 606 Sink
W-4 - 804 Room 408 Sink
W-5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 30 DAYS OLD.

THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature)

Date/Time

6-8-83 1155

Relinquished By: (Signature)

Date/Time

6-8-83 1155

Received By: (Signature)

Date/Time

6-8-83 1155

Received By: (Signature)

Date/Time

6-8-83 1155



Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Billing Address:

MONTEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcambell@monteau.org

5100316



Moniteau School District

Administrative Offices
1810 West Sunbury Road
West Sunbury, PA 16061
(724) 637-2117
Fax (724) 637-3862

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.55	060823	801		060823	D	1155	32382	23F1056-01	BROWNKA_255
5100316	1013	FREE CHLORINE	301	0.73	060123	802		060123	D	1135	32382	23F0109-01	BROWNKA_33
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060223	802		060123	D	1135	32382	23F0109-01	BROWNKA_34



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F1955
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23F1955-01	Drinking Water	06/15/2023 11:25	6/15/23 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 83-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/19/2023 11:41

Lab Sample ID#: 23F1955-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 06/15/2023 11:25
Receipt Date: 06/15/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.580	mg/L		0.200	PS	06/15/23 11:25	06/15/23 11:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 of 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 483-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NO 431
Mo (57)
FA



DIVISION
16
-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 500	7301955	6/15/23	1125	DW	Field	Field	Free Chlorine 0.58 mg

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) 6/15/23 1125 Date/ Time 6/15/23 1140

Relinquished By: (Signature) 6/15/23 1125 Date/ Time 6/15/23 1140

Relinquished By: (Signature) Date/ Time

Relinquished By: (Signature) Date/ Time

Relinquished By: (Signature) Date/ Time

Received By: (Signature) Date/ Time 6/15/23 1140

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Company Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD

Contact Person: WEST SUNBURY, PA 16061

Phone Number: JEFFREY CAMPBELL

Cell Phone: 724-406-4426

Email Address: jcampbell@moniteau.org

Billing Address: 5100316

PWSID: 5100316

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.58	061523	803		061523	D	1125	32382	23F1955-01	BROWI 324



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F2766
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23F2766-01	Drinking Water	06/22/2023 10:45	6/22/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/28/2023 13:16

Lah Sample ID#: 23F2766-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 06/22/2023 10:45
Receipt Date: 06/22/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.48	mg/L		0.200	PS	06/22/23 10:45	06/22/23 10:45

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.58	061523	803		061523	D	1125	32382	23F1955-01	BROWN 324
5100316	1013	FREE CHLORINE	301	1.48	062223	804		062223	D	1045	32382	23F2766-01	BROWN 751

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1603 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1275 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

DE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: 804	2372726	67223	1045	DW	Field	Field	Free Chlorine 1.48

ROTATION

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) *[Signature]* Date/Time 6/22/23 1045
 Relinquished By: (Signature) *[Signature]* Date/Time 6/22/23 1330

Relinquished By: (Signature) _____ Date/Time _____
 Relinquished By: (Signature) _____ Date/Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Company Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: icampbell@moniteau.org
 Email Address: icampbell@moniteau.org
 Billing Address: 5100316
 PWSID: 5100316



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

30 June 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23F3447
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23F3447-01	Drinking Water	06/29/2023 09:35	6/29/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/30/2023 15:52

Lab Sample ID#: 23F3447-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 06/29/2023 09:35
Receipt Date: 06/29/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-II				Prep Method: No Prep - Field			
Chlorine, Free	0.610	mg/L		0.200	PS	06/29/23 09:35	06/29/23 09:35

Page 1 of 1

NORTHWEST DIVISION
950 Main Street
Sharnsville, PA 16
(724) 453-TEST
FAX: (724) 455-4209

Analysis Requested

Free Chlorine 0.61 mg/L

Wk 5 - 802 Room 617 Sink

Notes/Special Instructions:

23F3447

MONTEAU SCHOOL DISTRICT

WEST SUNBURY, PA 16061

1

icarnpbell@moniteau.org

5100316



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.61	062923	802		062923	D	0935	32382	23F3447-01	BROW 1052
5100316	1013	FREE CHLORINE	301	0.58	061523	803		061523	D	1125	32382	23F1955-01	BROW 324
5100316	1013	FREE CHLORINE	301	1.48	062223	804		062223	D	1045	32382	23F2766-01	BROW 751