



13035 SW Pacific Hwy
Tigard, OR 97223
Tel: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2015

Received: 09/08/2015

Sampled By:

Work Order: 5251024

C David Douglas School District

L Attn:

I 11300 NE Halsey St

E Portland OR, 97220

N Phone: (503) 252-2900

T

Project: -

Project #: N/A

PWSID #: -

Sampling Location: South High School

Sample Matrix: Water

Lab Number	Sample Name	Sampled: 9/8/15 12:00	Sample Composition:
5251024-01	Main DW		

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	09/15/15 16:32

Lab Number	Sample Name	Sampled: 9/8/15 12:05	Sample Composition:
5251024-02	DF-1 #1 @ S Gym		

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	09/15/15 16:32

Lab Number	Sample Name	Sampled: 9/8/15 12:00	Sample Composition:
5251024-03	DF-1 #1 @ #239		

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
+Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	09/15/15 16:32

ND = None detected

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit

+All procedures for this analysis conform to NELAP standards.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.