



13035 SW Pacific Hwy
Tigard, OR 97223
Tel: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2015
Received: 09/08/2015
Sampled By: Max Roccoforte
Work Order: 5251025

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland, OR, 97220
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -

Sampling Location: Menlo Park
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 9/8/15 6:45		Sample Composition:				
5251025-01	Main CW							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.017	0.002	0.015	-	09/15/15 16:32 MCLE

Lab Number	Sample Name	Sampled: 9/8/15 11:00		Sample Composition:				
5251025-02	Bubbler @ 8							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	09/15/15 16:32

Lab Number	Sample Name	Sampled: 9/8/15 11:15		Sample Composition:				
5251025-03	DF-a @ (A) Hall							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	09/15/15 16:32

ND = None detected MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

MCLE This analyte exceeds the MCL limit.

†All procedures for this analysis conform to NELAC standards.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.