



13035 SW Pacific Hwy
Tigard, OR 97223
Tel: (503) 638-9311 Fax: (503) 684-1588

Professional Laboratory Services

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2015

Received: 09/08/2015

Sampled By: Max Roccoforte

Work Order: 5251023

C David Douglas School District

L Attn: -

I 11300 NE Halsey St

E Portland OR, 97220

N Phone: (503) 252-2900

T

Project: -

Project #: N/A

PWSID #: -

Sampling Location: Ventura Park

Sample Matrix: Water

Lab Number	Sample Name	Sampled: 9/8/15 7:12	Sample Composition:
5251023-01	Bubbler @ Rm 8		

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	09/15/15 16:32

Lab Number	Sample Name	Sampled: 9/8/15 7:00	Sample Composition:
5251023-02	Main CW		

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.026	0.002	0.015	-	09/15/15 16:32 MCLE

Lab Number	Sample Name	Sampled: 9/8/15 7:15	Sample Composition:
5251023-03	DF-1 (West)		

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	09/15/15 16:32

ND = None detected

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit

MCLE This analyte exceeds the MCL limit.

†All procedures for this analysis conform to NELAC standards.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.