



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077

Fax: (856) 205-0413

1/5/2023

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2022. The results are tabulated on the attached data pages for the following client designated project:

Logan Twp Elementary School (NJ-DOE)

The reference number for these samples is EMSL Order #012215268. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012215268

CustomerID: EPIC62

CustomerPO: (22-3128)

ProjectID:

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
Fax: (856) 205-0413
Received: 12/20/2022 01:40 PM

Project: **Logan Twp Elementary School (NJ-DOE)****Analytical Results**

Client Sample Description LEMS-FB **Collected:** 12/17/2022 7:39:00 AM **Lab ID:** 012215268-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	12/28/2022 JW	12/28/2022 JW 18:23

Client Sample Description LEMS-DW-128 **Collected:** 12/17/2022 7:41:00 AM **Lab ID:** 012215268-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.29	1.00 ppb	12/28/2022 JW	12/28/2022 JW 18:25

Client Sample Description LEMS-DW-123 **Collected:** 12/17/2022 7:43:00 AM **Lab ID:** 012215268-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	61.1	1.00 ppb	12/28/2022 JW	12/28/2022 JW 18:33

Client Sample Description LEMS-DW-123 (FLUSH) **Collected:** 12/17/2022 7:44:00 AM **Lab ID:** 012215268-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.62	1.00 ppb	12/28/2022 JW	12/28/2022 JW 18:40

Client Sample Description LEMS-DW-124 **Collected:** 12/17/2022 7:45:00 AM **Lab ID:** 012215268-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.06	1.00 ppb	12/28/2022 JW	12/28/2022 JW 18:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012215268

CustomerID: EPIC62

CustomerPO: (22-3128)

ProjectID:

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
Fax: (856) 205-0413
Received: 12/20/2022 01:40 PM

Project: **Logan Twp Elementary School (NJ-DOE)**

Analytical Results

Client Sample Description LEMS-DW-125**Collected:** 12/17/2022
7:47:00 AM**Lab ID:** 012215268-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.32	1.00 ppb	12/28/2022 JW	12/28/2022 JW 18:46

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results