

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for March 2023

**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST

ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

FACILITY: MONTEAU JR SR HIGH SCHOOL

LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

STAGE: Final Effluent

PA0091341	
PERMIT NUMBER	

001	
OUTFALL NUMBER	

Reporting Frequency: Monthly

DMR Effective From: 03/01/2023

DMR Effective To: 03/31/2023

Permit Expires: 01/31/2028

Permit Application Due: 09/04/2027

No Discharge: ☐

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	03	01	2023	03	31
FROM			TO		

PARAMETER	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	VALUE	UNITS	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.88	***	mg/L	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		4.0	***	mg/L	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	***		Daily Min	***		Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		6.0	***	S.U.	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		Daily Min	***		2/month	Grab
	PERMIT REQUIREMENT	***		<5.0	***	mg/L	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		30.0	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		IMAX	***	mg/L	2/month	Grab
Ultraviolet light Intensity (49907)	SAMPLE MEASUREMENT	***		Monitor & Report	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Avg Mo	***	mg/L	2/month	Grab
Flow (50050)	SAMPLE MEASUREMENT	***		5.54	***	µm/cm²	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		Monitor & Report	***	µm/cm²	Daily when Discharging	Grab
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		Avg Mo	***		1/week	Measured
	PERMIT REQUIREMENT	***		***	***		1/week	Measured
	SAMPLE MEASUREMENT	***		<1.0	***	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***		2000	***	No./100 ml	2/month	Grab
	SAMPLE MEASUREMENT	***		Geo Mean	***	IMAX	2/month	Grab
	PERMIT REQUIREMENT	***		10000	***	IMAX	2/month	Grab

**COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD ₅) (80082)	SAMPLE MEASUREMENT	***	***		***	3.7	7.4		2/month	Grab
	PERMIT REQUIREMENT	***	***		***	25.0 Avg Mo	50.0 MAX	mg/L	2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Mon, Apr 17, 2023 at 10:32 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 03/01/2023-03/31/2023

Report Due Date: 04/28/2023

Submitted By: Jeffrey Campbell

Submission Id: 387927

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: March 2023

Flow	$107,428 \text{ GLs.} \div 31 = 3,465$ Daily Avg		
UV Light	$127.6 \div 23 = 5.54$ Daily Avg		
		Basin #	Date
PH Low	7.00	2	3/30/23
PH High	8.63	1	3/15/23
D. O. Low	7.86	2	3/23/23
D. O. High	10.11	1	3/15/23

Date:	3/2/23	3/16/23	SUB TOTAL	$\div 2$	AVG. TOTAL
Total Nitrogen	33.8	7.87	41.67	20.83	20.83
TSS	<5	<5	—	—	<5
TKN	4.5	1.22	5.72	2.86	2.86
Nitrate/Nitrate	29.3	6.64	35.94	17.97	17.97
Phos	4.2	1.0	5.2	2.6	2.6
CBOD	5.4	<2.00	7.4	3.7	3.7
Fecal	<1	<1	—	—	<1
Ammonia	<0.329	<0.329	—	—	<0.329

--	--

March 2023

[illegible]



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

16 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0241
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23C0241-01	Waste Water	03/02/2023 10:00	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

SS Seed Control did not meet reference method acceptance criteria.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/16/2023 11:02

Lab Sample ID#: 23C0241-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 03/02/2023 10:00
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	33.8	mg/L			2.70	DAA	03/10/23 11:00	03/13/23 13:16
General Chemistry	Analytical Method: ASTM6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	03/13/23 21:34	03/13/23 21:34
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	4.50	mg/L			0.625	DAA	03/10/23 11:00	03/13/23 13:16
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	APC	03/09/23 11:30	03/09/23 17:00
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	29.3	mg/L			2.08	AW	03/09/23 11:22	03/09/23 11:22
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem		
Phosphorus	4.2	mg/L			1.0	AW	03/09/23 13:40	03/09/23 13:40
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	>5.4	mg/L	SS		2.00	ATJ	03/03/23 15:31	03/08/23 10:22
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	AMB	03/02/23 14:53	03/03/23 11:45



SAMPLE RECEIPT AND REVIEW FORM

Client: Monterey



23C0241

PART A: GENERAL INFORMATION- SATELLITE LABO

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other:	Received on Ice? YES NO
Sample Receipt Temperature: °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>MD / W382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>3/2/23 1350</u>	Date Sampled: <u>3/2/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other:	
Sample Receipt Temperature: <u>2.8</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other:	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time
Chain of custody documents included with samples?	YES NO		
COC form is properly signed in relinquished/received sections?	YES NO		
Sample containers intact and sealed?	YES NO		
Number of containers received matches number indicated on COC?	YES NO		
Sample IDs on COC match IDs on bottles?	YES NO		
Date and time on COC match date and time on bottles?	YES NO		
Samples received within holding time?	YES NO		
Samples received at appropriate pH for analysis requested?	YES NO		
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO		
Adequate sample volume received?	YES NO		
VOA vials free of headspace (defined as < 6 mm bubble)?	YES <u>NO</u>		
Other Comments:	Deficiency Log Created: YES <u>NO</u>		

Effective Date:

GP.25.A-1 Sample Receipt Log

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 3

FOR INTERNAL LABORATORY USE ONLY

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (1.8% PER ANNUM (BY LAW)). THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT, AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Wastewater

MONTEAU SCHOOL DISTRICT

JEFFREY CAMPBELL

1810 WEST SUNBURY ROAD

201 105 111
201 105 111

724-406-4426

campbell@moniteau.org

Page 3 of 4



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

03 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1690
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23C1690-01	Waste Water	03/16/2023 10:00	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

SS	Seed Control did not meet reference method acceptance criteria.
MH	Matrix Spike recovery exceeded the laboratory acceptance criteria; result may be biased high.
G	CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
BB	Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL	Reporting Limit
CFU	Colony Forming Units
MDL	Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/03/2023 13:55

Lab Sample ID#: 23CI690-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 03/16/2023 10:00
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	7.87	mg/L			1.14	DAA	03/22/23 13:10	03/23/23 16:43
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	03/24/23 23:17	03/24/23 23:17
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	1.22	mg/L			0.625	DAA	03/22/23 08:45	03/23/23 16:43
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	APC	03/23/23 10:27	03/23/23 12:39
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	6.64	mg/L	MH		0.520	AW	03/22/23 13:10	03/22/23 13:10
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem		
Phosphorus	1.0	mg/L			0.10	AW	03/22/23 11:35	03/22/23 11:35
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, G, SS		2.00	EMH	03/16/23 16:35	03/21/23 12:45
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	AMB	03/16/23 15:48	03/17/23 11:10

SAMPLE REQUEST & CHAIN OF CUSTODY

TEL: (724) 465-4209



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work Or  23C1690
-------------------------	--

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>DM / 00382</u>	Samples Received on Ice? (YES) NO
Date/Time Received: <u>3/16/23 1530</u>	Date Sampled: <u>3/16/23</u>
Method of Delivery: FedEx UPS Client Drop off (ESL courier) Other: _____	
Sample Receipt Temperature: <u>3.0</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: (PA) NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES (NO)

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria		Signature _____ Date / / Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	(YES) NO		Comments:
COC form is properly signed in relinquished/received sections?	(YES) NO		Comments:
Sample containers intact and sealed?	(YES) NO		Circle Applicable: Damaged Container Custody Seal Broken Other: _____ Leaking Container
Number of containers received matches number indicated on COC?	(YES) NO		Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	(YES) NO		Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	(YES) NO		Sample IDs and Containers Affected:
Samples received within holding time?	(YES) NO		Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	(YES) NO		Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	(YES) NO		For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	(YES) NO		Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES (NO)		Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES (NO)	

Effective Date:

GP.25.A-1 Sample Receipt Log

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for March 2023

MONTEAU HIGH SCHOOL WATER TREATMENT PLANT													
MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
March	1	Ned	50.9	10.07	7,624,559	0.79	0.83	7.0	0.00	0	1.18	Jeff C	9:00 AM
	2	Thurs	52.7	8.57	7,624,559	0.79	0.84	7.0	0.00	0	1.17	Jeff C	9:30 AM
	3	Fri	55.2	10.67	7,636,365	0.76	0.81	7.1	0.00	0	1.36	Jeff C	1:00 AM
	4	SAT											
	5	SUN											
	6	Mon	50.5	9.00	7,636,365	0.75	0.81	7.1	0.00	0	1.35	Jeff C	10:00 AM
	7	Tues	56.0	10.95	7,649,758	0.73	0.79	7.1	0.00	0	1.19	Jeff C	3:00 PM
	8	Wed	53.2	10.05	7,649,758	0.73	0.79	7.1	0.00	0	1.18	Jeff C	8:30 AM
	9	Thurs	55.1	10.64	7,657,887	0.69	0.77	7.2	0.01	0	2.01	Jeff C	11:00 AM
	10	Fri	56.1	10.67	7,663,252	0.70	0.77	7.2	0.01	0	1.99	Jeff C	10:00 AM
	11	SAT											
	12	SUN											
	13	Mon	50.0	11.88	7,675,884	0.72	0.78	7.0	0.00	0	1.68	Jeff C	8:00 AM
	14	Tues	50.0	10.69	7,675,884	0.72	0.78	7.0	0.00	0	1.68	Jeff R	11:30 AM
	15	Wed	46.1	8.86	7,675,884	0.72	0.78	7.0	0.00	0	1.65	Jeff C	1:00 PM
	16	Thurs	49.0	8.25	7,676,425	0.71	0.77	7.0	0.00	0	1.63	Jeff C	9:30 AM
	17	Fri	54.5	10.95	7,687,258	0.73	0.79	7.0	0.00	0	1.19	Jeff C	9:00 AM
	18	SAT											
	19	SUN											
	20	Mon	51.9	11.92	7,698,584	0.69	0.76	7.2	0.01	0	1.70	Jeff C	9:30 AM
	21	Tues	51.6	10.01	7,698,584	0.70	0.76	7.2	0.01	0	1.68	Jeff C	9:30 AM
	22	Wed	51.4	8.19	7,698,584	0.70	0.76	7.2	0.01	0	1.68	Jeff C	9:30 AM
	23	Thurs	56.0	11.21	7,711,099	0.71	0.77	7.1	0.01	0	1.26	Jeff C	9:30 AM
	24	Fri	55.6	9.09	7,711,099	0.70	0.77	7.1	0.01	0	1.26	Jeff C	10:00 AM
	25	SAT											
	26	SUN											
	27	Mon	55.7	9.82	7,721,866	0.52	0.66	7.1	0.01	0	0.71	Jeff C	3:00 PM
	28	Tues	55.5	8.73	7,721,866	0.52	0.66	7.1	0.01	0	0.70	Jeff C	5:00 AM
	29	Wed	56.6	11.09	7,731,987	0.51	0.63	7.0	0.01	0	1.56	Jeff R	11:45 AM
	30	Thurs	54.1	9.07	7,731,987	0.52	0.62	7.1	0.00	0	1.43	Jeff R	11:45 AM
	31	Fri	55.1	8.18	7,731,987	0.52	0.63	7.1	0.00	0	1.47	Jeff C	8:00 AM

2/28/23 Meter Reading.
7,624,559

= WATER Test Days = Sewage Test Days



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0268
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23C0268-01	Drinking Water	03/02/2023 11:50	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:11

Lab Sample ID#: 23C0268-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 03/02/2023 11:50
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11					Prep Method: No Prep - Field		
Chlorine, Free	0.800	mg/L		0.200	PS	03/02/23 11:50	03/02/23 11:50
Microbiology							
Analytical Method: SM 9223 B-16					Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorthis, PA 15366
(724) 258-TEST
FAX: (724) 258-6376

NORTHERN DIVISION
435 Broad Street
Montonsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification
CIRCLE ONE:
704 KITCHEN MAIN SINK
802 ROOM-204 SINK

ESL#
23C0268

Sample Type
Grab
Date
Time

Matrix

of Bottles

Container Type
Preservative

Analysis Requested

3/23 1150
DW
1
STERILE PLASTIC
NA THIO

TC/EC
Free Chlorine 0.80



23C0268

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

MONITEAU SCHOOL DISTRICT

1810 WEST SUNBURY ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcampbell@moniteau.org

5100324

3/23 1150

3/23 1150

3/23 1150

3/23 1150

3/23 1150

3/23 1150

3/23 1150

Correct Preservations (Y/N/NA) Correct Containers (Y/N/NA) Receipt Temperature 3.1 °F

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA 182



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0268
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23C0268-01	Drinking Water	03/02/2023 11:50	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04680

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:11

Lab Sample ID#: 23C0268-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 03/02/2023 11:50
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.800	mg/L		0.200	PS	03/02/23 11:50	03/02/23 11:50
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4208	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharpsville, PA 16150 (724) 463-TEST FAX: (724) 465-4208
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM-204 SINK	ESL# 23C0268	Sample Type Grab Date 3/23/11		Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC / EC Free Chlorine 0.80



23C0268

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS O.D.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Monthly

Notes/Special Instructions:

Company Name: MONITEAU SCHOOL DISTRICT	
Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061	
Contact Person: JEFFREY CAMPBELL	
Phone Number: 724-406-4426	
Call Phone: jcampbell@moniteau.org	
Billing Address: 5100324	
PWSID:	

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1077
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23C1077-01	Drinking Water	03/09/2023 11:45	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNK 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNK 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNK 182

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharps
(724) 4
FAX: (



23C1077

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>23C1077</u>	Date	Time	DW	Field	Field	Free Chlorine <u>0.72</u> mg/L
ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u>				Received By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145 0730</u> Received By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u> Received By: (Signature) <u>[Signature]</u> Date/ Time <u>3-9-23 1145</u>			
Correct Preservations Y/N <u>(NA)</u> Correct Containers Y/N <u>(NA)</u> Receipt Temperature <u>—</u>				Drinking Water Moniteau Jr/Sr - Weekly Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.org Billing Address: 5100324 PWSID:			



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monitorsville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1077-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 03/09/2023 11:45
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.720	mg/L		0.200	PS	03/09/23 11:45	03/09/23 11:45



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1077
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23C1077-01	Drinking Water	03/09/2023 11:45	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1077-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 03/09/2023 11:45
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.720	mg/L		0.200	PS	03/09/23 11:45	03/09/23 11:45

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bendleyville Road
Van Voorhis, PA 15368
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-0003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharps
(724) 4
FAX: (

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23C1077	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: <u>802</u>	<u>on</u>	Date <u>3-9-23</u> Time <u>1145</u>	DW	Field	Field	Free Chlorine <u>0.72</u> mg/L

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (10% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Weekly

Notes/Special Instructions:

Sampled By: (Signature) <u>[Signature]</u>	Date/ Time <u>3-9-23 1145</u>	Company Name: MONITEAU SCHOOL DISTRICT
Relinquished By: (Signature) <u>[Signature]</u>	Date/ Time <u>3-9-23 1145</u>	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061
Relinquished By: (Signature)	Date/ Time	Contact Person: JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Phone Number: 724-406-4426
Relinquished By: (Signature)	Date/ Time	Cell Phone: jcampbell@moniteau.org
Relinquished By: (Signature)	Date/ Time	Billing Address: 5100324
Correct Preservations Y/N <u>NA</u>	Correct Containers Y/N <u>NA</u>	Receipt Temperature <u>—</u>

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04680

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1754
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23C1754-01	Drinking Water	03/16/2023 11:28	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:51

Lab Sample ID#: 23C1754-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 03/16/2023 11:28
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.780	mg/L		0.200	PS	03/16/23 11:28	03/16/23 11:28

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 of 1

FAX: (724) 465-4200

18THWEST DIVISION
D Main Street
Lapspville, PA 16
24) 463-TEST

FOR INTERNAL LABORATORY USE ONLY

ESL# 25C17561

Sample Type	
Grab	
Date	Time
5/6/23	1128

Field

Field

Free Chlorine 0.78 mg/L

WK 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Date/ Time

Date/ Time

Date/ Time

Correct Containers Y / N NA

Receipt Temperature _____

MONTEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

icampbell@moniteau.org

5100324

Page 3 of 4

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA_871



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1747
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23C1747-01	Drinking Water	03/16/2023 11:05	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:49

Lab Sample ID#: 23C1747-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 03/16/2023 11:05
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11							
Chlorine, Free	0.660	mg/L		0.200	PS	03/16/23 11:05	03/16/23 11:05
Prep Method: No Prep - Field							

SAMPLE REQUEST & CHAIN OF CUSTODY

Page _____ of _____

FAX: (724) 465-4209

FAX: (724) 258-8376

FAX: (570) 321-1957

25C1/41

0301747

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL#

Sample Type	Grab
-------------	------

Matrix

of Bottles

Container Type

Analysis Requested

Distribution: 803

9

37627 1115

Dw

Field

pid

Free Chlorine 0.16 mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

YK 3 - 803 Room 606 Sink

WK 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2 THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY

MONITEAU SCHOOL DISTRICT

Sampled By: (Signature)	Date/ Time
-------------------------	------------

26-10-20

(

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

1

MONITEAU SCHOOL DISTRICT

Address:
391 HOOKER ROAD

WEST SUNBURY, PA 16061

Phone Number _____
Contact Person _____
City/State/Zip _____

Cell Phone: 724-406-4426

Billing Address:
Carmichael, CA 95608

PWSID: 5100316

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monitorsville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1754
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23C1754-01	Drinking Water	03/16/2023 11:28	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 483-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:51

Lab Sample ID#: 23C1754-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 03/16/2023 11:28
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.780	mg/L		0.200	PS	03/16/23 11:28	03/16/23 11:28

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1275 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 256-6376

23C1754

IRTHWEST DIVISION
D Main Street
Jupersville, PA 16
(24) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23C1754	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: 803			5/6/23	DW	Field	Field	Free Chlorine 0.78 mg/L

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) 	Date/ Time 11/28	Company/Name: MONITEAU SCHOOL DISTRICT
Relinquished By: (Signature) 	Date/ Time 12/19	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID:
Relinquished By: (Signature)	Date/ Time	724-406-4426 jcampbell@moniteau.org
Relinquished By: (Signature)	Date/ Time	5100324
Correct Preservations Y/N (N/A)	Correct Containers Y/N (N/A)	Receipt Temperature

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA_871



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2329
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23C2329-01	Drinking Water	03/23/2023 10:40	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:29

Lab Sample ID#: 23C2329-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 03/23/2023 10:40
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	PS	03/23/23 10:40	03/23/23 10:40

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA_871
5100324	1013	FREE CHLORINE	301	0.64	032323	804		032323	D	1040	32382	23C2329-01	BROWNKA_1259

ENVIRONMENTAL SERVICE LABORATORIES, INC.

S,

HEADQUARTER

1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION

1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-9376

NORTHERN

435 Broad St.
Montoursville
(570) 321-6
FAX: (570)



3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL # 25075-20	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: 804	on	3/23/83	1040	DW	Field	Field	Free Chlorine 0.64 mg/L
ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW). 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, PERSONAL ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Company/Name: MONTEAU SCHOOL DISTRICT			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Address: 391 HOOKER ROAD			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Contact Person: WEST SUNBURY, PA 16061			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Phone Number: JEFFREY CAMPBELL			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Cell Phone: 724-406-4426			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Email Address: jcampbell@monteau.org			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/23/83 1040				Billing Address: 5100324			
Correct Preservations Y/N <i>(N)</i>				Correct Containers Y/N <i>(N)</i>			
Receipt Temperature <i>---</i>				Notes/Special Instructions: <i>Drinking Water Monteau Jr/Sr - Weekly</i>			



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 March 2023

Monitcau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2329
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23C2329-01	Drinking Water	03/23/2023 10:40	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:29

Lab Sample ID#: 23C2329-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 03/23/2023 10:40
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11							
Chlorine, Free	0.640	mg/L		0.200	PS	03/23/23 10:40	03/23/23 10:40
Prep Method: No Prep - Field							

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA 182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA 871
5100324	1013	FREE CHLORINE	301	0.64	032323	804		032323	D	1040	32382	23C2329-01	BROWNKA 1259

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN
435 Broad St.
Montoursville
(570) 321-9
FAX: (570)

23C2329

FOR INTERNAL LABORATORY USE ONLY

Page 1 of 1

Sample Identification

ESL#
23C2329

Distribution: SO4

Sample Type
Grab

Matrix

of Bottles

Container Type
Preservative

Analysis Requested

Date

Time

DW

Field

Field

Free Chlorine @ .62 mg/L

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Monticau Jr/Sr - Weekly

Sampled By: (Signature)

3/23/83 1840

Date/ Time

Relinquished By: (Signature)

3/23/83 1840

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Correct Preservations Y / N (N)

Correct Containers Y / N (N)

Receipt Temperature

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

MONTICAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcambell@monticau.org

5100324



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-6378 x 500
F: (724) 465-4209
PADEP: 43-04834

03 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2932
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23C2932-01	Drinking Water	03/30/2023 10:50	3/30/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-8002
F: (570) 321-1967
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/03/2023 16:30

Lab Sample ID#: 23C2932-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler:
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 03/30/2023 10:50
Receipt Date: 03/30/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.530	mg/L			Client	03/30/23 10:50	03/30/23 10:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	☒	SOUTHERN DIVISION 1276 Benleyville Road Van Vleet, PA 15366 (724) 258-TEST FAX: (724) 258-8376	☐	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	☐	NORTHWEST DIVISION 950 Main Street Sharpville, PA 16 (724) 463-TEST FAX: (724) 465-4209	☐
---	-------------------------------------	---	--------------------------	--	--------------------------	--	--------------------------

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 804	23C2932	3-30-23	1650	DW	Field	Field	Free Chlorine 0.53 mg/L

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

23C2932

THE UNDERSIGNED PURCHASER/PROPERTY AGREE TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Monticau Jr/Sr - Weekly

THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
 THE UNDERSIGNED PURCHASER/PROPERTY AGREE TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY
 ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

MONTEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

icampbell@monticau.org

5100324

Sampled By: (Signature) *[Signature]* Date/Time 3-30-23 1650
 Relinquished By: (Signature) *[Signature]* Date/Time 3-30-23 1330

Received By: (Signature) *[Signature]* Date/Time 3/30/23 1530

Received By: (Signature) Date/Time

Received By: (Signature) Date/Time

Correct Preservations Y/N/NA

Correct Containers Y/N/NA

Receipt Temperature



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA 182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA 871
5100324	1013	FREE CHLORINE	301	0.64	032323	804		032323	D	1040	32382	23C2329-01	BROWNKA 1259
5100324	1013	FREE CHLORINE	301	0.53	033023	804		033023	D	1050	32382	23C2932-01	BROWNKA 1972

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for March 2023

Dassa McKinney Elementary School Water Treatment Facility											
Month	Mar.	2023									
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes	
1	Wed	8.7	0.02	0.58	0.66	3.12	13999800	Jeff R	4:30P	4000	
2	Thurs	8.7	0.00	0.77	0.87	2.89	14003700	Jeff R	3:30P	3900	
3	Fri	8.7	0.02	0.76	0.86	1.95	14007600	Jeff R	4:30P	3900	
4	Sat										
5	Sun										
6	Mon	8.7	0.00	0.57	0.64	2.11	14011500	Jeff R	5:00P	3900	
7	Tues	8.7	0.01	0.63	0.71	2.18	14015300	Jeff R	5:00P	3800	
8	Wed	8.7	0.01	1.11	1.24	3.13	14019000	Jeff R	4:00P	3700	
9	Thurs	8.7	0.00	0.59	0.67	3.35	14025300	Jeff R	4:30P	6300	
10	Fri	8.7	0.02	0.61	0.70	2.57	14027800	Jeff R	4:30P	2500	
11	Sat										
12	Sun										
13	Mon	8.7	0.00	0.67	0.75	2.66	14031400	Jeff R	4:30P	3600	
14	Tues	8.7	0.02	0.72	0.82	2.81	14035000	Jeff R	4:30P	3600	
15	Wed	8.7	0.01	0.70	0.78	3.08	14039000	Jeff R	4:30P	4000	
16	Thurs	8.7	0.02	0.57	0.63	3.25	14042600	Jeff R	4:30P	3600	
17	Fri	8.7	0.00	0.59	0.66	3.28	14046400	Jeff R	4:30P	3800	
18	Sat										
19	Sun										
20	Mon	8.7	0.03	0.73	0.78	3.01	14050100	Jeff R	4:30P	3700	
21	Tues	8.7	0.00	0.86	0.96	3.22	14053900	Jeff R	3:30P	3800	
22	Wed	8.7	0.02	0.82	0.91	3.25	14058100	Jeff R	4:30P	4200	
23	Thurs	8.7	0.02	0.78	0.85	3.69	14062200	Jeff R	4:30P	4100	
24	Fri	8.7	0.00	0.80	0.88	3.45	14066000	Jeff R	4:30P	3800	
25	Sat										
26	Sun										
27	Mon	8.7	0.02	0.73	0.83	2.64	14069900	Jeff R	4:30P	3900	
28	Tues	8.7	0.00	0.74	0.81	2.75	14073900	Jeff R	4:30P	4000	
29	Wed	8.7	0.01	0.71	0.79	2.82	14078200	Jeff R	4:30P	4300	
30	Thurs	8.7	0.00	0.73	0.81	3.17	14080200	Jeff R	12:00P	2000	
31	Fri	8.7	0.02	0.73	0.80	3.28	14086300	Jeff R	4:30P	6100	

Meter Reading 2/28/23 - 13995800



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0267
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23C0267-01	Drinking Water	03/02/2023 11:36	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:12

Lab Sample ID#: 23C0267-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 03/02/2023 11:36
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.840	mg/L		0.200	PS	03/02/23 11:36	03/02/23 11:36
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorth, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
801 KITCHEN SINK 802 ROOM 617 SINK	73C0367	Grab	Time	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.84 mg/L



23C0267

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

Notes/Special Instructions:

Sampled By: (Signature) [Signature] Date/ Time 3-2-23 11:36a
Relinquished By: (Signature) [Signature] Date/ Time 3-2-23 11:43

Relinquished By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations (Y) / N / NA

Correct Containers (Y) / N / NA

Receipt Temperature 3.1 #3

Company Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

MONITEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcampbell@moniteau.org

5100316

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA 177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA 178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA 179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0267
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23C0267-01	Drinking Water	03/02/2023 11:36	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:12

Lab Sample ID#: 23C0267-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 03/02/2023 11:36
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-C1 G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/02/23 11:36	03/02/23 11:36
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharpville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
801 KITCHEN SINK	7300367	Grab				STERILE PLASTIC	TC / EC
802 ROOM 617 SINK	CA	Date	Time	DW	1	NA THIO	Free Chlorine 0.84 mg/L



23C0267

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

Notes/Special Instructions:

Sampled By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time

Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time

Correct Preservations ☒ N / NA Correct Containers ☒ N / NA Receipt Temperature 3.1 #3

Company/Name:	MONITEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Contact Person:	
Phone Number:	724-406-4426
Cell Phone:	
Email Address:	campbell@moniteau.org
Billing Address:	
PWSID:	5100316

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0267
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23C0267-01	Drinking Water	03/02/2023 11:36	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:12

Lab Sample ID#: 23C0267-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 03/02/2023 11:36
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/02/23 11:36	03/02/23 11:36
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4208	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharpville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	73C0367 CA	3-2-23	11:36	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.84 mg/L



23C0267

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

Notes/Special Instructions:

Sampled By: (Signature) 3-2-23 11:36 Date/ Time		Company/Name: MONITEAU SCHOOL DISTRICT	
Relinquished By: (Signature) 3-2-23 11:43 Date/ Time		Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL	
Relinquished By: (Signature) _____ Date/ Time		Contact Person: _____ Phone Number: _____	
Relinquished By: (Signature) _____ Date/ Time		Cell Phone: 724-406-4426 Email Address: jcampbell@moniteau.org	
Correct Preservations (Y) N / NA		Billing Address: _____ PWSID: 5100316	
Correct Containers (Y) N / NA		Receipt Temperature 31.43	

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monitorsville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1076
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23C1076-01	Drinking Water	03/09/2023 11:27	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1076-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 03/09/2023 11:27
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	1.08	mg/L		0.200	PS	03/09/23 11:27	03/09/23 11:27

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVI
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-1000



23C1076

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>23C1076</u>	<u>3923</u>	<u>1127</u>	DW	Field	Field	Free Chlorine <u>1.08</u> mg/L
ROTATION Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (12% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Notes/Special Instructions: <i>Drinking Water Dassa McKinney - Weekly</i>				Company Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcambell@moniteau.org 5100316			
Received By: (Signature) <u>[Signature]</u> Date/ Time <u>3/9/23 1410</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3/9/23 1407</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3/9/23 1407</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3/9/23 1407</u> Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3/9/23 1407</u>				Correct Containers Y/N (NA) <u>Y/N (NA)</u> Receipt Temperature <u>—</u>			

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Monitcau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1076
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23C1076-01	Drinking Water	03/09/2023 11:27	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RI. Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



ENVIRONMENTAL
SERVICE LABORATORIES, INC.

1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16160
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1076-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 03/09/2023 11:27
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	1.08	mg/L		0.200	PS	03/09/23 11:27	03/09/23 11:27

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 463-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorchis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIV.
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-1...



23C1076

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>23C1076</u>	<u>3923</u>	<u>1127</u>	DW	Field	Field	Free Chlorine <u>1.68</u> mg/L

ROTATION
Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 3-9-23 11:27
Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 11:27

Received By: (Signature) [Signature] Date/ Time 3-9-23 11:10
Received By: (Signature) [Signature] Date/ Time 3-9-23 11:10
Received By: (Signature) [Signature] Date/ Time 3-9-23 11:10

Correct Preservations Y/N (NA) Correct Containers Y/N (NA) Receipt Temperature ---

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.org
Email Address: jcampbell@moniteau.org
Billing Address: 5100316
PWSID:

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNK 177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNK 178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNK 179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1747
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23C1747-01	Drinking Water	03/16/2023 11:05	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:49

Lab Sample ID#: 23C1747-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 03/16/2023 11:05
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM14500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.660	mg/L		0.200	PS	03/16/23 11:05	03/16/23 11:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 463-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN DIVISION
435 Broad Street
Montourville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



23C1747

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23C1747	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 803	01	3/6/03	1105	DW	Field	Field	Free Chlorine 0.166 mg/L

ROTATION

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (16% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) <i>[Signature]</i> Date/Time 3/6/03 1105 Relinquished By: (Signature) <i>[Signature]</i> Date/Time 3/6/03 1214 Relinquished By: (Signature) Date/Time Relinquished By: (Signature) Date/Time Correct Preservations Y/N <i>NA</i> Correct Containers Y/N <i>NA</i> Receipt Temperature	Company/Name: MONTICAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: 724-406-4426 Email Address: jcampbell@monticau.org Billing Address: 5100316 PWSID:
--	---

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Benlleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2330
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23C2330-01	Drinking Water	03/23/2023 10:15	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monitorsville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:30

Lab Sample ID#: 23C2330-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 03/23/2023 10:15
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.840	mg/L		0.200	PS	03/23/23 10:15	03/23/23 10:15

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870
5100316	1013	FREE CHLORINE	301	0.84	032323	804		032323	D	1015	32382	23C2330-01	BROWNKA_1258

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE #

Page 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHE
435 Broa
Montours
(570) 321
FAX: (570)

FOR INTERNAL LABORATORY USE



23C2330

Sample Identification

ESL# 25C2330

Sample Type

Grab

Matrix

of Bottles

Container Type
Preservative

Analysis Requested

Distribution: 804

32303

DW

Field

Field

Free Chlorine

0.84

mg/L

ROTATION

WK 1 - 801 Kitchen Sink

WK 2 - 802 Room 617 Sink

WK 3 - 803 Room 606 Sink

WK 4 - 804 Room 408 Sink

WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.72% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Sampled By: (Signature)

Date/Time

1015

Company/Name:

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

Relinquished By: (Signature)

Date/Time

1015

Received By: (Signature)

Date/Time

Contact Person:

724-406-4426

jcampbell@monteau.org

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Cell Phone:

724-406-4426

jcampbell@monteau.org

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Billing Address:

PWSID:

5100316

Correct Preservations Y/N (NA)

Correct Containers Y/N (NA)

Receipt Temperature



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2330
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23C2330-01	Drinking Water	03/23/2023 10:15	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:30

Lab Sample ID#: 23C2330-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 03/23/2023 10:15
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11							
Chlorine, Free	0.840	mg/L		0.200	PS	03/23/23 10:15	03/23/23 10:15
Prep Method: No Prep - Field							

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870
5100316	1013	FREE CHLORINE	301	0.84	032323	804		032323	D	1015	32382	23C2330-01	BROWNKA_1258



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

03 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2937
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23C2937-01	Drinking Water	03/30/2023 10:25	3/30/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monitorsville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/03/2023 16:32

Lab Sample ID#: 23C2937-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: 802 Room 617 Sink

Sample Date: 03/30/2023 10:25
Receipt Date: 03/30/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.580	mg/L			Client	03/30/23 10:25	03/30/23 10:25

SAMPLE REQUEST & CHAIN OF CUSTODY

100

FOR INTERNAL LABORATORY USE ONLY

ROTATION

Wk 5 - 802 Room 617 Sink

23C2937

23C2937

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

MONTEAU SCHOOL DISTRICT
391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
724-406-4426
jcambell@monteau.org
5100316

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA 177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA 178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA 179
5100316	1013	FREE CHLORINE	301	0.58	033023	802		033023	D	1025	32382	23C2937-01	BROWNKA 1971
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA 870
5100316	1013	FREE CHLORINE	301	0.84	032323	804		032323	D	1015	32382	23C2330-01	BROWNKA 1258