



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 07/13/2021  
Received: 07/02/2021  
Sampled By:  
Work Order: 1183003

**C** **David Douglas School District**  
**L** Attn: Troy Thompson  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Menlo Park

### Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>1183003-01</b>	<b>Sample Name:</b> 076 WD 1st Draw <b>Sampled:</b> 7/1/21 6:52 <b>Sample Composition:</b> 1st Draw						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	07/08/21 13:21
<b>1183003-02</b>	<b>Sample Name:</b> 076 WD 2st Draw <b>Sampled:</b> 7/1/21 6:55 <b>Sample Composition:</b> 2nd Draw						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	07/08/21 13:21

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

**Note:** Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: \_\_\_\_\_

  
Adriana Gonzalez-Gray  
Laboratory Director



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 07/13/2021  
Received: 07/02/2021  
Sampled By:  
Work Order: 1183004

**C L I E N T** **David Douglas School District**

Attn: Troy Thompson  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**

Project # : N/A  
Sample Type :

Sampling Location: Menlo Park

### Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>1183004-01</b>	<b>Sample Name:</b> #077 Ref Box 1st Draw <b>Sampled:</b> 7/2/21 6:32 <b>Sample Composition:</b> 1st Draw						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	07/08/21 13:21
<b>1183004-02</b>	<b>Sample Name:</b> #077 Ref Box 2nd Draw <b>Sampled:</b> 7/2/21 6:34 <b>Sample Composition:</b> 2nd Draw						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	07/08/21 13:21

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

**Note:** Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: \_\_\_\_\_

  
Adriana Gonzalez-Gray  
Laboratory Director