

(example)

## Weekly Underground Tank Inspection Checklist

Week 12/27/17  
Year GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b>										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b>										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overflow Protection</b>	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overflow alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the delivery of product.	<u>S</u>		<u>S</u>							
<b>Dispensers</b>	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: DANIS  
Date: 12/27/17

--OMNITIC MSG. v1  
TEL: 1(631) 981-2001  
FAX: 1(631) 981-2007  
DELT ID: L1362849

MCUD BOARD SERIAL: 745  
FIRMWARE: OEL3KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-12-27 14:00:01

--SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0X00DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Interstitial:0 P  
S/N:210160712, P/N:BX-PDWF  
4 T 2, Interstitial:0 P  
S/N:210161171, P/N:BX-PDWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstitial:0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 12/15/17  
Year 2017(GAS) DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: DIAMOS  
Date 12/15/17

--ONLINE INFO.: 09:  
TEL: (631) 981-2001  
FAX: (631)-981-2007  
DELS ID: 162849

MCU BOARD SERIAL: 746  
FIRMWARE: 0F1303P002AG  
RELEASE: Nov 17 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-12-16 10:06:15

--SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL W  
3 TURF OIL P

--BX-SENSOR TEST

TOTAL OF BX SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162255 P/N:BX-PDS

2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS

3 T 1, Intersight#:0 P  
S/N:210160712, P/N:BX-PDWF

4 T 2, Intersight#:0 P  
S/N:210160713, P/N:BX-PDWF

5 T 3, Sump#:2 P  
S/N:200162257, P/N:BX-PDS

6 T 3, Intersight#:0 P  
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 12/11/17  
Year 2017

(GAS) (DIESEL)

	Tank # <u>1</u>	Tank # <u>2</u>	Tank #	Tank #	Tank #					
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S								
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S								
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u> S      U	Dispenser # <u>2</u> S      U	Dispenser #	Dispenser #	Dispenser #	Dispenser #	S	U	S	U
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 12/11/17

---UNIFIED LOGIC INC.  
TEL: (563)1-981-2001  
FAX: (563)1-981-2007  
DELS ID: EL162849

MCUB BOARD SERIAL: 745  
FIRMWARE: DEL3KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-12-11 14:00:22

--SLOT: 1  
AB 4 IN ID: 0  
CANBUS START: 0X030E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02  
--PROM TEST P  
--RAM TEST P

--LEVEL PROBE TEST  
T# PRODUCT ID# TEST  
1 GAS P  
2 DIESEL P  
3 FOIL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Samp#1 P  
S/N:200162935, P/N:BX-PDS  
2 T 2, Samp#2 P  
S/N:200162936, P/N:BX-PDS  
3 T 3, Interstic#0 P  
S/N:210160717, P/N:BX-PDWF  
4 T 2, Interstic#0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Samp#2 P  
S/N:200162937, P/N:BX-PDS  
6 T 3, Interstic#0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Samp#1 P  
S/N:200162539, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIR,  
W = WARNING, NK = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 12/4/17  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			S		S					
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			N		N					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.			N		N					
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEAN'D + VACUUM'D / DISPENSERS + SPILL/FILL BX'S

Inspected By: RAMOS  
Date 12/4/17

...@MINTY.COM 201-2001  
TEL. 433-2007  
FAX. 433-2049  
GEL3 INC.

info  
info  
info  
info

TIME: 2017-12-04 14:01:09

--INVENTORY

TANK 1 GAS  
PRODUCT: 36.91(in)  
TOTAL HEIGHT: 0.01(in)  
WATER HEIGHT: 1976.38(Gal)  
TOTAL VOLUME: 0.68(Gal)  
WATER VOLUME: 1980.75(Gal)  
T.C. VOLUME: 56.8(F)  
TEMPERATURE: 2023.61(Gal)  
ULLAGE: 1623.61(Gal)  
90% ULLAGE:

TANK 2 DIESEL  
PRODUCT: 36.91(in)  
TOTAL HEIGHT: 0.01(in)  
WATER HEIGHT: 2043.29(Gal)  
TOTAL VOLUME: 29.18(Gal)  
WATER VOLUME: 2047.09(Gal)  
T.C. VOLUME: 58.0(F)  
TEMPERATURE: 1934.70(Gal)  
ULLAGE: 1554.70(Gal)  
90% ULLAGE:

TANK 3 FULL OIL  
PRODUCT: 73.19(in)  
TOTAL HEIGHT: 0.14(in)  
WATER HEIGHT: 9629.65(Gal)  
TOTAL VOLUME: 31.28(Gal)  
WATER VOLUME: 9635.89(Gal)  
T.C. VOLUME: 58.5(F)  
TEMPERATURE: 9070.35(Gal)  
ULLAGE: 3570.35(Gal)  
90% ULLAGE:

(example)

## Weekly Underground Tank Inspection Checklist

Week 11/27/17  
Year 2017(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			<u>S</u>		<u>S</u>					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			<u>S</u>		<u>S</u>					
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.		<u>N</u>		<u>N</u>						
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		<u>N</u>		<u>N</u>						
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump,ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 11/28/17

--OEMINFO: TEL: (1031)-961-2001  
TEL: (1031)-961-2007  
FAX: (1031)-961-2007  
DE13 ID: E1162649

ECU BOARD SERIAL: 745  
FIRMWARE: DE13KXP002AQ  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-11-28 14:03:11

--SL01: 1  
XB\_41G\_ID: 0  
CANBUS\_START: 0X03DF  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P  
- RAM TEST P

--LEVEL PROBE TEST  
T# PROBEID TYPE TEST  
1 GAS P  
2 DISEL P  
3 FUEL\_OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Samp#1 P  
S/N:200162255, P/N:BX-PDS  
2 T 2, Samp#2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Interstic#0 P  
S/N:21016112, P/N:BX-PDWF  
4 T 2, Interstic#0 P  
S/N:21016113, P/N:BX-PDWF  
5 T 3, Samp#2 P  
S/N:200162567, P/N:BX-PDS  
6 T 3, Interstic#0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Samp#1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week W2017  
Year 2017

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North									
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. alarms must activate and be visible and audible to the deliverer of product.	S		S							
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump,ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #									
	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEANING ON WALL BY'S

Inspected By: RAMOS  
Date 11/20/17

-- DATALOG TESTS --  
TEL: (631) 981-2001  
FAX: (631) 981-2007  
DELS ID: T1162849

MEUB GUARD SERIAL: 745  
FIRMWARE: 0ff13KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2015-11-20 15:53:58

--SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0x03DE  
FIRMWARE: A16\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T# PROBE# [TEST]  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST

TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#1 P  
S/N:200167235, P/N:BX-PDS  
2 T 2, Sump#2 P  
S/N:200167200, P/N:BX-PDS  
3 T 1, Interstic#0 P  
S/N:210160712, P/N:BX-PDWF  
4 T 2, Interstic#0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Sump#2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstic#0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sump#1 P  
S/N:200162536, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 11/13/17  
Year 2017

(GAS) (DIESEL)

	Tank #									
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West	North South East West	North South East West	North South East West	North South East West	North South East West				
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #1	Dispenser #2	Dispenser #	Dispenser #	Dispenser #	Dispenser #				
	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

VACUUM'D BOTH SPILL/FILL BX'S &amp; DISPENSERS

Inspected By: RAMOS  
Date 11/13/17

-- UNMETIC DATA, INC.  
TEL: (1631)-581-2001  
FAX: (1631)-581-2007  
DELS. ID: 01062849

MCU BOARD SERIAL: 745  
FIRMWARE: 0113KXPUD2AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-11-13 11:51:11

--SLOT: 1  
X8-416 ID: 0  
CANBUS SIAKT: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

# PROBE# TIME TEST  
1 GAS P  
2 Diesel P  
3 Fuel Oil P

--BX-SENSOR TEST

TOTAL # BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162476, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162477, P/N:BX-PDS  
3 T 1, Interstic#:0 P  
S/N:210161173, P/N:BX-PDWF  
4 T 2, Interstic#:0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstic#:0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER.

S# = BX-SENSOR NUMBER.

S/N = SENSOR SERIAL NUMBER.

P/N = SENSOR PART NUMBER.

P = PASS, A = ALARM, F = FAIL,

W = WARNING, NR = NO REPLY,

D = DISCARDED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 11/6/17  
Year 2017GAS    DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. Alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # S    U	Dispenser # S    U								
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: R.A.MIS  
Date 11/6/17

(example)

## Weekly Underground Tank Inspection Checklist

Week 10/30/17  
Year 2017

(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			S		S					
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.		N			N					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		N			N					
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u> S      U	Dispenser # <u>2</u> S      U	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 10/30/17

-- DMRTEC Mfg., Inc.  
TEL: (401) 981-2001  
FAX: (401) 981-2007  
QELB ID: F1162849

MCU BOARD SERIAL: 745  
FIRMWARE: 0FL3K8P002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-10-30 13:05:38

-- SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0X030E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

-- PRUM TEST P

-- RAH TEST P

-- LEVEL PROBE TEST  
# PRODUCT TYPE TEST W  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

-- BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST P  
1 T 1, Sump#:1 S/N:20016273, P/N:BX-PDS P  
2 T 2, Sump#:2 S/N:20016276, P/N:BX-PDS P  
3 T 1, Interstitial S/N:210160712, P/N:BX-PDWF P  
4 T 2, Interstitial S/N:210161173, P/N:BX-PDWF P  
5 T 3, Sump#:2 S/N:200162537, P/N:BX-PDS P  
6 T 3, Interstitial S/N:210162479, P/N:BX-PDWF P  
7 T 3, Sump#:1 S/N:200162538, P/N:BX-PDS P

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 10/23/17  
Year 2017

(GAS) (DIESEL)

	Tank #							
	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S					
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N					
<b>U-tubes or Monitoring Wells</b>	Tank #	Tank #	Tank #	Tank #				
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____							
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump,ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #	Dispenser #	Dispenser #	Dispenser #				
	S	U	S	U	S	U	S	U
	S		S					

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

BLEW-OUT CAVITIES OF DISPENSERS

Inspected By: RAMOS  
Date 10/24/17

-- UNIT TEST --  
TEL: 1663 301-2001  
FAX: 1663 301-2007  
DEI3 ID: EL162849

MCU BOARD SURF 715  
FIRMWARE: DEI3RXP0146  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-10-24 13:03:40

--SLOT:  
Adc410\_ID: 1  
CANBUS\_START: 0  
FIRMWARE: 0XD3DE  
INTERFACE: 20410\_P2P

--PROM TEST P

--RAM TEST P

--LEVEL Probe TEST  
#1: probe test TEST  
1.000 P  
2.000 P  
3.000 P

--Board Level TEST  
#1: 0.000 S/N:20016233, P/N:BX-PDS  
1. T1, Sumpit:1 P  
S/N:20016233, P/N:BX-PDS

2. T2, Sumpit:2 P  
S/N:20016233, P/N:BX-PDS  
3. T3, Interc. A/B P  
S/N:210160712, P/N:BX-PDNE

4. T4, Interc. C/D P  
S/N:210160712, P/N:BX-PDNE

5. T5, Jumper DZ P  
S/N:20016233, P/N:BX-PDS

6. T6, Interc. E/F P  
S/N:210160712, P/N:BX-PDNE

7. T7, Sumpit:1 P  
S/N:20016233, P/N:BX-PDS

Th = BANK NUMBER,  
Sl = BX SLOT NUMBER,  
S/N = SERIAL NUMBER,  
P/N = SERIAL PART NUMBER,  
P = PASS, A = AL, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 10/16/17  
Year 2017

	Tank # <u>1</u>	Tank # <u>2</u>	Tank #	Tank #	Tank #					
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b>										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b>										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b>	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. Alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
<b>Dispensers</b>	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RHM/S  
Date 10/16/17

-- OMNITEL MFG., INC.  
TEL: (631)-981-2001  
FAX: (631)-981-2007  
DEL 3 10: EL102849

MCU BOARD SERIAL: 746  
FIRMWARE: DE10XPOU2AG  
RELEASE: Nov 12, 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-10-16 13:10:19

--OLDE,  
AB-416-117 1  
CANBUS START: 0X03DE  
FIRMWARE: 416\_PZAL  
RELEASE: 2015-11-02

--PROM TEST P

- RAM TEST P

--LEVEL PROBE TEST

# Task ID Test  
1 GAO P  
2 D1501 P  
3 F041\_011 P

--BX-SENSOR TEST

Total of 6 sensors /  
S# Label Test

1 T\_1, Subpart: S/N:2001622705, P/N:BX-PDS

2 T\_2, Subpart:2 S/N:2001622705, P/N:BX-PDS

3 T\_3, Subpart:3 S/N:2101620712, P/N:BX-PDWF

4 T\_2, Subpart:0 S/N:2101620712, P/N:BX-PDWF

5 T\_1, Subpart:2 S/N:2001622637, P/N:BX-PDS

6 T\_3, Subpart:0 S/N:210162479, P/N:BX-PDWF

7 T\_3, Subpart:1 S/N:2001622636, P/N:BX-PDS

T# = TASK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P : PASS, A : ALARM, F : FAIL,  
W : WARNING, NR : NO REPLY,  
D : DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 10/19/17  
Year 2017(GAS) (DIESEL)

	Tank # <u>1</u>	Tank # <u>2</u>	Tank #	Tank #	Tank #					
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMS  
Date 10/19/17

---DRIVER REV.: 1.0.0  
TEL: (631) 981-2001  
FAX: (631) 981-2007  
DEVC ID: E1162849

MCUD BOARD SERIAL: 745  
FIRMWARE: DE13KXP002AS  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-10-10 19:12:46

-- SENSORS . 1  
XB-41B 001 0  
LAMBOUS 0100E 0A00E  
FIRMWARE: 910-PZK  
RELEASE: 2015-11-04

FROM TANK P

RAM TEST P

-- LEVEL PROBE TEST  
T# PRODUCT TYPE TEST  
1 G60 P  
2 DTECFI P  
3 FUEL OIL P

--BX SENSORS TEST  
TOTAL OF BX SENSOR: 7  
S# LDR# TEST  
1 1-1, Comp#0 P  
2/BL200102200, P/N:BX-PDS

2 1-2, Comp#0 P  
S/N:200102200, P/N:BX-PDS

3 1-1, Interstitial P  
S/N:200102200, P/N:BX-PDS

4 1-2, Interstitial P  
S/N:200102200, P/N:BX-PDS

5 1-3, Comp#0 P  
S/N:200102200, P/N:BX-PDS

6 1-3, Interstitial P  
S/N:200102200, P/N:BX-PDS

7 1-3, Comp#0 P  
S/N:200102200, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 10/21/17  
Year 2017

	GAS		DIESEL									
	Tank # <u>1</u>	Tank # <u>2</u>	Tank #	Tank #								
	S	U	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S									
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S									
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N									
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N									
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West		North South East West		North South East West		North South East West		North South East West		North South East West	
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U	S	U
	S		S									

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 10/21/17

PHOTO BY: J. S.  
TEL: (408) 961-2001  
FAX: (408) 961-2707  
EMAIL: j.s@j-s.com

MICRO BOARD: 745  
FILEMATE: 01030002AU  
RELEASE: 2011-01-11 27

info  
info  
info  
info

TIME: 2011-10-02 12:07:00

DATE: 2011-10-02  
APPROVED: 01030002AU  
RELEASE: 416,02A  
EXPIRES: 2011-11-01

CMU-100

CMU-100

1 - DSCN0001.JPG  
2 - DSCN0002.JPG  
3 - DSCN0003.JPG  
4 - DSCN0004.JPG

5 - DSCN0005.JPG  
6 - DSCN0006.JPG  
7 - DSCN0007.JPG  
8 - DSCN0008.JPG

9 - DSCN0009.JPG  
10 - DSCN0010.JPG  
11 - DSCN0011.JPG  
12 - DSCN0012.JPG

13 - DSCN0013.JPG  
14 - DSCN0014.JPG  
15 - DSCN0015.JPG  
16 - DSCN0016.JPG

17 - DSCN0017.JPG  
18 - DSCN0018.JPG  
19 - DSCN0019.JPG  
20 - DSCN0020.JPG

21 - DSCN0021.JPG  
22 - DSCN0022.JPG  
23 - DSCN0023.JPG  
24 - DSCN0024.JPG

TH = Test  
SU = SURVEYOR  
S/N = SENSOR SERIAL NUMBER  
P/N = SENSOR PART NUMBER  
P = PASS, A = ALERT, F = FAIL,  
W = WARNING, NR = NO RESPONSE,  
D = DECODED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 9/29/17  
Year 2017GAS    DIESEL

	Tank # <u>1</u>	Tank # <u>1</u>	Tank #	Tank #	Tank #					
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have fine leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #	Tank #								
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u>	Dispenser # <u>2</u>	Dispenser #	Dispenser #	Dispenser #	Dispenser #				
	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 9/27/17

1 - 索引標題  
 200 - 145-2001  
 300 - 145-2001  
 DE13 - 145-2001

MUD 模組一號。 145  
 145-2001 電子版  
 RELEASE : 6.12.2001 10:11:27

info  
 info  
 info  
 info

TIME : 2001-12-27 09:54:37

1. M01 : 1  
 3. M10 : 0  
 13. M25 : 0.0000E+00  
 14. M30 : 4.112E-05  
 15. M40 : 0.0000E+00

1. M01 : P

1. M02 : P

1. M03 : P0000.000  
 10. M04 : 1.0000E-06  
 11. M05 : P  
 12. M06 : W  
 13. M07 : L  
 14. M08 : T

1. M09 : P0000.000  
 16. M10 : 1.0000E-06  
 20. M11 : TEST  
 21. M12 : 1.0000E-06  
 22. M13 : S74-0000000000000000

2. M1 : 警報項  
 5. M2 : 警報項

3. M3 : 警報項  
 8. M4 : 0.0000E+00

4. M5 : 警報項  
 9. M6 : 0.0000E+00

5. M7 : 警報項  
 13. M8 : 0.0000E+00

6. M9 : 警報項  
 14. M10 : 0.0000E+00

7. M11 : 警報項  
 15. M12 : 0.0000E+00

T# = TAKE 標題。  
 C# = Box-Set-# 盒號。

S/N = CENTRAL SERIAL NUMBER。  
 P/N = PART NUMBER。  
 P = PASS, A = ALARM, F = FAIL,  
 W = WARNING, IR = NO RESPONSE,  
 D = DISCARD.

(example)

## Weekly Underground Tank Inspection Checklist

Week 9/15/17  
Year 2017GAS    DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			<u>S</u>		<u>S</u>					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			<u>S</u>		<u>S</u>					
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.		<u>N</u>		<u>N</u>						
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		<u>N</u>		<u>N</u>						
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u> S    U	Dispenser # <u>2</u> S    U	Dispenser # S    U	Dispenser # S    U	Dispenser # S    U	Dispenser # S    U				
	<u>S</u>	<u>S</u>								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 9/15/17

WIRELESS  
 FAULT  
 DUE TO  
 HOLD TIME EXCEEDED  
 FAULT  
 RELEASED  
 NO  
 INFO  
 INFO  
 INFO

HOLD TIME EXCEEDED  
 FAULT  
 RELEASED  
 NO  
 INFO  
 INFO  
 INFO

TIME: 2017-01-13T23:53

FAULT	1
NO FAULT	0
WIRELESS FAULT	00000E
FROM FAULT	400_P2AL
RELEASED	2015-11-02

FROM FAULT P

FROM FAULT P

FAULT	RES
NO FAULT	P
WIRELESS FAULT	P
FROM FAULT	P

NO FAULT	P
WIRELESS FAULT	P
FROM FAULT	P
1. T.1. Sample 1	P
S/N:2001020304, P/N:BX-P02	

2. T.1. Sample 1	P
S/N:2001020305, P/N:BX-P02	

3. T.1. Sample 1	P
S/N:2001020306, P/N:BX-P02	

4. T.1. Sample 1	P
S/N:2001020307, P/N:BX-P02	

5. T.1. Sample 1	P
S/N:2001020308, P/N:BX-P02	

6. T.1. Sample 1	P
S/N:2001020309, P/N:BX-P02	

7. T.1. Sample 1	P
S/N:2001020310, P/N:BX-P02	

TO = Target location

SI = Sensor location

S/N = SENSOR NUMBER

P/N = SENSOR PART NUMBER

P = PART A = FAIL, F = FAIL,

W = WARNING, NR = NO REPLY,

D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 9/11/17  
Year 2017GAS      DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill/Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.										
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S    U	Dispenser # 2 S    U	Dispenser # S    U	Dispenser # S    U	Dispenser # S    U					
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

VACUUM'D SPILL/FILL BX'S OF ALL WATER + DEBRI

DISPENSERS = VACUUM'D &amp; CLEANED OF ALL DEBRI

Inspected By: \_\_\_\_\_  
Date: \_\_\_\_\_

COMPLETED: May 1, 2017  
TEL: (731) 981-2001  
FAX: (731) 981-2007  
DELO ID: EL162849

MCUB BOARD SERIAL: 745  
FIRMWARE: UMA3KXP002AG  
RELEASE: Nov 12 2016 16:11:27

info  
info  
info  
info

TIME: 2017-09-11 12:44:00

--SLU1: 1  
AB-416\_WL 0  
CANBUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL Probe TEST  
T# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162255, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Interstitial:0 P  
S/N:210160712, P/N:BX-PDWF  
4 T 2, Interstitial:0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstitial:0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 5/4/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product'	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stamp, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:	<u>CLEAN'D &amp; VACUUM'D SPILL/FILL BX'S</u>									

Inspected By: RAMS  
Date 5/5/17

--DANGER: HIGH VOLTAGE  
TEL: +46 10 2001 2001  
FAX: +46 10 2001 2002  
OE13 10: 01162049

MCUD BOARD SERIAL: 745  
FIRMWARE: 0013RXP04Z00  
RELEASE: Nov 17 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-09-05 13:08:21

--SLDIF: 1  
XB-4 LS: W: 0  
CANBUS START: 0X03DE  
FIRMWARE: 410\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAN TEST P

--LEVEL PROBE TEST

T#	PRODUCT TYPE	TEST
1	SK	P
2	DIESEL	P
3	FUEL SK	P

--BX-SENSOR TEST

TOTAL OF BX-SENSOR:	7	
S#	LABEL	TEST
1	T 1, Sump#1	P S/N:200162235, P/N:BX-PDS
2	T 2, Sump#2	P S/N:200162260, P/N:BX-PDS
3	T 1, Interstitial	P S/N:210162071Z, P/N:BX-PDS
4	T 1, Interstitial	P S/N:210162175, P/N:BX-PDS
5		P S/N:200162637, P/N:BX-PDS
6	T 3, Interstitial	P S/N:210162479, P/N:BX-PDS
7	T 3, Sump#1	P S/N:200162558, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 8/28/17  
Year 2017

(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u> S      U	Dispenser # <u>2</u> S      U	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #	Dispenser #
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: DAMIS  
Date 8/28/17

-- DMCU MSG., LOG.  
TEL: (131) 981-2001  
FAX: (131) 981-2007  
DE13 ID: FL162849

MCUD BOARD SERIAL: 745  
FIRMWARE: UFI3KXP002AG  
RELEASE: Nov 12 2015 16:11:27

info  
info  
info  
info

TIME: 2011-06-28 13:17:16

-- GDI: 1  
AB-410\_BI: 0  
CANBUS START: 0X000E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

-- PROM TEST P

-- RAM TEST P

-- CAVITY TESTS, TEST  
# PRODUCT TEST TEST  
1 Gas P  
2 Diesel P  
3 Fuel Oil P

-- BX SENSOR TEST  
TOTAL OF BX SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162735, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Inters#:0 P  
S/N:210160712, P/N:BX-POWF  
4 T 2, Inters#:0 P  
S/N:210161173, P/N:BX-POWF  
5 T 3, Sump#:2 P  
S/N:200162637, P/N:BX-PDS  
6 T 3, Inters#:0 P  
S/N:210162479, P/N:BX-POWF  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 8/21/17  
Year 2017GAS    DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have fine leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S    U	Dispenser # 2 S    U	Dispenser # 3 S    U	Dispenser # 4 S    U	Dispenser # 5 S    U					
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By P. AMOS  
Date 8/21/17

--ONTELIC MFG., Inc.  
TEL: (731)-981-2001  
FAX: (731)-981-2007  
DELS ID: EL162849

MOUD BOARD SERIAL: 745  
FIRMWARE: OF13KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-08-21 13:10:12

--SLOT: 1  
ANALOG I/O: 9  
CANBUS START: NOX/NO  
FIRMWARE: 4.03\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT TYPE	TEST
1	WAS	P
2	DIESEL	P
3	FUEL OIL	P

--BX-SENSOR TEST

S#	LABEL	TEST
1	T 1, Sample:1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Ground:	P
	S/N:200162236, P/N:BX-PDS	
3	T 1, Interstitial	P
	S/N:210160712, P/N:BX-PDWF	
4	T 2, Interstitial	P
	S/N:210161113, P/N:BX-PDWF	
5	T 3, Sample:2	P
	S/N:2001622537, P/N:BX-PDS	
6	T 3, Interstitial:0	P
	S/N:210162479, P/N:BX-PDWF	
7	T 3, Sample:1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 6/4/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			<u>S</u>			<u>S</u>				
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			<u>S</u>		<u>S</u>					
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.		<u>N</u>			<u>N</u>					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		<u>N</u>			<u>N</u>					
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____		North _____ South _____ East _____ West _____		North _____ South _____ East _____ West _____		North _____ South _____ East _____ West _____		North _____ South _____ East _____ West _____	
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # S      U		Dispenser # S      U		Dispenser # S      U		Dispenser # S      U		Dispenser # S      U	
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 6/14/17

---DRNTEC Mfg., Inc.  
TEL: 1.619.581-2001  
FAX: 1.619.581-2007  
GEN3 ID: 01162849

MCUD BOARD SERIAL: 745  
FIRMWARE: DE13KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-08-14 19:14:58

--SL01: 1  
XB-416 ID: 0  
CANBUS START: 0X030E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

-- LEVEL PROBE TEST  
#  
# PROBE TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL # OF BX SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Inteclick#:0 P  
S/N:210160712, P/N:BX-POWF  
4 T 2, Inteclick#:0 P  
S/N:210161173, P/N:BX-POWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Inteclick#:0 P  
S/N:210162479, P/N:BX-POWF  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 8/7/17  
Year 2017GAS      DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S    U		Dispenser # 2 S    U		Dispenser # S    U		Dispenser # S    U		Dispenser # S    U	
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 8/7/17

--OMNITR MFG., INC.  
TEL: (260) 491-2001  
FAX: (260) 491-2007  
DELS ID: EI 162649

MOD BOARD SERIAL: 745  
FIRMWARE: OLE3KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-08-07 13:36:54

--SLOT: 1  
XB 41G ID: 0  
CANBUS START: 0003DE  
FIRMWARE: 41G\_PZAL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
# Frequency Test  
1 GAS P  
2 DIESEL P  
3 FULL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
SH LABEL TEST  
1 T 1, Sensor#1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sensor#2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Interstitial P  
S/N:210160712, P/N:BX-PDMF  
4 T 2, Interstitial P  
S/N:210161173, P/N:BX-PDMF  
5 T 3, Sensor#2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstitial P  
S/N:210162479, P/N:BX-PDMF  
7 T 3, Sensor#1 P  
S/N:200162538, P/N:BX-PDS

# = TANK NUMBER,  
SH = BX SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 7/31/17  
Year 2017

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: RAMOS  
Date 7/31/17

--OMNIPC Mfg. / Inc.  
T# : 1661-901-2001  
F# : 1661-901-2007  
OEL3 ID: EL162849

MOUD BOARD SERIAL : 745  
FIRMWARE : OEL3EXP02AG  
RELEASE : Nov 12 2015, 16:11:27

info  
info

TIME: 2017-07-31 13:09:31

--SLOT:  
XB-416 ID: 1  
CANBUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
T# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162205, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162200, P/N:BX-PDS  
3 T 1, Interstic#:0 P  
S/N:210160712 P/N:BX-PDWF  
4 T 2, Interstic#:0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstic#:0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sump#:1 P  
S/N:200162638, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NN = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 7/24/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b>										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b>										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b>	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
<b>Dispensers</b>	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 7/24/17

status: OK  
---  
--> (MWB) MBG\_11001  
TEL: (631) 981-2001  
FAX: (631) 981-2007  
REF ID: FL162848

MCDD BOARD SERIAL: 745  
FIRMWARE: DE13KXP002AC  
REV: F4, Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-07-24 12:16:06

--> SLOT: 1  
XB-416 ID: 0  
CAMSUS TANK: 0x03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--> PROM TEST P  
--> RAM TEST P

--> LEVEL PROBE TEST  
T# PRODUCT ID TEST  
1 GAS P  
2 DIESEL P  
3 FULL OH P

--> BX-SENSOR TEST  
TOTAL OF BX SENSORS: 7  
S# LABEL TEST  
1 1, Comp#1 P  
S/N:200162534, P/N:BX-PDS  
2 1, Comp#2 P  
S/N:200162560, P/N:BX-POS  
3 1,1, Interstic#0 P  
S/N:210160712, P/N:BX-PDWF  
4 1,2, Interstic#0 P  
S/N:210161113, P/N:BX-PDWF  
5 1,3, Comp#2 P  
S/N:200162537, P/N:BX-POS  
6 1,3, Interstic#0 P  
S/N:210162549, P/N:BX-PDWF  
7 1,3, Comp#1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, R/W = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 7/17/17  
Year 2017

	Tank # <u>1</u>	Tank # <u>2</u>	Tank #	Tank #	Tank #					
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b>										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>	<u>S</u>								
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b>										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>	<u>S</u>								
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>	<u>N</u>								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>	<u>N</u>								
<b>U-tubes or Monitoring Wells</b>	Tank #	Tank #								
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b>	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>	<u>S</u>								
<b>Dispensers</b>	Dispenser # <u>1</u>	Dispenser # <u>2</u>	Dispenser #	Dispenser #	Dispenser #					
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 7/17/17

- SANTES, H.  
TEL: +39 010-951-2001  
FAX: +39 010-981-2007  
GCC ID: EL162049

MONITOR BOARD SERIAL: 745  
FIRMWARE: 00136XP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-07-17 10:58:36

--SOLI: 1  
XB-416: 0  
CANBUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM: S1 P  
--RAM: C1 P

--LEVEL PROBE TEST  
T# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL W  
3 FUEL OIL P

--BX-SENSOR TL  
TOTAL OF BX-SENSES: 7  
S# LABEL TEST  
1 T 1, Sample#1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sample#2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Interf#0 P  
S/N:210161173, P/N:BX-PWF  
4 T 2, Interf#1 P  
S/N:210161173, P/N:BX-PWF  
5 T 3, Sample#1 P  
S/N:200162237, P/N:BX-PDS  
6 T 3, Interf#0 P  
S/N:210162479, P/N:BX-PWF  
7 T 3, Sample#1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 7/10/17  
Year 2017GAS    DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u> S    U	Dispenser # <u>2</u> S    U	Dispenser # S    U	Dispenser # S    U	Dispenser # S    U	Dispenser # S    U				
	<u>S</u>	<u>S</u>								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMC  
Date 7/10/17

start time: 2017-07-19 13:16:22

--DRIVER: RPI, 1.2.0  
TEL: (11) 981-2001  
FAX: (1631)-981-2007  
OELS ID: 11162849

MCU/ BOARD SERIAL: 745  
FIRMWARE: 0.1.36X002AG  
RELEASE: Nov 22 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-07-19 13:16:28

--SLOT:  
XB-41B ID: 1  
CANBUS START: 0x03DE  
FIRMWARE: 41B\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT TYPE	TEST
1	GAS	P
2	DIESEL	W
3	FUEL GTL	P

--BX-SENSOR TEST

TOTAL OF BX SENSORS: 7

S# LABEL TEST

1 T 1, Sump#:1 P  
S/N:200162559, P/N:BX-PDS

2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P  
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P  
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P  
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,

S# = BX-SENSOR NUMBER,

S/N = SENSOR SERIAL NUMBER,

P/N = SENSOR PART NUMBER,

P = PASS, A = ALARM, F = FAIL,

W = WARNING, NR = NO REPLY,

D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 7/3/17  
Year 2017GAS, DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b>										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b>										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Un satisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b>	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
<b>Dispensers</b>	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By PAMOS  
Date 7/3/17

INTER. MSGN. 0000  
TEL: (601) 981-2001  
FAX: (601) 981-2007  
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745  
FIRMWARE: OI13KXP02AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-07-03 13:16:59

-+ SENS: 1  
XB-410-10: 0  
CANDU: 00000E  
FIRMWARE: 410\_PZAL  
RELEASE: 2015-11-02

FRUIT TEST P

-+ FRUIT TEST P

-+ LEVEL METER TEST  
# PRODUCT TYPE TEST  
1 WAO P  
2 UltraL A  
3 Folic Acid P

-+BX SENSOR TEST  
TOTAL BX-10 SENSORS: 1  
S# 1 Left TEST  
1 T-1, Sample: P  
S/N:210161173, P/N:BX-PDS

2 T-2, Sample:2 P  
S/N:210161173, P/N:BX-PDS  
3 T-3, Interstitial P  
S/N:210161173, P/N:BX-PDS

4 T-4, Interstitial P  
S/N:210161173, P/N:BX-PDS

5 T-5, Sample:2 P  
S/N:210161173, P/N:BX-PDS

6 T-6, Interstitial P  
S/N:210161173, P/N:BX-PDS

7 T-7, Sample:1 P  
S/N:210161173, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 6/26/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMES  
Date 6/26/17

--- OMNILOC M1200 Board  
TEL: (603) 981-2001  
FAX: (603) 981-2007  
DELR ID: 01162849

MCU0 BOARD SERIAL: 745  
FIRMWARE: OMEGAPUD2A0  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-06-26 13:30:07

--SHELL:  
#d 410 10. 0  
VANCOUVER, CANADA  
FIRMWARE: 416\_P2AL  
RELEASE: 2015\_11-02

--PROM TEST P  
--RAM TEST P

--LEVEL Probe Test  
T# PRODUCT ID# TEST  
1 1E, Compacting P  
2 Diesel P  
3 Fuel Oil P

--BX-SENSOR TEST  
TOTAL OF BX-SENSORS: 7  
S# LABEL TEST  
1 T 1, Compacting P  
S/N:20036748, P/N:BX-PDS  
2 T 2, Compacting P  
S/N:200160712, P/N:BX-PDS  
3 T 3, Interstitial P  
S/N:200162937, P/N:BX-PDS  
4 T 2, Interstitial P  
S/N:200161173, P/N:BX-PDS  
5 T 3, Compacting P  
S/N:200162937, P/N:BX-PDS  
6 T 3, Interstitial P  
S/N:200162937, P/N:BX-PDS  
7 T 3, Compacting P  
S/N:200162936, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 6/17/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: RAMC  
Date 6/17/17

---UNITEC Mfg., Inc.  
TEL: 1(631)-981-2001  
FAX: 1(631)-981-2007  
OELS ID: EL162849

MCUD BOARD SERIAL: 745  
FIRMWARE: OJ3KXP02AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-06-19 13:18:19

-- SLOTC: L  
XB-POS TH: 0  
CANBUS START: 0X03DE  
FIRMWARE: 416\_F2A1  
RELEASE: 2012-11-32

--PROB TEST P

--RAM TEST P

--LEVEL PROBE TEST  
TH PRODUCT TYPE TEST  
1 UR5 P  
2 UR5E1 P  
3 FUEL UR1 P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162135, P/N:BX-PDS

2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS

3 T 1, Interstitial P  
S/N:210160712, P/N:BX-PDW

4 T 2, Interstitial#0 P  
S/N:210161175, P/N:BX-PDW

5 T 3, Sump#:2 P  
S/N:200162937, P/N:BX-PDS

6 T 3, Interstitial#0 P  
S/N:210162479, P/N:BX-PDW

7 T 3, Sump#:3 P  
S/N:200162538, P/N:BX-PDS

TH = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 6/12/17  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b>										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b>										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b>	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
<b>Dispensers</b>	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 6/12/17

>

-- OMNITCO REG. INC.  
TEL: (905) 981-2001  
FAX: (905) 981-2007  
DE13 ID: E1162849

MCUD BOARD SERIAL: 745  
FIRMWARE: 38150X002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-06-12 13:11:36

--SLOT: 1  
XB-416 ID: 9  
CANBUS START: 0x03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PROBE #	TEST
1	GAS	P
2	DIESEL	P
3	FUEL OIL	P

--BX-SENSOR TEST

TOTAL	NUMBER	TEST
S#	LABEL	
1	T 1, Beam#1	P

S/N:200162538, P/N:BX-PDS

2 T 2, Comp#2 P  
S/N:200162539, P/N:BX-PDS

3 T 1, Interstic#0 P  
S/N:210161173, P/N:BX-POWF

4 T 2, Interstic#0 P  
S/N:210161173, P/N:BX-POWF

5 T 1, Alarm#1 P  
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#0 P  
S/N:210162479, P/N:BX-POWF

7 T 3, Comp#1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 6/15/17  
Year 2017GAS    DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEANED DISPENSERS/SPILL-FILL BY'S

Inspected By: RAMOS  
Date 6/15/17

-- AMMTEC Model: Test  
TEL: (631) 981-2001  
FAX: (631) 981-2007  
DEI3 ID: EL162649

MCUD BOARD SERIAL: 745  
FIRMWARE: DEI3EXP002AG  
RELEASE: Nov 17 2015, 16:11:27

info  
info  
info  
info

TIME: 2016-06-05 13:07:35

-- SLCF: 1  
AB420: 0  
CANBUS Slave: 0X030E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

-- PROM TEST P

-- RAM TEST P

-- LEVEL PROBE TEST  
# PROBE TYPE TEST  
1 GAS P  
2 OLESEL P  
3 HUMIDITY P

-- BX-SENSOR TEST  
TOTAL BX-SENSOR: 7  
S# LABEL TEST  
1 1, Gas#1 P  
S/N:200102235, P/N:BX-PDS

2 1,2, Gas#1 P  
S/N:200102260, P/N:BX-PDS

3 1,1, Interstitial P  
S/N:2101040717, P/N:BX-PDWF

4 1,2, Interstitial P  
S/N:2101041173, P/N:BX-PDWF

5 1,3, Gas#1 P  
S/N:200102337, P/N:BX-PDS

6 1,3, Interstitial P  
S/N:210104162479, P/N:BX-PDWF

7 1,3, Gas#1 P  
S/N:2001023696, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 5/30/17  
Year 2017GAS    DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)		S		S						
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #	Tank #	Tank #	Tank #	Tank #	Tank #				
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMUS  
Date 5/30/17

-- ARMED BEAM INC.  
TEL: (631) 981-2001  
FAX: (631) 981-2007  
DELB ID: EL102849

MODULE BOARD SERIAL: 745  
FIRMWARE: DE13KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-05-30 13:17:37

--SLOT:  
XB-416 ID: 0  
CANBUS START: 0xA3DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FOIL OH P

--BX SENSOR TEST  
TOTAL OF BX SENSORS: 7  
S# LABEL TEST  
1 T 1, Comp#1 P  
S/N:200162759, P/N:BX-PDS  
2 T 2, Comp#2 P  
S/N:200162760, P/N:BX-PDS  
3 T 1, Interstitial P  
S/N:2101600112, P/N:BX-PDWF  
4 T 2, Interstitial P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Comp#2 P  
S/N:200162637, P/N:BX-PDS  
6 T 3, Interstitial P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Comp#1 P  
S/N:200162638, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAULT,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 5/21/17  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			S		S					
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			N		N					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.			N		N					
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 5/22/17

--OMNITEL INC., LA.  
TEL : (1631)-981-2001  
FAX : (1631)-981-2007  
OEI 3 ID: EL162849

MODEL BOARD SERIAL: 745  
FIRMWARE: OEI38/P00ZAG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TEMP: 2017-05-27 12:36:06

--SLOT:  
XB-416 ID: 0  
CANBUS STAGE: 0x03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT ID#	TEST
1	GAS	P
2	DIESEL	P
3	FUEL_OIL	P

--BX-SENSOR TEST  
TOTAL OF BX SENSORS 7

S#	LABEL	TEST
1	1_1, Sample#1	P
	S/N:200162255, P/N:BX-PDS	
2	1_2, Sample#2	P
	S/N:200162260, P/N:BX-PDS	
3	1_1, Interstage#0	P
	S/N:210160712, P/N:BX-PWRF	
4	1_2, Interstage#0	P
	S/N:210160713, P/N:BX-PWRF	
5	1_3, Sample#1	P
	S/N:200162257, P/N:BX-PDS	
6	1_3, Interstage#0	P
	S/N:210162419, P/N:BX-PWRF	
7	1_3, Sample#1	P
	S/N:200162258, P/N:BX-PDS	

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED

(example)

## Weekly Underground Tank Inspection Checklist

Week 5/15/17  
Year 2017GAS    DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
	S	U	S	U	S	U	S	U	S	U
	S		S		S		S		S	

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 5/15/17

ORIGINATOR: ELM  
TEL: (631)-981-2001  
FAX: (631)-981-2007  
DELS ID: EL162849

MCUD BOARD SERIAL: 745  
FIRMWARE: v1.013KXP102AG  
RELEASE: Nov 17 2016, 16:11:27

info  
info  
info  
info

TIME: 2017-05-16 11:21:49

--SLOT 1  
XB-416 ID: 0  
CANBUS START: 0XD3DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2016\_11-02

--PROM TEST P  
--RAM TEST P

--LEVEL PROBE TEST  
T# PROBE# TPL TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sumpk1 P  
S/N:200162335, P/N:BX-PDS  
2 T 2, Sumpk2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Intestctrl0 P  
S/N:210160712, P/N:BX-POWF  
4 T 2, Intestctrl0 P  
S/N:210160117, P/N:BX-POWF  
5 T 3, Sumpk2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Intestctrl0 P  
S/N:210162479, P/N:BX-POWF  
7 T 3, Sumpk1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX SENSOR NUMBER,  
S/N = CANBUS SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 5/9/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection  Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection  Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection  Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	S		<u>S</u>							
Dispensers  Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 5/9/17

--OEMINFO INFO --  
TEL: 1(631)-981-2001  
FAX: 1(631)-981-2007  
OEM3 ID: E1182849

MCU BOARD SERIAL: 745  
FIRMWARE: OEM3KXP002AG  
RELEASE: Nov 12 2015 16:11:27

info  
info  
info  
info

TIME: 2017-05-08 11:55:59

--SLOT:  
XB-416 HI: 1  
CANBUS START: 0  
FIRMWARE: 0X030E  
RELEASE: 416\_P2AL  
2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
1# Product Part TEST  
1 GAS P  
2 DIESEL P  
3 FOUL OIL P

--BX-SENSOR TEST  
TOTAL OF BX SENSORS: 7  
S# LABEL TEST  
1 T 1, Sample#1 P  
S/N:20010223b, P/N:BX-PDS  
2 T 2, Sample#2 P  
S/N:20010223c, P/N:BX-PDS  
3 T 1, Intake#0 P  
S/N:210100712, P/N:BX-PWF  
4 T 2, Intake#0 P  
S/N:210161171, P/N:BX-PWF  
5 T 3, Sample#2 P  
S/N:20010223d, P/N:BX-PDS  
6 T 3, Intake#0 P  
S/N:210102479, P/N:BX-PWF  
7 T 3, Sample#3 P  
S/N:20010223e, P/N:BX-PDS

I# = FAIL NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 5/11/17  
Year 2017GAS      DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks; gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMUS  
Date 5/11/17

Site ID: 111-981-2001  
ID: 111-981-2007  
Date ID: EL162849

info  
info  
info  
info

TIME: 2017-05-02 12:32:25

--INVENTORY

TANK 1 GAS  
PRODUCT:  
TOTAL HEIGHT: 30.56(in)  
WATER HEIGHT: 0.03(in)  
TOTAL VOLUME: 2227.82(Gal)  
VOL/FRT VOLUME: 1.23(Gal)  
T.C. VOLUME: 2238.36(Gal)  
TEMPERATURE: 53.2(F)  
UILLAGE: 3772.17(Gal)  
90%UILLAGE: 1372.17(Gal)

TANK 2 DIESEL  
PRODUCT:  
TOTAL HEIGHT: 48.36(in)  
WATER HEIGHT: 0.81(in)  
TOTAL VOLUME: 2698.31(Gal)  
WATER VOLUME: 29.25(Gal)  
T.C. VOLUME: 2704.56(Gal)  
TEMPERATURE: 54.7(F)  
UILLAGE: 1301.68(Gal)  
90%UILLAGE: 901.68(Gal)

TANK 3 FUEL OIL  
PRODUCT:  
TOTAL HEIGHT: 72.61(in)  
WATER HEIGHT: 0.14(in)  
TOTAL VOLUME: 9093.70(Gal)  
WATER VOLUME: 11.40(Gal)  
T.C. VOLUME: 10026.79(Gal)  
TEMPERATURE: 52.2(F)  
UILLAGE: 5006.29(Gal)  
90%UILLAGE: 3506.29(Gal)

(example)

## Weekly Underground Tank Inspection Checklist

Week 4/24/17  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	H		H							
U-tubes or Monitoring Wells	Tank #	Tank #	Tank #	Tank #	Tank #	Tank #				
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMUS  
Date 4/24/17

--UNITEC MFG., INC.  
TEL: (1631) 981-2001  
FAX: (1631) 981-2007  
OEM ID: EL162849

MCUD BOARD SERIAL: 745  
FIRMWARE: DELBRXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-04-24 12:13:35

--SLOT:  
XB-416 ID: 1  
CANBUS START: 0  
FIRMWARE: 0X03DE  
RELEASE: 416\_P2AL  
2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
T# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL OF BX SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162230, P/N:BX-PDS  
3 T 1, Interstitial P  
S/N:210160712, P/N:BX-PDWF  
4 T 2, Interstitial P  
S/N:210161175, P/N:BX-PDWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstitial P  
S/N:210162475, P/N:BX-PDWF  
7 T 3, Sump#:1 P  
S/N:200162536, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NK = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 4/17/17  
Year 2017GAS    DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #	Tank #	Tank #	Tank #	Tank #	Tank #				
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1	Dispenser # 2	Dispenser # 3	Dispenser # 4	Dispenser # 5	Dispenser # 6	Dispenser # 7	Dispenser # 8	Dispenser # 9	Dispenser # 10
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S		S		S		S		S	

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEANED DISPENSERS/SPILL FILL  
BX'S

Inspected By: RAMOS  
Date 4/17/17

--OMNITEC WEST, INC.  
TEL: (1131) 981-2001  
FAX: (1661)-981-2007  
DEL3 10: LL162849

NCUD BOARD SERIAL: 745  
FIRMWARE: DEL3KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-04-17 10:50:20

--SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
T# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

--BX-SENSOR TEST  
TOTAL OF BX-SENSOR: 7  
S# LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:200162200, P/N:BX-PDS  
3 T 1, Interstic#:0 P  
S/N:210160712, P/N:BX-PDWF  
4 T 2, Interstic#:0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstic#:0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 4/10/17  
Year 2017

(GAS) (DIESEL)

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (PP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1	Dispenser # 2	Dispenser #							
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stamp, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMIS  
Date 4/10/17

ORIONTEK, Inc.  
TEL: 1(631) 931-2001  
FAX: 1(631) 931-2007  
GEL3 ID: E1162849

HOST BOARD SERIAL: 745  
FIRMWARE: ORL-BXP002AG  
RELEASE: 2005-12-28T09:16:11Z

info  
info  
info  
info

TIME: 14:48

--SL01:  
XB-416 ID: 0  
COMBUS STATUS: OK/OK/OK  
FIRMWARE: 416-F2AL  
RELEASE: 2005-11-02

PROM TEST P

1ZP100 P

1X-Sensor Test  
ID# of XB Model TEST  
1 GAS P  
2 OIL P  
3 FOE OIL P

1X-Sensor Test  
ID# of XB Model TEST  
S/N:1A01 S/N:1A01  
1 T.1, Sample#1 P  
S/N:20010228, F/N:BX-PDS

2 T.2, Sample#2 P  
S/N:20010228, F/N:BX-PDS

3 T.1, Sample#3 P  
S/N:20010228, F/N:BX-PDS

4 T.2, Interstitial P  
S/N:2101B1173, F/N:BX-PDS

5 T.3, Sample#2 P  
S/N:20010228, F/N:BX-PDS

6 T.3, Interstitial P  
S/N:2101B2479, F/N:BX-PDS

7 T.3, Sample#1 P  
S/N:20010228, F/N:BX-PDS

P = PASS, A = ALARM,

S/N = SENSOR NUMBER,

S/W = SENSOR SERIAL NUMBER,

P/N = SENSOR PART NUMBER,

P = PASS, A = ALARM, F = FAIL,

W = WARNING, NR = NO REPLY,

B = DISABLED

(example)

## Weekly Underground Tank Inspection Checklist

Week 4/3/17  
Year 2017GAS      DIESEL

Double Walled Tanks, Double walled piping: Leak Detection	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		S							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (PP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By RAMW  
Date 4/5/17

机架号: 1001-001  
 机架: 10031: 081 2002  
 机架 ID: 01062849  
 频率: 1000.0 MHz: 745  
 信噪比: 0.0030024G  
 采样率: Nov 12 2005, 16:11:27  
 info  
 info  
 info  
 info  
 日志: 2005-09-04 03:12:07:42  
 1. 识别: 1  
 频率: 1000.0 MHz: 0  
 QPSK 调制: 0.0000E  
 信噪比: 4.0 P2AL  
 采样率: 1000.01 02  
 FSK 1001 P  
 FSK 1001 P  
 日期: 2005-09-04  
 接收带宽: 1.0 MHz: 0.0 S1  
 1. PPS  
 2. 相位  
 3. 速率: 0.0  
 FSK 1001 P  
 FSK 1001 P  
 FSK 1001 P  
 2. 识别: 2  
 频率: 1000.0 MHz: 0.0000E  
 信噪比: 0.0000000, 0.0000-PPS  
 3. 识别: 3  
 频率: 1000.0 MHz: 0.0000E  
 信噪比: 0.0000000, 0.0000-PPS  
 4. 识别: 4  
 频率: 1000.0 MHz: 0.0000E  
 信噪比: 0.0000000, 0.0000-PPS  
 5. 识别: 5  
 频率: 1000.0 MHz: 0.0000E  
 信噪比: 0.0000000, 0.0000-PPS  
 6. 识别: 6  
 频率: 1000.0 MHz: 0.0000E  
 信噪比: 0.0000000, 0.0000-PPS  
 7. 识别: 7  
 频率: 1000.0 MHz: 0.0000E  
 信噪比: 0.0000000, 0.0000-PPS

R = 1000, 速率: 0,  
 S = 0.0, 相位: 0.0000  
 SPS = 1000000, 采样: 1000000  
 PPS = 1000000, 速率: 1000000  
 F = FAIL, R = REPLY, T = FAIL,  
 W = 窗口模式, H = No REPLY,  
 D = DISABLED

(example)

## Weekly Underground Tank Inspection Checklist

Week 3/27/17  
Year 2017(GAS) (DIESEL)

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
	<u>S</u>		<u>S</u>							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill/Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			<u>N</u>		<u>N</u>					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.			<u>N</u>		<u>N</u>					
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>	U	<u>S</u>	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	<u>S</u>	U	<u>S</u>	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMVJ  
Date 3/27/17

报告日期: 2015-06-12  
报告编号: 160612-001-2001  
FAX: 16630-981-2002  
ORI 3 ID: EEB62849

报告日期: 2015-06-12  
FAX 软件: 16630-981-2002AG  
RELEASE: 2015-06-12 2015-06-12:11:27

info  
info  
info  
info

时间: 2015-06-12 16:51

采样时间:  
采集速率:  
采样间隔:  
采样频率:  
循环地址:

RAM 地址 P

RAM 地址 P

采样周期:  
采集速率:  
1. CAS A  
2. RDH B  
3. RDH C

采样周期:  
采集速率:  
1. RDH A  
2. RDH B  
3. RDH C  
4. RDH D  
5. RDH E  
6. RDH F  
7. RDH G

3. RDH A  
4. RDH B  
5. RDH C  
6. RDH D  
7. RDH E

3. RDH A  
4. RDH B  
5. RDH C  
6. RDH D  
7. RDH E

3. RDH A  
4. RDH B  
5. RDH C  
6. RDH D  
7. RDH E

1. RDH A  
2. RDH B  
3. RDH C  
4. RDH D  
5. RDH E  
6. RDH F  
7. RDH G

(example)

## Weekly Underground Tank Inspection Checklist

Week 3/20/17  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	(S)	U	(S)	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	(S)	U	(S)	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S)	U	(S)	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 3/20/17

標題：2015-03-12 00:00:00  
 日期：2015-03-12 00:00:00  
 時間：00:00:00  
 總頁數：1

檢測結果：總頁數：745  
 [檢測報告]：D:\Users\002AG  
 [ETTASF]：2015-03-12 2015-03-11:27

info  
 info  
 info  
 info

時間：2015-03-12 13:22:55

一級目：1  
 KB-416-110  
 CANCER (癌)  
 二級類別：EASDE  
 日期類別：416-P2R  
 檢測類別：2015-03-02

檢測結果：P

-RAM TEST P

日期：2015-03-12  
 檢測結果：TEST  
 1. 0% P  
 2. 0% P  
 3. 100% P

KB-416-314  
 檢測日期：2015-03-12  
 試劑：APM  
 1. 1.1. Sanger  
 2. 電子顯微鏡  
 3. 100% P

2. 1. 1. Sanger P  
 3. 電子顯微鏡 P  
 4. 100% P

3. 1.1. Interferon P  
 4. 電子顯微鏡 P

4. 1.3. Sanger P  
 5. 電子顯微鏡 P

6. 1.3. Interferon P  
 7. 電子顯微鏡 P

7. 1.3. Sanger P  
 8. 電子顯微鏡 P

P = PASS, N = 計算錯誤, F = 故障  
 R = 錯誤, NR = NO 檢測  
 U = UNKNOWN

(example)

## Weekly Underground Tank Inspection Checklist

Week 3/13/17  
Year 2017GASDIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks; gasoline and diesel greater than 1000 gallons).										
Does this facility have fine leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	S		S							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____	North _____ South _____ East _____ West _____	North _____ South _____ East _____ West _____	North _____ South _____ East _____ West _____	North _____ South _____ East _____ West _____					
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #1 <input checked="" type="radio"/> S <input type="radio"/> U	Dispenser #2 <input checked="" type="radio"/> S <input type="radio"/> U	Dispenser #3 S    U	Dispenser #4 S    U	Dispenser #5 S    U					

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMUS  
Date 3/13/17

新嘉坡 一九三〇年  
十一月二日

總行： 1966年 1月 1日  
開戶行： 1966年 1月 1日  
總行賬號： 10011627

info

TIME: 2017-03-19 13:20:31

• SMT	1
• 電子元件	0
• 機械電子元件	350組別
• 組裝機器	5組上場
• 線材機器	20組上場

第101頁

1991 里昂 F

日用品	137	TEST
生活必需品	137	P
衣服	137	P
日用品	137	P

日本語の書類  
SBR-1000-A  
SBR-1000-B  
SBR-1000-C

2. 4. 1.  $\beta = 6^\circ$ .  $P$   
Spherical K. 極面圖

4. *Indication of the disease* P

5. 1.3. Sample  
S-NET1000, 1/4inch

6-13. Best Match P  
SIE2000-00000000

卷之三

維吾爾族語言  
維吾爾族文學

(example)

## Weekly Underground Tank Inspection Checklist

Week 3/6/17  
Year 2017

	<u>GAS</u>		<u>DIESEL</u>		Tank #		Tank #		Tank #		Tank #			
	Tank #	S	Tank #	S	U	Tank #	S	U	Tank #	S	U	Tank #	S	U
Double Walled Tanks, Double walled piping: Leak Detection														
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)		S		S										
Single Walled Tanks, Single Walled Piping: Leak Detection														
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).		S		S										
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.		N		N										
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		N		H										
U-tubes or Monitoring Wells	Tank #		Tank #			Tank #			Tank #			Tank #		
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____		North _____ South _____ East _____ West _____			North _____ South _____ East _____ West _____			North _____ South _____ East _____ West _____			North _____ South _____ East _____ West _____		
Overfill Protection	S	U	S	U	S	U	S	U	S	U	S	S	U	
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	S		S											
Dispensers	Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S)	U	(S)	U	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 3/6/17

資料來源：  
拍賣：中華人民共和國郵政總局  
日期：1981年1月1日  
地點：北京

郵票名稱：中國郵政郵票  
面額價值：1元  
發行地點：北京

info  
info  
info  
info

目錄號：ZD1981.1.1.14.1.5.2

郵票圖案：	1
郵票面值：	0
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

印製廠：北京郵電印刷廠

印製方法：膠版印刷

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000
印製廠：	P
印製方法：	P
郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：郵票圖案

郵票面值：郵票面值

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：	P
郵票面值：	P
郵票發行地點：	北京
郵票發行時間：	1981-01-01
郵票發行數量：	1000000

郵票圖案：郵票圖案  
郵票面值：郵票面值  
郵票發行地點：北京  
郵票發行時間：1981-01-01  
郵票發行數量：1000000  
印製廠：北京郵電印刷廠  
印製方法：膠版印刷

(example)

## Weekly Underground Tank Inspection Checklist

Week \_\_\_\_\_  
Year \_\_\_\_\_

(GAS) (DIESEL)

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	H		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		H							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	(S)	U	(S)	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.										
Dispensers	Dispenser #1		Dispenser #2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S)	U	(S)	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEANED SPILL/FILL BYS

Inspected By: RAMVS  
Date 2/27/17

	TIME	DATE	PERIOD
1	10:30 AM	2001-08-21	AM
2	10:30 AM	2001-08-21	AM
3	10:30 AM	2001-08-21	AM
4	10:30 AM	2001-08-21	AM
5	10:30 AM	2001-08-21	AM
6	10:30 AM	2001-08-21	AM
7	10:30 AM	2001-08-21	AM

(example)

## Weekly Underground Tank Inspection Checklist

Week 2120167  
Year 2017

(GAS) (DIESEL)

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S		S					
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	S		S							

*Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:*Inspected By: RAMOS  
Date 2/2/17

2007-06-12  
2007-06-12  
TEL: (03) 331-2001  
FAX: (03) 331-2002  
GMAIL: ft162849

推進力燃燒室試驗： 745  
試驗編號： 080907A6  
試驗日期： 2007-06-12 11:27

info  
info  
info  
info

日標： 745-080907A6

時間：  
總時間： 0  
起始時間： 08:06  
終止時間： 09:16  
耗時： 11:02

PMT 0.81 P  
PMT 0.81 P

1. 單噴嘴試驗  
1.1. 單噴嘴試驗  
1.1.1. GAS P  
1.1.2. N2O P  
1.1.3. 液氮 P

2. 多噴嘴試驗  
2.1. 多噴嘴試驗  
2.1.1. 3噴嘴 P  
2.1.2. 4噴嘴 P  
2.1.3. 5噴嘴 P  
2.1.4. 6噴嘴 P

3. 積分式試驗  
3.1. 積分式試驗  
3.1.1. 0.05mm P

4. 打開封閉試驗  
4.1. 打開封閉試驗  
4.1.1. 0.05mm P

5. 單噴嘴試驗  
5.1. 單噴嘴試驗  
5.1.1. 0.05mm P

6. 累積試驗  
6.1. 累積試驗  
6.1.1. 0.05mm P

7. 單噴嘴試驗  
7.1. 單噴嘴試驗  
7.1.1. 0.05mm P

1. 單噴嘴試驗  
2. 多噴嘴試驗  
3. 積分式試驗  
4. 打開封閉試驗  
5. 單噴嘴試驗  
6. 累積試驗  
7. 單噴嘴試驗

(example)

## Weekly Underground Tank Inspection Checklist

Week 2/13/17  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1989 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	(S)	U	(S)	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.										
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S)	U	(S)	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEANED SPILL/FILL BYS &amp; DISPENSERS

Inspected By: RAMC  
Date 2/13/17

日期：2007年11月13日  
时间：06:31:2007  
地点：中国科学院植物研究所  
编号：CIB 062849

植物名称：白花桔梗  
科属：桔梗科  
采集人：胡建明  
日期：Nov 12 2005, 06:14:22

alt

日期：2007年11月13日 06:28:32

植物名称：桔梗科  
科属：桔梗科  
采集人：胡建明  
日期：Nov 12 2005, 06:14:22  
地点：中国科学院植物研究所  
编号：CIB 062849

植物名称：

科属：

植物名称：桔梗科  
科属：桔梗科  
采集人：胡建明  
日期：Nov 12 2005, 06:14:22  
地点：中国科学院植物研究所  
编号：CIB 062849

植物名称：

科属：桔梗科

采集人：胡建明

日期：Nov 12 2005, 06:14:22

地点：中国科学院植物研究所

植物名称：桔梗科  
科属：桔梗科  
采集人：胡建明  
日期：Nov 12 2005, 06:14:22

植物名称：桔梗科  
科属：桔梗科  
采集人：胡建明  
日期：Nov 12 2005, 06:14:22  
地点：中国科学院植物研究所  
编号：CIB 062849

(example)

## Weekly Underground Tank Inspection Checklist

Week 2/6/17  
Year 2017GAS    DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	(S)	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection  Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection  Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection  Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product	(S)	U	(S)	U	S	U	S	U	S	U
S		S								
Dispensers  Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	(S)	U	(S)	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RANDS  
Date 2/6/17

Shippers Inc.  
Tel: 011 981 2001  
Fax: 011 981 2007  
Email: EL162849

"P" 表示已阅读;  
"R" 表示已回复;  
"F" 表示已发送;  
"D" 表示已删除;

info

日期: 2015年1月13日 星期一

收件人:	P
发件人:	O
主题:	00000000000000000000000000000000
发送时间:	2015-01-13 10:16:53
接收时间:	2015-01-13 10:32:02

主题: P  
回复: P

主题: P  
回复: P  
发送时间: 2015-01-13 10:32:02  
接收时间: 2015-01-13 10:32:02

主题: P  
回复: P  
发送时间: 2015-01-13 10:32:02  
接收时间: 2015-01-13 10:32:02

主题: P  
回复: P

1. "P" 表示已阅读。  
2. "R" 表示已回复。  
3. "S" 表示已发送。  
4. "D" 表示已删除。  
5. "A" = 阅读; "F" = 下载;  
"N" = 暂存; "R" = REPLY;  
"M" =

(example)

## Weekly Underground Tank Inspection Checklist

Week 113017  
Year 2017GAS    DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. <u>Attach printout or log</u> (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have fine leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	(S)	U	(S)	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S)	U	(S)	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEAN'D SPILL/FILL RX'S

Inspected By: RAMOS  
Date: 13/8/17

AMTEC Mfg., Inc.  
TEL: (631) 981-2001  
FAX: (631) 981-2002  
DE13 ID: 11162849

FOUND BOARD SERIAL: 745  
FIRMWARE: 01130000  
REVISION: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017/01/30 12:01:17

---SLOT: 1  
BX-416 ID: 0  
CANBUS START: 0X030E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

PROM TEST P

RAM TEST P

LEVEL FROM TEST  
ID PRODUCT TYPE TEST  
1 GAS A  
2 DIESEL P  
3 FUEL OIL P

BX-416 TEST  
TOTAL OF BX SENSOR: 7  
S/N LAB# TEST  
1 1-1, Swap#:1 P  
S/N:200167735, P/N:BX-PDS

2 1-2, Swap#:2 P  
S/N:200167230, P/N:BX-PDS

3 1-1, Interstitial:0 P  
S/N:210161173, P/N:BX-PMW

4 1-2, Interstitial:0 P  
S/N:210161173, P/N:BX-PMW

5 1-3, Swap#:2 P  
S/N:200167237, P/N:BX-PDS

6 1-3, Interstitial:0 P  
S/N:210167237, P/N:BX-PMW

7 1-3, Swap#:1 P  
S/N:200167235, P/N:BX-PDS

L = TANK NUMBER,  
S/N = BX SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 112317  
Year 2017GAS    DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm system to ensure audible and visual alarms function as designed. (Attach printout or log (depends on system installed))	S	X	S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/tilt box. (Spill/Tilt boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North									
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	(S)	U	(S)	U	S	U	S	U	S	U
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S)	U	(S)	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By RAMOS  
Date 112317

OMNIFEC Mfg., Inc.  
TEL: (631) 981-2001  
FAX: (631) 981-2002  
OEM ID: 61162849

MOTOR BOARD SERIAL: 745  
FIRMWARE: 043385402AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-01-23 14:42:01

--SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0X030E  
FIRMWARE: 416.PZAL  
RELEASE: 2015-11-02

PROM TEST P

RAM TEST P

LEVEL PROM TEST  
RC PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

BX SENSOR TEST  
TOTAL # OF BX SENSORS: 7  
SF LABEL TEST  
1 T 1, Sump#:1 P  
S/N:2001b2235, P/N:BX-PDS  
2 T 2, Sump#:2 P  
S/N:2001b2260, P/N:BX-PDS  
3 T 1, Interstitial#0 P  
S/N:2101b0712, P/N:BX-PDW  
4 T 2, Interstitial#0 P  
S/N:2101b1113, P/N:BX-PDW  
5 T 3, Sump#:2 P  
S/N:2001b2537, P/N:BX-PDS  
6 T 3, Interstitial#0 P  
S/N:2101b2479, P/N:BX-PDW  
7 T 3, Sump#:1 P  
S/N:2001b2538, P/N:BX-PDS

H# - TANK NUMBER,  
SF - BX SENSOR NUMBER,  
S/N - SENSOR SERIAL NUMBER,  
P/N - SENSOR PART NUMBER,  
P - PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 1-16-17  
Year 2017

(645)

DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed) <u>1645-DIESEL</u>	S	S								
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S								
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
<b>U-tubes or Monitoring Wells</b>	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	(S) U	(S) U	S U	S U	S U	S U				
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S) U	(S) U	S U	S U	S U	S U				

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By RAMOS  
Date 1/17/17

OMNIIC Miss., Inc.  
TEL: (631) 981 2001  
FAX: (631) 981 2007  
OEM ID: EL162849

MCU BOARD SERIAL: 745  
FIRMWARE: DEFBXPI02AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017/01/17 14:28:59

--SLOT: 1  
XB-416 ID: 0  
CABUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

-PROM TEST P  
-RAM TEST P

LEVEL PROBE TEST  
TH PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL W P

BX SENSOR TEST  
TOTAL # OF BX SENSOR: 7  
SI LABEL TEST  
1 T 1, Sump#:1 P  
S/N:200162235, P/N:BX-PUS  
  
2 T 2, Sump#:2 P  
S/N:200162260, P/N:BX-PDS  
  
3 T 1, Interstic#:0 P  
S/N:210160112, P/N:BX-PWF  
  
4 T 2, Interstic#:0 P  
S/N:210161103, P/N:BX-PWF  
  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
  
6 T 3, Interstic#:0 P  
S/N:210162479, P/N:BX-PWF  
  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PUS

TH = TANK NUMBER,  
SI = X SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

(example)

## Weekly Underground Tank Inspection Checklist

Week 1-9-17  
Year 2017

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S							
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overtight Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # S U									
	S		S		S					

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS  
Date 1-9-17

TEL: +971 50 981-2001  
FAX: +971 50 981-2007  
HELS ID: EL162849

MUIN BOARD SERIAL: 745  
FIRMWARE: DHT-BKXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-01-09 14:11:27

---SLOT:  
XB-416 ID: 0  
CANBUS START: 0X030E  
FIRMWARE: 416\_P2AL  
RELEASE: 2015-11-02

- PROM TEST P  
- RAM TEST P

FUEL PROBE TEST  
# PROBE TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL OIL P

BX SENSOR TEST  
TOTAL # BX SENSOR: 7  
S# TANK TEST  
1 T 1, Sump#:1 P  
S/N:200162235, P/N:BX-PDS  
  
2 T 2, Sump#:2 P  
S/N:200162280, P/N:BX-PDS  
  
3 T 1, Interstic#:0 P  
S/N:210160712, P/N:BX-POWF  
  
4 T 2, Interstic#:0 P  
S/N:210161173, P/N:BX-POWF  
  
5 T 3, Sump#:2 P  
S/N:200162537, P/N:BX-PDS  
  
6 T 3, Interstic#:0 P  
S/N:210162479, P/N:BX-POWF  
  
7 T 3, Sump#:1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
SH = BX SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.

example)

## Weekly Underground Tank Inspection Checklist

Week 11/3/16  
Year 2017GAS      DIESEL

	Tank #		Tank #		Tank #		Tank #		Tank #	
	(S)	U	(S)	U	S	U	S	U	S	U
<b>Double Walled Tanks, Double walled piping: Leak Detection</b> Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
<b>Single Walled Tanks, Single Walled Piping: Leak Detection</b> Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
<b>U-tubes or Monitoring Wells</b>	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
<b>Overfill Protection</b> Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. alarms must activate and be visible and audible to the deliverer of product.	(S) U	(S) U	S U	S U	S U					
<b>Dispensers</b> Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	(S) U	(S) U	S U	S U	S U					

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMVS  
Date 11/3/17

OMNICO Mfg., Inc.  
TEL: 1(631) 981-2001  
FAX: 1(631) 981-2007  
DELL TO: EL.162849

MODULE BOARD SERIAL: 745  
FIRMWARE: OH3KXP002AG  
RELEASE: Nov 12 2015, 16:11:27

info  
info  
info  
info

TIME: 2017-01-03 14:15:50

--SLOT: 1  
XB-416 ID: 0  
CANBUS START: 0X03DE  
FIRMWARE: 416\_P2AL  
RELEASE: 2015\_11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST  
ID# PRODUCT TYPE TEST  
1 GAS P  
2 DIESEL P  
3 FUEL, OIL P

--BX SENSOR TEST  
INITIAL ID BX SENSOR: 7  
S# LABEL TEST  
1 T 1, Sample#1 P  
S/N:200162235, P/N:BX-PDS  
2 T 2, Sample#2 P  
S/N:200162260, P/N:BX-PDS  
3 T 1, Interstitial#0 P  
S/N:210160712, P/N:BX-PDWF  
4 T 2, Interstitial#0 P  
S/N:210161173, P/N:BX-PDWF  
5 T 3, Sample#2 P  
S/N:200162537, P/N:BX-PDS  
6 T 3, Interstitial#0 P  
S/N:210162479, P/N:BX-PDWF  
7 T 3, Sample#1 P  
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,  
S# = BX-SENSOR NUMBER,  
S/N = SENSOR SERIAL NUMBER,  
P/N = SENSOR PART NUMBER,  
P = PASS, A = ALARM, F = FAIL,  
W = WARNING, NR = NO REPLY,  
D = DISABLED.