

(example)

Weekly Underground Tank Inspection Checklist

Week 12/17/18
Year 2018

GAS DIESEL

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed).	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in-line leak detection? (Y/N). If so, check for operability and list attachment of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and then the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. Alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: LAW
Date 12/19/18

---DMMTEC Mfg., Inc.
TEL: 1(631)-931-2001
FAX: 1(631)-931-2007
DEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-12-19 10:51:11

--SLU1: 1
XB-410 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7

S#	LABEL	TEST
1	T 1, Sump#:1	P
	S/N:2001G2235, P/N:BX-PDS	
2	T 2, Sump#:2	A P Corroded
	S/N:2001G2230, P/N:BX-PDS	
3	T 1, Interstitial:0	P
	S/N:210160712, P/N:BX-PWF	
4	T 2, Interstitial:0	P
	S/N:210161173, P/N:BX-PWF	
5	T 3, Sump#:2	P
	S/N:2001G2937, P/N:BX-PDS	
6	T 3, Interstitial:0	P
	S/N:210162479, P/N:BX-PWF	
7	T 3, Sump#:1	P
	S/N:2001G2538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER.
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(exempt)

Weekly Underground Tank Inspection Checklist

Week 12/24/08
Year 2008GAS DIESEL

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Determine all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S	S	S	S	S	S	S	S	S
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons.)	S	S	S	S	S	S	S	S	S	S
Does this facility have in-line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N	N	N	N	N	N	N	N	N	N
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N	N	N	N	N	N	N	N	N
U-tubes or Monitoring Wells	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and smell the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (PP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S	S	S	S	S	S	S	S	S	S
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser piping, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5	
	S	U	S	U	S	U	S	U	S	U
	S	S	S	S	S	S	S	S	S	S

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

...USA... Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
QEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: QEL3KXPO02AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-12-26 15:01:52

--SLOT: 1
 100%
 0
 0X03DE
 41G_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
 S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
 S/N:200162260, P/N:BX-PDS (A)
3 T 1, Interstitial:0 P
 S/N:210160712, P/N:BX-PDMF
4 T 2, Interstitial:0 P
 S/N:210161173, P/N:BX-PDMF
5 T 3, Sump#:2 P
 S/N:200162537, P/N:BX-PDS
6 T 3, Interstitial:0 P
 S/N:210162479, P/N:BX-PDMF
7 T 3, Sump#:1 P
 S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 12 weeks
Year 2015

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)												
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S									
Does this facility have in line leak detection? (Y/N). If no, check for operability and/or attach printout of testing performance to form.	N		N									
Does this facility conduct annual piping pressure test? If yes, note date of last test.	N		N									
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North		North	
	South		South		South		South		South		South	
	East		East		East		East		East		East	
	West		West		West		West		West		West	
Overflow Protection	S	U	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S									
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:												

Inspected By: RAMS
Date 10/17/15

---OMNITEC MFG., INC.
TEL: 1(631)-361-2001
FAX: 1(631)-961-2007
DELB ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEL3KXPOU2AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-12-10 06:35:53

--SL01: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS F
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 Canceled A
S/N:200162260, P/N:BX-PDS
3 T 1, Interstitial:0 P
S/N:21016160712, P/N:BX-PDWF
4 T 2, Interstitial:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstitial:0 P
S/N:210162479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 12/31/15
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill mitigation box. (Spill Mitigation boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in-line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: RAMOS
Date 11/31/13

--OMNILEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: QEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-12-03 15:06:52

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 CONN A
S/N:200162260, P/N:BX-PDS
3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162507, P/N:BX-PDS
6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200162508, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 11/26/18
Year 2018

(GAS) (DIESEL)

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S								
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 for single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S								
Does this facility have in-line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overall Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: RAMS
Date: 11/26/18

--OMNITEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: E1162849

MCU/D BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-11-26 08:31:28

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT TYPE	TEST
1	GAS	P
2	DIESEL	P
3	FUEL OIL	P

--BX-SENSOR TEST

TOTAL OF BX SENSOR:	7
S#	LABEL TEST
1	T 1, Sump#:1 P S/N:200162235, P/N:BX-PDS
2	T 2, Sump#:2 C(A) S/N:200162260, P/N:BX-PDS
3	T 1, Interstick#:0 P S/N:210160712, P/N:BX-PDWF
4	T 2, Interstick#:0 P S/N:210161173, P/N:BX-PDWF
5	T 3, Sump#:2 P S/N:200162537, P/N:BX-PDS
6	T 3, Interstick#:0 P S/N:210162479, P/N:BX-PDWF
7	T 3, Sump#:1 P S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(continued)

Weekly Underground Tank Inspection Checklist

(GAS), (DIESEL)

Week 11/24/18
Year 2018

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5		Tank #6	
	S	U	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection												
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S										
Single Walled Tanks, Single Walled Piping: Leak Detection												
Check condition of spill/kill box. (Spill Kill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S										
Does this facility have in-line tank detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N	N										
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N										
U-tubes or Monitoring Wells												
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West											
Overfill Protection	S	U	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S										
Dispensers												
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stems, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #1 S S	Dispenser #2 U S	Dispenser #3 S U	Dispenser #4 U S	Dispenser #5 S U	Dispenser #6 U S	Dispenser #7 S U	Dispenser #8 U S	Dispenser #9 S U	Dispenser #10 U S	Dispenser #11 S U	Dispenser #12 U S

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

ALARM CORRECT'D PUMP'D WATER OUT OF
SUMP#2

---OMNTEC Mfg., Inc.
TEL: 1(831)-981-2001
FAX: 1(831)-981-2007
DEL3 ID: E1.162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEI3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-11-13 14:36:13

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X030E
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 Correct P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist
(GAS) (DIESEL)

Week 11/5/18
Year 2018

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarm function as designed. Attach printout or log (depends on system installed)	S	S								
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fix box. (Spill Fix boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S								
Does this facility have in line leak detection? (Y/N). If no, check for operability and/or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
Do Single walled tanks have U-tubes or Monitoring Wells? If no, open end thief wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overflow Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

BLEW OUT LEAVE'S FROM DISPENSERS

Inspected By RAMES
Date 11/5/18

---OMNIEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: E1162B49

MCUD BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-11-05 14:19:20

---SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P
--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL (OIL) P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS
3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist
(GAS) (DIESEL)

 Week 10/29/18
 Year 2018

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection	S	S								
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed).										
Single Walled Tanks, Single Walled Piping: Leak Detection	S	S								
Check condition of spill fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
Does this facility have in-line leak detection? (Y/N). If no, check for operability and/or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overall Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser arms, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

(BLEW-OUT DISPENSERS OF ALL DEBRIS)
 +
 (LEAVES)

(ER)

Inspected By: RAMOS
 Date: 10/29/18

---OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
GEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-10-29 08:28:33

---SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

---PROM TEST P

---RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstick#:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstick#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstick#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSDR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(cont'd.)

Weekly Underground Tank Inspection Checklist

Week 10/22/16
Year 2018

GAS, DIESEL

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping-Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S								
Single Walled Tanks, Single Walled Piping- Leak Detection										
Check condition of spill fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S								
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (F), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: CMV
Date: 10/23/18

---OMNITEC Mfg., Inc.
TEL: (631)-981-2001
FAX: (631)-981-2007
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: uC-FX002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-10-22 14:39:39

---SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

#	PRODUCT TYPE	TEST
1	GAS	P
2	DIESEL	P
3	FUEL OIL	P

--BX-SENSOR TEST

S#	TOTAL OF BX-SENSOR:	TEST
1	T 1, Sump#:1	P S/N:200162235, P/N:BX-PDS
2	T 2, Sump#:2	P S/N:200162260, P/N:BX-PDS
3	T 1, Interstitial:0	P S/N:210160712, P/N:BX-PDWF
4	T 2, Interstitial:0	P S/N:210161173, P/N:BX-PDWF
5	T 3, Sump#:2	P S/N:200162537, P/N:BX-PDS
6	T 3, Interstitial:0	P S/N:210162479, P/N:BX-PDWF
7	T 3, Sump#:1	P S/N:200162533, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

**Weekly Underground Tank Inspection Checklist
(GAS) (DIESEL)**

Week 10/15/18
Year 2018

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection	S	S								
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
Single Walled Tanks, Single Walled Pipings - Leak Detection	S	S								
Check condition of spill/GF box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
Does this facility have in-line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells	Tank # 1	Tank # 2	Tank # 3	Tank # 4	Tank # 5					
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	S								
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly. Alarms must activate and be visible and audible to the deliverer of product.										
Dispensers	Dispenser # 1	Dispenser # 2	Dispenser # 3	Dispenser # 4	Dispenser # 5					
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser piping, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S U	S U	S U	S U	S U					
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: _____
Date: _____

UNITEC MFG., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DEI3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEI3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-10-15 08:16:02

--SLOT: 1
XB-41b ID: 0
CANBUS STAR1: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS F
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162230, P/N:BX-PDS
3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-POWF
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week Wk 18
Year 2013

(GAS) (DIESEL)

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S								
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/tilt box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons.)	S	S								
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:	<i>ALARM CORRECT'D / WATER INSIDE sump WELL</i>									
	<i>(SEE ATTACH'D)</i>									

Inspected By RAMOS
Date 10/11/13

--OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
QEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: QEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info

info

info

info

TIME: 2018-10-11 14:31:45

--SLOT: 1
XB-416_10: 0
CANBUS START: 0X03DE
FIRMWARE: 416_F2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

— 2 T 2, Sump#:2 A
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 9/17/18
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection	S		S							
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection	S		S							
Check condition of spill fill box. (Spill Fill boxes were required by the EPA since 1999 to single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and for actual greatest of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open end thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S		S		S		S		S	

Comments? Note any scheduled or unscheduled maintenance on tank equipment below:

ALARM CORRECT'D / WATER IN sump (DIESEL) well

---OMNIEL Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162849

MCU/D BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-10-15 08:16:02

---SLOT: 1
XB-416 IO: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

— 2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

--OMNITEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-09-19 06:31:42

--SLOT:
XB-416 ID: 1
CANBUS START: 0
FIRMWARE: 0X03DE
RELEASE: 416_P2AL
2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7

S#	LABEL	TEST
1	T 1, Sump#:1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Sump#:2	P
	S/N:200162260, P/N:BX-PDS	
3	T 1, Interstic#:0	P
	S/N:210160712, P/N:BX-PDWF	
4	T 2, Interstic#:0	P
	S/N:210161173, P/N:BX-PDWF	
5	T 3, Sump#:2	P
	S/N:200162537, P/N:BX-PDS	
6	T 3, Interstic#:0	P
	S/N:210162479, P/N:BX-PDWF	
7	T 3, Sump#:1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(exempt)

Weekly Underground Tank Inspection Checklist

Week 9/24/18
Year 2013

(CAS) (DIESEL)

	Task # 1		Task # 2		Task #		Task #		Task #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Task #		Task #		Task #		Task #		Task #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and close the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overflow Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overflow alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tank/equipment below:										

Inspected By: RAMOS
Date: 9/24/18

---OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162B49

MCU BOARD SERIAL: 746
FIRMWARE: OEL3KXP002AG
RELEASE: Jul 1, 2015, 16:11:27

info
info
info
info

TIME: 2018-09-24 14:14:41

----SLOT: 1
XB-416 ID: 0
CANBUS START: D0D3DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS
3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 9/10/18
Year 2018

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S								
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/SPILL box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons.)	S	S								
Does this facility have in-line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells										
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	S								
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.										
Dispensers										
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser pump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S S	Dispenser # 2 U S	Dispenser # 3 S U	Dispenser # 4 S U	Dispenser # 5 S U					

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 9/11/18

-- OMNTEC Mfg., Inc.
TEL: (631)-981-2001
FAX: (631)-981-2007
DELS ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEI3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-09-11 06:39:29

--SLOT:
XB-416 ID: 1
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT TYPE	TEST
1	GAS	P
2	DIESEL	P
3	FUEL OTL	P

--BX-SENSOR TEST

S#	LABEL	TEST
1	T 1, Sump#:1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Sump#:2	A
	S/N:200162260, P/N:BX-PDS	
3	T 1, Interstitial:0	P
	S/N:210160712, P/N:BX-PDWF	
4	T 2, Interstitial:0	P
	S/N:210161173, P/N:BX-PDWF	
5	T 3, Sump#:2	P
	S/N:200162537, P/N:BX-PDS	
6	T 3, Interstitial:0	P
	S/N:210162479, P/N:BX-PDWF	
7	T 3, Sump#:1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(continued)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 9/3/18
Year 2018

	Tank #		Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping, Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms functioning as designed. Attach printout or log (depends on system installed)												
	S		S									
Single Walled Tanks, Single Walled Piping - Leak Detection Check condition of spill/tilt box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).												
	S		S									
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	A		A									
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N									
U-tubes or Monitoring Wells	Tank #											
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North											
	South		South		South		South		South		South	
	East		East		East		East		East		East	
	West		West		West		West		West		West	
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S									
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #											
	S	U	S	U	S	U	S	U	S	U	S	U
	S		S									

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By RAMOS
Date 9/4/18

--DMNTEC M.J., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DEI3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEI3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-09-04 14:36:05

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7

S#	LABEL	TEST
1	T 1, Sump#:1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Sump#:2	P
	S/N:200162260, P/N:BX-PDS	
3	T 1, Interstic#:0	P
	S/N:210160712, P/N:BX-PDWF	
4	T 2, Interstic#:0	P
	S/N:210161179, P/N:BX-PDWF	
5	T 3, Sump#:2	P
	S/N:200162537, P/N:BX-PDS	
6	T 3, Interstic#:0	P
	S/N:210162479, P/N:BX-PDWF	
7	T 3, Sump#:1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 5/27/18
Year 2018

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S	S								
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S								
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N	N								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N								
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West	North South East West	North South East West	North South East West	North South East West	North South East West				
Overflow Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S U	Dispenser # 2 S U	Dispenser # S U	Dispenser # S U	Dispenser # S U	Dispenser # S U				

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMUS
Date 5/29/18

---OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DEL3 1/1: EL162849

MCUU BOARD SERIAL: 745
FIRMWARE: DEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-08-29 06:47:09

---SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT TYPE	TEST
1	GAS	P
2	DIESEL	P
3	FUEL OIL	P

--BX-SENSOR TEST

T#	S#	LABEL	TEST
1	1	T 1, Sump#:1	P
		S/N:200162236, P/N:BX-PDS	
2	2	T 2, Sump#:2	P
		S/N:200162260, P/N:BX-PDS	
3	3	T 1, Interstic#:0	P
		S/N:210160712, P/N:BX-POWF	
4	4	T 2, Interstic#:0	P
		S/N:210161173, P/N:BX-POWF	
5	5	T 3, Sump#:2	P
		S/N:200162537, P/N:BX-PDS	
6	6	T 3, Interstic#:0	P
		S/N:210162479, P/N:BX-POWF	
7	7	T 3, Sump#:1	P
		S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist
(GAS) (DIESEL)

Week 8/20/18
Year 2018

	Tank #		Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection												
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed).	S	S										
Single Walled Tanks, Single Walled Piping: Leak Detection												
Check condition of spill/FG box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S	S										
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N	N										
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N	N										
U-tubes or Monitoring Wells	Tank #											
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and fix presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South										
	East	West										
Overall Protection	S	U	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S										
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5		Dispenser # 6	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:												

Inspected By: RAMOS
Data 8/20/18

---OMNITEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162849

MCU4 BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info

info

info

info

TIME: 2016-08-20 06:41:21

--SLOT: 1
XB=416 IO: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT	TYPE	TEST
1	GAS		P
2	DIESEL		P
3	FUEL OIL		P

--BX-SENSOR TEST

S#	LABEL	TEST
1	T 1, Sump#:1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Sump#:2	P
	S/N:200162260, P/N:BX-PDS	
3	T 1, Interstic#:0	P
	S/N:210160712, P/N:BX-PDWF	
4	T 2, Interstic#:0	P
	S/N:210161173, P/N:BX-PDWF	
5	T 3, Sump#:2	P
	S/N:200162537, P/N:BX-PDS	
6	T 3, Interstic#:0	P
	S/N:210162479, P/N:BX-PDWF	
7	T 3, Sump#:1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 3/13/18
Year 2018

	Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			N		N					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.			N		N					
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North									
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overflow Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5	
	S	U	S	U	S	U	S	U	S	U
	S		S		S		S		S	

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMS
Date: 3/14/18

--OMNITEC Engg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-08-14 08:02:43

--SLOT: 1
AIS-FWD: 0
CANBUS-START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDMF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDMF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDMF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 8/6/18
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.		N		N						
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		N		N						
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
	S		S							
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S	Dispenser # 2 S	Dispenser # 3 S	Dispenser # 4 S	Dispenser # 5 S	Dispenser # 6 S	Dispenser # 7 S	Dispenser # 8 S	Dispenser # 9 S	Dispenser # 10 S

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 8/6/18

--OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-06-06 14:46:51

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER--
P = PASS, A = ALARM, F
W = WARNING, NR = NO RE
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 7/30/18
Year 2018

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #									
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

SWEPT OUT DISPENSERS / VACUUM'D WATER
 OUT OF SPILL/FILL BX AND CLEAN'D OUT ALL
 DEBRIS FROM SPILL/FILL BX'S.

 Inspected By: RAMES
 Date 7/30/18

---GMNTLC Mfg., Inc.
TEL: (1631)-981-2001
FAX: (1631)-981-2007
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-07-30 12:08:20

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS
3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 7/23/18
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill/Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells			Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers			Dispenser #		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 7/23/18

---UNITEC MFG., INC.
TEL: (631)-981-2001
FAX: (631)-981-2007
DEI3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEI3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-07-23 06:52:29

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0XD3DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 7/16/18

Year 2018

GAS

DIESEL

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping, Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping, Leak Detection										
Check condition of spill/Fill box. (Spill/Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons.)	S		S							
Does this facility have in-line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells			Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers			Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4	
Open covers and check for leaks or other irregularities. If there is leak detection probe in dispenser pump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEAN'D INSIDE OF DISPENSERS / VACUUM'D INSIDE
 OF SPILL/FILL BX'S OF ALL WATER / ~~DEBRIS~~ DEBRIS

 Inspected By RAMUS
 Date 7/16/18

--OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-07-16 14:13:23

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0XD3DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7

S#	LABEL	TEST
1	T 1, Sump#:1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Sump#:2	P
	S/N:200162260, P/N:BX-PDS	
3	T 1, Interstic#:0	P
	S/N:210160712, P/N:BX-PDWF	
4	T 2, Interstic#:0	P
	S/N:210161173, P/N:BX-PDWF	
5	T 3, Sump#:2	P
	S/N:200162537, P/N:BX-PDS	
6	T 3, Interstic#:0	P
	S/N:210162479, P/N:BX-PDWF	
7	T 3, Sump#:1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 7/2/18
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S									
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S									
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N									
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N									
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

NO SLIP DO TO OMNI-TEK COMPUTER
 NOT PRINTING. (TRISH FROM TRANSPORTATION
 WAS CALLED /INFORMED ON
 7/3/18 about THE PROBLEM)

 Inspected By: RAMVS
 Date: 7/2/18

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 6/25/18
Year 2018

	Tank #		Tank #		Tank #		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection												
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed).	S		S									
Single Walled Tanks, Single Walled Piping: Leak Detection												
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S									
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N									
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N									
U-tubes or Monitoring Wells			Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West											
Overfill Protection	S	U	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S									
Dispensers			Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:												

Inspected By RAM
Date 6/25/18

---OMNITEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
OEL3 ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-06-26 11:42:01

-- SLOT: 1
XB-416 IO: 0
CANBUS START: 0X03DE
FIRMWARE: 0X03DE
RELEASE: 20416_P2AL

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST

TOTAL OF BX SENSOR: 7

S# LABEL TEST

1 T 1, Sump#:1 P

S/N:200167235, P/N:B

2 T 2, Sump#:2 P

S/N:200162260, P/N:BX-PDS

3 T 1, Interstick:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstick:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstick:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 6/18/18Year 2018

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill/Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open end thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser # 3		Dispenser # 4		Dispenser # 5	
	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMES
Date 6/18/18

--DMTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DELB ID: EL162849

MCUO BOARD SERIAL: 745
FIRMWARE: DELOKXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-06-18 14:19:35

--SLOT: 1
XH-FH-ID: U
CANBUS START: 0X03DE
FIRMWARE: 416_PZAL
RELEASE: 2015-11-02

--HUM TEST P

--RAN TEST P

--LEVEL PROBE TEST
TB Product Test: TEST
1 GAS P
2 DIESEL P
3 Fuel Oil P

--BX SENSOR TEST
TOTAL OF BX SENSOR: 7
SR LABEL TEST
1 T 1, Supply1 P
S/N:2003L223, P/N:BX-PDS

2 T 2, Supply2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interfice#0 P
S/N:21010112, P/N:BX-PWIF

4 T 2, Interfice#0 P
S/N:21010113, P/N:BX-PWIF

5 T 3, Supply2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interfice#0 P
S/N:21010113, P/N:BX-PWIF

7 T 3, Supply1 P
S/N:200162536, P/N:BX-PDS

TB = TANK NUMBER,
SR = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 6/11/18

Year 2018

	Tank # 1		Tank # 2		Tank # 3		Tank # 4		Tank # 5		Tank # 6	
	S	U	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection	Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)											
	S		S									
Single Walled Tanks, Single Walled Piping: Leak Detection	Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).											
	S		S									
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N									
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N									
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South	East	West	North	South	East	West	North	South	East	West
	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Overfill Protection	S	U	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S									
Dispensers	Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U	S	U
	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date: 6/11/18

--ORNLIC-Mfg., Inc.
TEL: (631)-981-2001
FAX: (631)-981-2007
DELB ID: EL162B49

MCUD BOARD SERIAL: 745
FIRMWARE: DE13RXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-06-11 14:16:48

SDU: 1
SD 4R: 0
CANBUS START: 0X03DE
FIRMWARE: 430_FZAC
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST

Position Test Test
1 GND P
2 D1ESI P
3 GND D

--BX (BA) TEST

TOTAL OF BX SENSOR: 7

Label Test
1 T 1, Supply 1 P
S/N:200107260, P/N:BA-PDS

2 T 2, Supply 2 P
S/N:200107260, P/N:BA-PDS

3 T 3, Interstitial 0 P
S/N:210106112, P/N:BA-PDS

4 T 4, Interstitial 0 P
S/N:210106113, P/N:BA-PDS

5 T 5, Supply 2 P
S/N:200107260, P/N:BA-PDS

6 T 6, Interstitial 0 P
S/N:210106113, P/N:BA-PDS

7 T 7, Supply 1 P
S/N:200107260, P/N:BA-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, MR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 6/4/18
Year

(GAS) (DIESEL)

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North									
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #									
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 6/4/18

---OMNITEC MFG., INC.
TEL: (631) 981-2001
FAX: (631) 981-2007
DE33 ID: E1162849

MCCD BOARD SERIAL: 749
FIRMWARE: DE10RXP002AG
RELEASE: NOV 12 2015, 16:11:27

info
info
info
info

TIME: 2010-06-04 14:16:52

- SLOT: 1
AB-400-110: 0
LANGUAGE: DAISUE
FIRMWARE: 416_P2AL
RELEASE: rev 11-02

- PROM TEST P
- RAM TEST P

- LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 UNK P
2 DIFFSI P
3 FWT OIL P

-BX SENSOR TEST
TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162236, P/N:BX-PDS
3 T 1, Interf1#:0 P
S/N:201611173, P/N:BX-PDS
4 T 2, Interf1#:0 P
S/N:201611173, P/N:BX-PDS
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interf1#:0 P
S/N:20162479, P/N:BX-PDS
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 5/28/18
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
	<u>S</u>	<u>S</u>								
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
	<u>S</u>	<u>S</u>								
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.										
	<u>N</u>	<u>N</u>								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.										
	<u>N</u>	<u>N</u>								
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South	North	South	North	South	North	South	North	South
	East	West	East	West	East	West	East	West	East	West
Overflow Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>	<u>S</u>								
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	<u>S</u>	<u>S</u>								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 5/31/18

-- OMNIVIS, Inc., Inc.
TEL: (1631)-981-2001
FAX: (1631)-981-2007
OEM ID: E1162649

MICUB BOARD SERIAL: 745
FIRMWARE: OFF0KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-05-31 14:14:08

-- SLOT: 1
AB 410 10.0 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
TP PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7

S#	LABEL	TEST
1	T 1, Sump#1	P
	S/N:200162235, P/N:BX-PDS	
2	T 2, Sump#2	P
	S/N:200162260, P/N:BX-PDS	
3	T 1, Interstitial	P
	S/N:2101600712, P/N:BX-POWER	
4	T 2, Interstitial	P
	S/N:2101611173, P/N:BX-POWER	
5	T 3, Sump#2	P
	S/N:200162507, P/N:BX-PDS	
6	T 4, Interstitial	P
	S/N:210162479, P/N:BX-POWER	
7	T 5, Sump#1	P
	S/N:200162538, P/N:BX-PDS	

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

Weekly Underground Tank Inspection Checklist
(GAS) (DIESEL)

Week 5/21/18
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill/Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South	North	South	North	South	North	South	North	South
	East	West	East	West	East	West	East	West	East	West
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S		S		S		S	
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S		S		S		S		S	
<i>Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:</i>										

CLEAN'D SPILL/FILL BX'S + DISPENSERS

Inspected By: RAMOS
Date 5/21/18

---DRIVER INFO---
TEL: (631) 981-2001
FAX: (631)-981-2007
OCIO ID: 11162849

MCUD BOARD SERIAL: 745
FIRMWARE: OFLORXP02AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-05-22 13:21:09

---SLO1:
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

- PROM TEST P
- RAM TEST P

- LEVEL PROBE TEST
1# Probed#1 TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 I 1, Sump#1 P
S/N:200162234, P/N:BX-PDS
2 I 2, Sump#2 P
S/N:200162230, P/N:BX-PDS
3 I 1, Interstic#0 P
S/N:210160712, P/N:BX-PDWF
4 I 2, Interstic#0 P
S/N:210161173, P/N:BX-PDWF
5 I 3, Sump#2 P
S/N:200162537, P/N:BX-PDS
6 I 3, Interstic#0 P
S/N:210162470, P/N:BX-PDWF
7 I 3, Sump#1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 5/14/18
Year 2018

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection	S		S							
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
Single Walled Tanks, Single Walled Piping: Leak Detection	S		S							
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	N		N							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North									
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By RAMOS
Date 5/14/18

AMULU, M.G., 11
TEL: +91 981-2001
FAX: +91 981-2007
DELS ID: EL162849

MCU BOARD SERIAL: 745
FIRMWARE: DE13XPU02AG
RELEASE: Nov 12 2015, 16:11:27

info
...

Time : 2016-05-14 14:21:08

-- SLOW:
XB-416_1p: 0
CAMSUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

-- PROM TEST P

-- RAM TEST P

-- LEVEL PROBE TEST

T# PRODUCT TPL TEST
1 uAo P
2 uHSLI P
3 uHE_UII P

-- BX-SENSOR TEST

TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 1, Sample1 P
S/N:200102270, P/N:BX-POS
2 1,2, Sample2 P
S/N:200102260, P/N:BX-POS
3 1,1, Interstitial0 P
S/N:2101060712, P/N:BX-POWF
4 1,2, Interstitial0 P
S/N:2101061173, P/N:BX-POWF
5 1,3, Sample2 P
S/N:2001022507, P/N:BX-POS
6 1,5, Interstitial0 P
S/N:2101062479, P/N:BX-POWF
7 1,3, Sample1 P
S/N:2001022508, P/N:BX-POS

T# - Test number.
S# - BX-SENSOR NUMBER.
S/N - SENSOR SERIAL NUMBER.
P/N - SENSOR PART NUMBER.
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 5/18Year 2018

(GAS), (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection	S		S							
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
Single Walled Tanks, Single Walled Piping: Leak Detection	S		S							
Check condition of spill/SP box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).										
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overflow Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for lesions or other irregularities. If there is leak detection probes in dispenser sump,ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 5/7/18

--> OWNER: G.L.
TEL: 911-368-0001
FAX: 911-368-0007
EMAIL: g.l@...
P2349

MCU0430401_001.mif 745
FILED-001 001368P002AG
RELEASED: 2013-02-12 2015-11-11:27

Info
Info
Info
Info

TIME: 2013-02-07 14:26:43

SC01: 1
XB-416-BI: 0
CANBUS: 0x630E
FIRMWARE: 410_P23L
RELEASE: 2015-11-02

PROM_BI: P

RAM_BI: P

LEVEL_PMBI_BI: HSI
TR_PMBI_BI: HSI
1. Low: Y
2. Direct: P
3. Full BH: P

--BX-SENOR TEST
TOTAL OF BX SENORS: 7
S# TABLET TEST
1 1.1. Ground:
S/N:20016293B, P/N:BX-PDS
2 1.2. Nonparallel:
S/N:20016293B, P/N:BX-PDS
3 1.1. Interstitial:
S/N:20016293B, P/N:BX-PDS
4 1.2. Interstitial:
S/N:20016293B, P/N:BX-PDS
5 1.3. Ground:
S/N:20016293B, P/N:BX-PDS
6 1.4. Interstitial:
S/N:20016293B, P/N:BX-PDS
7 1.5. Nonparallel:
S/N:20016293B, P/N:BX-PDS

TR = Test
S# = BX SENSORS NUMBER,
S/N = SERIAL NUMBER,
P/N = PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = ND REPLY,
D = DISABLED,

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 4
Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North									
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overflow Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly; alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #									
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

VACUUM'D RAIN WATER OUT OF WELL'S

Inspected By: RAMUS
Date 4/30/18

OMNIBUS: 000000000000
TEL: (631) 931-2001
FAX: (631) 931-2007
OEG ID: EL182849

MCUD BOARD SURFACE: 745
FIRMWARE: DEU1KAP00ZAG
RELEASE: Nov. 17 2015, 16:11:27

info
info
info
info

TIME: 2015-04-30 13:19:53

--SLOT: 1
X0-416 ID: 0
CANBUS START: 0x03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

- PROM TEST P
- RAB TEST P

- LEVEL PROBE TEST
PROBE ID TEST
1 GAS P
2 DIFCII P
3 VAK OII P

- BX SENSOE TEST
TOTAL OF BX SENSOE: 7
S# TABLE TEST
1 1 1, Comp#1 P
S/N:200107235, P/N:BX-PDS

2 1 2, Comp#1 P
S/N:200107236, P/N:BX-PDS

3 1 1, Interal#0 P
S/N:210107172, P/N:BX-PDS

4 1 2, Interal#0 P
S/N:210107173, P/N:BX-PDS

5 1 3, Comp#2 P
S/N:200107237, P/N:BX-PDS

6 1 3, Interal#0 P
S/N:210107238, P/N:BX-PDS

7 1 3, Comp#3 P
S/N:200107239, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSE NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(exam, e)

Weekly Underground Tank Inspection Checklist

Week 4/23/18
Year 2018

(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North		North		North		North		North	
	South		South		South		South		South	
	East		East		East		East		East	
	West		West		West		West		West	
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 4/23/18

LINKED TO: 11
TEL: +49 311 961-2001
FAX: +49 311 961-2007
REF ID: CL162849

NCAL/RESULT/TEST: 745
FIRMWARE: 0136xP002AG
RELEASE: Nov 17 2015, 16:11:27

info
info
info
info

TIME: 2016-04-23 12:07:47

SIOF: 1
XB-416 ID: 0
CANBUS START: 0x030E
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

-PROM TEST P
-RAM TEST P

-LEVEL PROBE TEST
TEST
1 GAS P
2 LIQUID P
3 FUEL OIL P

-BX-SENSOR TEST
TOTAL OF BX SENSOR: 7
TEST
1 1.1, Sample#1 P
S/N:200162160, P/N:BX-PDS
2 1.2, Sample#2 P
S/N:200162160, P/N:BX-PDS
3 1.1, Interfacing#0 P
S/N:210160117, P/N:BX-PDNF
4 1.2, Interfacing#0 P
S/N:210160117, P/N:BX-PDNF
5 1.1, Sample#2 P
S/N:200162160, P/N:BX-PDS
6 1.3, Interfacing#0 P
S/N:210162160, P/N:BX-PDNF
7 1.3, Sample#1 P
S/N:200162160, P/N:BX-PDS

= TANK NUMBER,
\$# = BX SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(416) 615

Weekly Underground Tank Inspection Checklist

(GAS), (DIESEL)

Week 4/16/15
Year 2015

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)		S		S						
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).		S		S						
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.		N		N						
Does this facility conduct annual piping pressure tests? If yes, note date of last test.		N		N						
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South	North	South	North	South	North	South	North	South
	East	West	East	West	East	West	East	West	East	West
Overflow Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1	Dispenser # 2	Dispenser #							
	S	U	S	U	S	U	S	U	S	U
<i>Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:</i>										

Inspected By CHMDS
Date 4/16/15

OMNIUS READING, INC.
TEL: (101) 981-2001
FAX: (101) 981-2007
OEM ID: D102B49

MCU BOARD SERIAL: 745
FIRMWARE: 01.00X002AG
RELEASE: Nov 12 2015 16:11:27

info
info
info
info

TIME: July 04 10:05:43;56

--SHOT: 1
XB-416 ID: 0
CANBUS START: 0X00DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

-PROM TEST P

-PAN TEST P

-LEVEL PROBE TEST
ID: PROBE01 TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

-BX SENSORS TEST
TOTAL OF BX SENSORS: 7
S# LABEL TEST
1 F 1, Sensor1 P
S/N:200102235, P/N:BX-PDS
2 F 2, Sensor2 P
S/N:200102236, P/N:BX-PDS
3 F 1, Intermittent P
S/N:210100712, P/N:BX-PIRF
4 F 2, Intermittent P
S/N:210101173, P/N:BX-PIRF
5 F 3, Sensor3 P
S/N:200102237, S/N:BX-PDS
6 F 3, Intermittent P
S/N:210102479, P/N:BX-PIRF
7 F 3, Sensor4 P
S/N:200102530, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 4/9/18
Year 2018GAS DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S U	Dispenser # 2 S U	Dispenser # S U	Dispenser # S U	Dispenser # S U					
<i>Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:</i>										

Inspected By: RAMOS
Date 4/9/18

---UMNITZ PROJ. INFO.
TEL: (631)-981-2001
FAX: (631) 981-2007
DELS IUS: 11162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEL3EXP002AG
RELEASE: NOV 11 2015, 16:11:27

info
info
info
info

TIME: 2016-04-09 13:16:49

--SLOT: 1
XB-41G ID: 0
CANDIS START: 0X03DE
FIRMWARE: 41G_P2AL
RELEASE: 2015-11-02

--PROM TEST P
--RAM TEST P

--LEVEL PROBE TEST
1# MODULE TYPE: Real
1 GAS P
2 DICEPI P
3 FRT_BEE P

--BX-SENSOR TEST
TOTAL OF BX SENSORS: 7
S/N TABLE TEST
1 1 1, Sample 1 P
S/N:200162246, P/N:BX-PDS
2 1 2, Sample 2 P
S/N:200162260, P/N:BX-PDS
3 1 1, Interstitial 0 P
S/N:210166717, P/N:BX-PWF
4 1 2, Interstitial 0 P
S/N:210166717, P/N:BX-PWF
5 1 3, Sample 7 P
S/N:200162537, P/N:BX-PUS
6 1 3, Interstitial 0 P
S/N:210162479, P/N:BX-PWF
7 1 3, Sample 1 P
S/N:200162536, P/N:BX-PDS

TB = TANK NUMBER,
S/N = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

(GAS) (DIESEL)

Week 4/21/18Year 2018

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U

Double Walled Tanks, Double walled piping:Leak Detection

Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)

	S		S						
--	---	--	---	--	--	--	--	--	--

Single Walled Tanks, Single Walled Piping: Leak Detection

Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).

	S		S						
--	---	--	---	--	--	--	--	--	--

Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.

	N		N						
--	---	--	---	--	--	--	--	--	--

Does this facility conduct annual piping pressure tests? If yes, note date of last test.

	N		N						
--	---	--	---	--	--	--	--	--	--

U-tubes or Monitoring Wells

	Tank #		Tank #		Tank #		Tank #		Tank #
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____								

Overfill Protection

Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.

	S		S		S	U	S	U	S	U
--	---	--	---	--	---	---	---	---	---	---

Dispensers

Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.

	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By RAMS
Date 4/21/18

UMNTEC MSG. ID: 1
TEL: (651) 961-2001
FAX: (651) 961-2007
EMAIL ID: fl162849

MCU BOARD SERIAL: 745
FIRMWARE: DE3KXP002AG
RELEASE: Nov 12 2015 16:11:27

info
info
info
info

TIME: 2015-04-03 11:45:34

SLOT: 1
XB-416 ID: 0
CANBUS CHART: 0X03DF
FIRMWARE: 416_PZAL
RELEASE: 2015_11-02

- PROM TEST P
- RAM TEST P

LEVEL Probe Test
1. Picard, T#1 TEST
1 GAS P
2 DIFCH P
3 FUEL DB P

- BX-SENSOR TEST
TOTAL OF BX SENSORS: 7
SI# LABEL TEST
1 T 1, Comp#1 P
S/N:200162236, P/N:BX-PDS
2 T 2, Comp#2 P
S/N:2001622760, P/N:BX-PUS
3 T 3, Interstitial P
S/N:2001622712, P/N:BX-PWF
4 T 2, Interstitial P
S/N:2001621173, P/N:BX-PWF
5 T 3, Comp#2 P
S/N:2001622537, P/N:BX-PDS
6 T 3, Interstitial P
S/N:200162479, P/N:BX-PWF
7 T 3, Comp#1 P
S/N:200162536, P/N:BX-PDS

T# = TANK NUMBER,
SI# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 3/26/18
Year 2018

(GAS) (DIESEL)

	Tank #1		Tank #2		Tank #3		Tank #4		Tank #5	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			S	S						
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			S	S						
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			N	N						
Does this facility conduct annual piping pressure tests? If yes, note date of last test.			N	N						
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North	South								
	East	West								
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	S								
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser #1		Dispenser #2		Dispenser #3		Dispenser #4		Dispenser #5	
	S	U	S	U	S	U	S	U	S	U
	S	S								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 3/26/18

--UNIFIED reg. Inc.
TEL: 1(631)-961-2001
FAX: 1(631)-981-2007
EMAIL ID: E1162849

MCU BOARD SERIAL: 745
FIRMWARE: DEI_3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-03-26 10:20:11

-- SENSORS:
XB-416 ID: 0
CANBUS START: -0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

-- PROM TEST P

--RAM TEST P

-- LEVEL PROBE TEST
T# PROBE TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162255, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162760, P/N:BX-PDS

3 T 1, Interstick#:0 P
S/N:210160712, P/N:BX-PDNE

4 T 2, Interstick#:0 P
S/N:210161173, P/N:BX-PDNE

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstick#:0 P
S/N:210162479, P/N:BX-PDNE

7 T 3, Sump#:1 P
S/N:200162508, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 3/19/18
Year 2018GAS DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		H							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (PP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #		Dispenser #		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEAN'D WATER OUT OF SPILL/FILL BODIES —
 ALSO CLEAN'D OUT DISPENSERS. (EV)

 Inspected By: P. AMOS
 Date 3/19/18

-- OMEGIC MFG., INC.
TEL: (631) 981-2001
FAX: (631) 981-2007
REF ID: FL162849

MCUD BOARD SERIAL: 745
FIRMWARE: OFI3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-03-19 10:34:48

--SLOT: 1
XB-416 (U): 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

-- LEVEL PROBE TEST
T# Product Test TEST
1 GAS P
2 DIESEL P
3 FUEL Oil P

--BX-SENSOR TEST
TOTAL OF BX-SENSES: 7
S# LABEL TEST
1 1-1, Sample#1 P
S/N:2001162365, P/N:BX-PDS
2 1-2, Sample#2 P
S/N:2001162366, P/N:BX-PDS
3 1-1, Interf. End#0 P
S/N:210160712, P/N:BX-PDWF
4 1-2, Interf. End#0 P
S/N:210161173, P/N:BX-PDWF
5 1-3, Sample#2 P
S/N:200162537, P/N:BX-PDS
6 1-3, Interf. End#0 P
S/N:210162479, P/N:BX-PDWF
7 1-3, Sample#1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 3/12/18
Year 2018

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)			<u>S</u>				<u>S</u>			
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			<u>S</u>				<u>S</u>			
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			<u>N</u>				<u>N</u>			
Does this facility conduct annual piping pressure tests? If yes, note date of last test.			<u>N</u>				<u>N</u>			
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overflow Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S	U	S	U	S	U	S	U	S	U
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 3/12/18

MCUD BOARD SERIAL: 745
FIRMWARE: 001.0KPH02AG
RELEASE: Nov 04 2015, 16:11:27

MCUD BOARD SERIAL: 745
FIRMWARE: 001.0KPH02AG
RELEASE: Nov 04 2015, 16:11:27

info
info
info
info

TIME: 2016-03-12 15:18:23

--SLOT: 1
XB-416 SN: 0
CANBUS START: 0x03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PNOM TEST P

--RAM TEST P

--LENTE TEST P
T# PN#QTY TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# TEST
1 T 1, Comp#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Comp#:2 P
S/N:200162236, P/N:BX-PDS
3 T 1, Interstitial P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstitial P
S/N:210161173, P/N:BX-PDWF
5 T 3, Comp#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstitial P
S/N:210162479, P/N:BX-PDWF
7 T 3, Comp#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week _____
Year _____

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells			Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers			Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser stump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

(~~pump~~) WATER OUT OF (DIESEL) SPILL-FILL BX.

Inspected By: RAMOS
 Date: 3/11/15

--- UNMAPPED INFO.:
TEL: (631)-981-2001
FAX: (631)-981-2087
DLT3 ID: 745

MOUD BOARD SERIAL: UFL3KXP002AG
FIRMWARE: Nov 12 2015, 16:11:27
REFPAGE:

info
info
info
info

TIME: 2016-03-05 12:53:00

-- SLOT: 1
XB-416 ID: 0
CANCUS START: OX03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02
P
--PROM TEST
P
--RAM TEST

--LEVEL PROBE TEST
TH PROBE#1 TIME TEST
1 GAS P
2 DIESEL P
3 FULL OIL P

--BX-SENSOR TEST
TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 1, Sample#1 P
S/N:200162301, P/N:BX-PDS

2 1, Sample#2 WATER INSUMO
S/N:200162300, P/N:BX-PDS

3 1, Interstitial#0 P
S/N:210160112, P/N:BX-PDNF

4 1,2, Interstitial#0 P
S/N:210161113, P/N:BX-PDNF

5 1,3, Sample#2 P
S/N:200162337, P/N:BX-PDS

6 1,3, Interstitial#0 P
S/N:210162479, P/N:BX-PDNF

7 1,3, Sample#1 P
S/N:200162336, P/N:BX-PDS

TH = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 3/19/18
Year 2018

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and/or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overflow Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 3/21/18

--OMNILOG--
TEL: (601)-981-2001
FAX: (601)-981-2007
OEL3 ID: EL162849

MONITOR BOARD SERIAL: 745
FIRMWARE: OEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-02-17 03:00:50

--SHOT: 1
XB-416 OIL 0
CAMPUS START: 0X03DE
: 416_P2AL
: 2015-11-02

1. TANK TEST P

RAM TEST P

--LEVEL PROBE TEST

T#	PRODUCT	TEST
1	GAS	P
2	DIESEL	P
3	FULL OIL	P

--BX-SENSOR TEST

TOTAL OF BX SENSOR. 7

S# LABEL TEST

1 T 1, Sample:1 P
S/N:200162299, P/N:BX-PDS

2 T 2, Sample:2 P
S/N:200162200, P/N:BX-PDS

3 T 1, Interstitial:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstitial:0 P
S/N:210161131, P/N:BX-PDWF

5 T 3, Sample:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstitial:0 P
S/N:210162473, P/N:BX-PDWF

7 T 3, Sample:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, N/A = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 2/19/18
Year 2018(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 2/20/18

OMNITRAC INSTRUMENTS
TEL: (1631) 981-2001
FAX: (1631) 981-2007
OEI3 10, EL162849

MOUL BOARD SERIAL: 745
FIRMWARE: OEI3RXP02AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-07-20 14:13:27

-- SED1: 1
XB-416 ID: 0
CANDUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015_11-02

- PROM TEST P

- RAM TEST P

- LEVEL PROBE TEST
1# Product Type HIGH → TEST W
1 GAS P
2 D1551 P
3 FUEL W W

- BX-SENSOR TEST
TOTAL OF BX SENSOR: 7

S# LABEL TEST
1 T 1, Comp#1 P
S/N:2001012235, P/N:BX-POS

2 T 2, Comp#2 P
S/N:2001012236, P/N:BX-PDS

3 T 1, Interact#0 P
S/N:2101010012, P/N:BX-POWER

4 T 2, Interact#0 P
S/N:2101011123, P/N:BX-POWER

5 T 3, Comp#2 P
S/N:2001020237, P/N:BX-POS

6 T 3, Interact#0 P
S/N:210102470, P/N:BX-POWER

7 T 5, Comp#1 P
S/N:200102538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 2/12/18
Year 2018

(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection			S		S					
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)										
Single Walled Tanks, Single Walled Piping: Leak Detection			S		S					
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).			N		N					
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.			N		N					
Does this facility conduct annual piping pressure tests? If yes, note date of last test.										
U-tubes or Monitoring Wells	Tank #									
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North South East West									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser #									
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEAN'D INSIDE OF DISPENCERS / VACUUM'D INSIDE OF —
 SPILL-FILL BY'S

Inspected By: RAMOS
Date 2/13/18

-- UNITED MFG., Inc.
TEL: (1631)-981-2001
FAX: (1631)-981-2007
DELB ID: EL162849

MCUR BOARD : 1RJAK 745
Firmware : 0E13KXPOD2AG
Plat Date : 6/2/2015, 16:11:27

info
info
info
info

TIME: 2013-02-12 14:20:58

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X030E
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST Recent
T# PROB#1^{GAS} TEST A

1 GAS ^{High} P
2 DIESEL ^{Low} P
3 FUEL OIL ^{Level} P

--BX-SENSOR TEST

TOTAL OF BX SENSOR: 7

S# LABEL TEST

1 T 1, Sump#1 P
S/N:200162230, P/N:BX-PDS

2 T 2, Sump#2 P
S/N:200162230, P/N:BX-PDS

3 T 1, Interstic#0 P
S/N:21016160712, P/N:BX-PDMF

4 T 2, Interstic#0 P
S/N:21016161123, P/N:BX-PDMF

5 T 3, Sump#2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#0 P
S/N:210162479, P/N:BX-PDMF

7 T 3, Sump#1 P
S/N:200162336, P/N:BX-PDS

T# = TANK NUMBER,

S# = BX-SENSOR NUMBER,

S/N = SENSOR SERIAL NUMBER,

P/N = SENSOR PART NUMBER,

P = PASS, A = ALARM, F = FAIL,

W = WARNING, NR = NO REPLY,

D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 26 Year 2018GAS DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>	<u>S</u>								
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>	<u>S</u>								
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>	<u>N</u>								
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>	<u>N</u>								
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank and for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>	<u>S</u>								
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>	<u>S</u>								

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

VACUUMED SPILL/FILL BXS ALSO
 PUMP'D WATER OUT OF (DIESEL WELL)

Inspected By: RAMOS
Date 26/10/18

DE162049 Rev. 1
H1: (631)-981-2001
FAR: (631)-981-2007
DEL3 BH: EL162049

MCU BOARD SERIAL: 745
FIRMWARE: DE1620XPO2AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-02-06 11:23:21

--SLUF: 1
XB-416 ID: 0
CANBUS START: 0X030E
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

- PROM TEST P

- RAM TEST P

--LEVEL PROBE TEST *recent*
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL *High Level* A
3 FUEL OIL *Delivery* P

- BX-SENSOR TEST
TOP OF BX-SENSOR: 7
S# TEST
1 111, *Normal*, S/N:200162210, P/N:BX-PDS

2 T 2, *Sump#2*, S/N:200162210, P/N:BX-PDS

3 T 1, *Intake#0*, S/N:210161173, P/N:BX-PDS

4 T 2, *Intake#0*, S/N:210161173, P/N:BX-PDS

5 T 3, *Sump#2*, S/N:200162253, P/N:BX-PDS

6 T 3, *Intake#0*, S/N:210161479, P/N:BX-PDS

7 T 3, *Sump#1*, S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 129 / 16
Year 2016GAS DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank # <u>3</u>		Tank # <u>4</u>		Tank # <u>5</u>	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: _____
Date: _____

--UNINITIALIZED MSG., ID#:
TEL: (631)-981-2001
FAX: (631)-981-2007
DEI3 ID: EJ162849

MCU BOARD SERIAL: 745
FIRMWARE: DEI3KXPU02AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-01-29 12:42:16

--SLOT: 1
XB-416 LU: 0
CANBUS SNARL: 0X030E
FIRMWARE: 416_P2AL
RELEASE: 2015_11-02

--PROM TEST P
--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS
3 T 1, Interstitial:0 P
S/N:210160712, P/N:BX-PDWF
4 T 2, Interstitial:0 P
S/N:210161173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200162637, P/N:BX-PDS
6 T 3, Interstitial:0 P
S/N:210162479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200162558, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 1/22/15
Year 2015

(GAS) (DIESEL)

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # 1		Dispenser # 2		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:										

Inspected By: _____
Date: _____

--OMNIVEL MFG., INC.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DELOS ID: EL102849

MCUD BOARD SERIAL: 745
FIRMWARE: DE10KXP02AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2016-01-22 14:16:16

-- SLOT: 1
XB-416 ID: 0
CANBUS START: 0x03DE
FIRMWARE: 416_P2A1
RELEASE: 2015-11-02

--PRDM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PROBE TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200102235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200102260, P/N:BX-PDS
3 T 1, Intest#:0 P
S/N:2101010712, P/N:BX-PDWF
4 T 2, Intest#:0 P
S/N:210101173, P/N:BX-PDWF
5 T 3, Sump#:2 P
S/N:200102537, P/N:BX-PDS
6 T 3, Intest#:0 P
S/N:210102479, P/N:BX-PDWF
7 T 3, Sump#:1 P
S/N:200102538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 11/15/18
Year 2018GAS DIESEL

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

CLEANED FILL/SPILL BXS OF WATER / DERRI

.. OUT DISPENSERS

Inspected By: RAMOS
Date 11/16/18

-- UNITEC MFG., INC.
TEL: (403) 981-2001
FAX: (403) 981-2007
DELB ID: EL162849

MCUB BOARD SERIAL: 745
FIRMWARE: DEL30XP002AG
RELEASE: May 12 2015, 16:11:27

info
info
info
info

TIME: 2015-01-16 13:20:47

-- SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 41B_P2AL
RELEASE: 2015-11-02

-- PWR TEST P

-- RAM TEST P

-- LEVEL PROBE TEST
T# PROBE#1 TEST
1 GAS P
2 DIT3E1 P
3 FULL OIL P

-- BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-POWF

4 T 2, Interstic#:0 P
S/N:210161172, P/N:BX-POWF

5 T 3, Sump#:2 P
S/N:200162937, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-POWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.

(example)

Weekly Underground Tank Inspection Checklist

Week 12/18/18
Year 2018(GAS) (DIESEL)

	Tank # <u>1</u>		Tank # <u>2</u>		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection										
Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	<u>S</u>		<u>S</u>							
Single Walled Tanks, Single Walled Piping: Leak Detection										
Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	<u>S</u>		<u>S</u>							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	<u>N</u>		<u>N</u>							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	<u>N</u>		<u>N</u>							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection	S	U	S	U	S	U	S	U	S	U
Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	<u>S</u>		<u>S</u>							
Dispensers	Dispenser # <u>1</u>		Dispenser # <u>2</u>		Dispenser #		Dispenser #		Dispenser #	
Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	S	U	S	U	S	U	S	U	S	U
	<u>S</u>		<u>S</u>							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAMOS
Date 1/18/18

--UNITEC MFG., INC.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DELO ID: FL162849

MUD BOARD SERIAL: 745
FIRMWARE: 0E13KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-01-08 14:11:46

--SLOT:
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS
2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS
3 T 1, Interstic#:0 P
S/N:210160012, P/N:BX-POWF
4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-POWF
5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS
6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-POWF
7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED,

(example)

Weekly Underground Tank Inspection Checklist

Week 11/21/19
Year 2019GAS DIESEL

	Tank # 1		Tank # 2		Tank #		Tank #		Tank #	
	S	U	S	U	S	U	S	U	S	U
Double Walled Tanks, Double walled piping: Leak Detection Demonstrate all leak detection and overfill alarm circuitry to ensure audible and visual alarms function as designed. Attach printout or log (depends on system installed)	S		S							
Single Walled Tanks, Single Walled Piping: Leak Detection Check condition of spill/fill box. (Spill Fill boxes were required by the EPA since 1999 on single walled tanks, gasoline and diesel greater than 1000 gallons).	S		S							
Does this facility have in line leak detection? (Y/N). If so, check for operability and /or attach printout of testing performance to form.	N		N							
Does this facility conduct annual piping pressure tests? If yes, note date of last test.	N		N							
U-tubes or Monitoring Wells	Tank #		Tank #		Tank #		Tank #		Tank #	
Do Single walled tanks have U-tubes or Monitoring Wells? If so, open and thief the wells on each tank end for presence of product or vapors. Note the results here as: Satisfactory (S), Unsatisfactory (U), odor (O), floating product (FP), or Dry (D). If odor or product are observed, discovery must be reported as a spill and investigated.	North _____ South _____ East _____ West _____									
Overfill Protection Check to ensure that the overfill alarm panel (or other approved method) is functioning properly: alarms must activate and be visible and audible to the deliverer of product.	S		S							
Dispensers Open covers and check for leaks or other irregularities. If there is leak detection probes in dispenser sump, ensure probes are functioning correctly. Remove and properly dispose of debris and contaminated water.	Dispenser # 1 S U	Dispenser # 2 S U	Dispenser # S U	Dispenser # S U	Dispenser # S U					
	S		S							

Comments? Note any scheduled or unscheduled maintenance on tanks/equipment below:

Inspected By: RAM
Date 11/21/19

---OMNTEC Mfg., Inc.
TEL: 1(631)-981-2001
FAX: 1(631)-981-2007
DELS ID: EL162849

MCUD BOARD SERIAL: 745
FIRMWARE: DEL3KXP002AG
RELEASE: Nov 12 2015, 16:11:27

info
info
info
info

TIME: 2018-01-02 13:44:29

--SLOT: 1
XB-416 ID: 0
CANBUS START: 0X03DE
FIRMWARE: 416_P2AL
RELEASE: 2015-11-02

--PROM TEST P

--RAM TEST P

--LEVEL PROBE TEST
T# PRODUCT TYPE TEST
1 GAS P
2 DIESEL P
3 FUEL OIL P

--BX-SENSOR TEST
TOTAL OF BX-SENSOR: 7
S# LABEL TEST
1 T 1, Sump#:1 P
S/N:200162235, P/N:BX-PDS

2 T 2, Sump#:2 P
S/N:200162260, P/N:BX-PDS

3 T 1, Interstic#:0 P
S/N:210160712, P/N:BX-PDWF

4 T 2, Interstic#:0 P
S/N:210161173, P/N:BX-PDWF

5 T 3, Sump#:2 P
S/N:200162537, P/N:BX-PDS

6 T 3, Interstic#:0 P
S/N:210162479, P/N:BX-PDWF

7 T 3, Sump#:1 P
S/N:200162538, P/N:BX-PDS

T# = TANK NUMBER,
S# = BX-SENSOR NUMBER,
S/N = SENSOR SERIAL NUMBER,
P/N = SENSOR PART NUMBER,
P = PASS, A = ALARM, F = FAIL,
W = WARNING, NR = NO REPLY,
D = DISABLED.