

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for October 2023

**COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONTEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341	
PERMIT NUMBER	

001	
OUTFALL NUMBER	

Reporting Frequency: Monthly
 DMR Effective From: 10/01/2023
 DMR Effective To: 10/31/2023
 Permit Expires: 01/31/2028
 Permit Application Due: 08/04/2027
 No Discharge: ☐

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	10	01	2023	10	31

FROM

PARAMETER	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION						SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS	VALUE	UNITS	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	***	4.90	***	***	***	***	mg/L	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***	***	4.0	***	***	***	***	mg/L	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	***	***	7.27	***	***	8.24	***	S.U.	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***	***	6.0	***	***	9.0	***	S.U.	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	***	***	***	***	5.0	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	***	***	60.0	***	mg/L	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***	***	***	***	***	2.33	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	***	***	5.31	***	mg/L	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***	***	***	***	***	***	***	µW/cm²	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***	***	***	***	***	***	***	µW/cm²	Daily when Discharging	Grab
Flow (50050)	SAMPLE MEASUREMENT	.003871	MGD	***	***	***	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	***	***	***	***	1/week	Measured
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***	***	***	***	<1.0	10000	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	***	***	2000	10000	No./100 ml	2/month	Grab

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)		***	***		***	2.14	2.28	2/month	Grab
		***	***		***	25.0	50.0	2/month	Grab
Facility Comments									

COMMENT DETAILS			OPERATOR CERTIFICATION NUMBER		OPERATOR CONTACT NUMBER	
COMMENTS	OPERATOR NAME					



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Tue, Nov 21, 2023 at 10:38 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 10/01/2023-10/31/2023
Report Due Date: 11/28/2023

Submitted By: Jeffrey Campbell
Submission Id: 424891
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: October 2023

Flow	$120,014 \div 31 \text{ DAYS} = 3,871 \text{ Daily Avg.}$ Daily Avg		
UV Light	$106.2 \div 20 =$: <u>5.31</u> Daily Avg		
		Basin #	Date
PH Low	7.27	# 1	10/10/23
PH High	8.24	# 2	10/16/23
D. O. Low	4.90	# 2	10/16/23
D. O. High	8.64	# 2	10/11/23

Date:	10/5/23	10/12/23	Sub	$\div 2$ Total	Report
Total Nitrogen	31.3	5.25	36.55	18.275	18.28
TSS	5	<5	5	2.5	2.5
TKN	4.85	<0.625	5.475	2.737	2.74
Nitrate/Nitrate	26.4	5.25	31.65	15.825	15.83
Phos	4.0	4.0	8.0	4.0	4.0
CBOD	2.28	<2.00	4.28	2.14	2.14
Fecal	<1	<1		<1	<1
AMMONIA	4.14	0.517	4.657	2.3285	2.33

Moniteau High School Sewage Treatment Plant				Daily Operations Worksheet				
Permit # PA0091341								
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator	
10/2	Mon	7.58	8.14	7.62	8.21	OCT 2023	JEFF C	
10/3	Tues	7.62	8.16	7.68	8.13		JEFF C	
10/4	Wed	AERATION		7.68	8.11		JEFF C	
10/5	Thurs	7.60	8.01	AERATION			JEFF C	
10/6	Fri	7.58	7.99	7.62	8.01		JEFF C	
10/9	Mon	7.40	7.62	AERATION			JEFF C	
10/10	Tues	7.27	8.27	7.33	8.64		JEFF C	
10/11	Wed	7.31	8.21	7.40	8.59		JEFF C	
10/12	Thurs	7.35	8.20	7.38	8.51		JEFF C	
10/13	Fri	7.36	8.28	7.31	8.42		JEFF C	
10/16	Mon	7.01	6.97	8.24	4.90		Seth C	
10/18	Wed	8.07	7.74	8.01	6.31		Seth C	
10/21	Sat	Aeration		8.23	7.93		Seth C	
10/23	Mon	7.95	7.78	8.16	8.03		JEFF C	
10/24	Tues	7.93	7.80	8.04	8.08		JEFF C	
10/25	Wed	8.03	7.95	8.01	8.03		JEFF C	
10/26	Thurs	8.01	7.97	8.06	8.01		JEFF C	
10/27	Fri	7.97	8.01	8.08	8.11		JEFF C	
10/30	Mon	7.95	8.03	7.99	8.04		JEFF C	
10/31	Tues	7.93	8.05	7.97	8.01		JEFF C	

TEST DAY *

TEST DAY *

*



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

17 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J0650
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23J0650-01	Waste Water	10/05/2023 10:00	10/5/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/17/2023 16:04

Lab Sample ID#: 23J0650-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 10/05/2023 10:00
Receipt Date: 10/05/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	31.3	mg/L			2.70	AW	10/16/23 14:55	10/16/23 14:55
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	4.14	mg/L		0.165	0.400	DAA	10/12/23 08:40	10/13/23 22:16
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	4.85	mg/L			0.625	AW	10/13/23 08:28	10/13/23 08:28
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	5	mg/L			5	MM	10/10/23 08:25	10/10/23 15:57
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	26.4	mg/L			2.08	AW	10/16/23 14:55	10/16/23 14:55
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	4.0	mg/L			1.0	JMS	10/10/23 18:36	10/10/23 18:36
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	2.28	mg/L	SS		2.00	ATJ	10/05/23 15:47	10/10/23 11:43
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	10/05/23 14:38	10/06/23 11:50

SAMPLE REQUEST & CHAIN OF CUSTODY



0310650

23J0650

Project Notes:

Wastewater

MONTEAU SCHOOL DISTRICT

JEFFREY CAMPBELL

WEST SUNBU

campbellcomonteau.org



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monterey S.D.</u>	Wt. <u>23J0650</u> (hers)
------------------------------	---------------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: <u>10/5/23</u>
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>AL/00382</u>	Samples Received on Ice? ☒ YES NO
Date/Time Received: <u>10/5/23 1400</u>	Date Sampled: <u>10/5/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>8.4</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: ☒ PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES ☒ NO

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria		Signature _____	Date _____	Time _____
Chain of custody documents included with samples?	YES NO	Comments/Qualifiers (Required for Non-Conforming Items)		
COC form is properly signed in relinquished/received sections?	YES NO	Comments:		
Sample containers intact and sealed?	YES NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____		
Number of containers received matches number indicated on COC?	YES NO	Sample IDs and Containers Affected:		
Sample IDs on COC match IDs on bottles?	YES NO	Sample IDs and Containers Affected:		
Date and time on COC match date and time on bottles?	YES NO	Sample IDs and Containers Affected:		
Samples received within holding time?	YES NO	Sample IDs and Containers Affected:		
Samples received at appropriate pH for analysis requested?	YES NO	Sample IDs and Containers Affected and Observed pH:		
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.		
Adequate sample volume received?	YES NO	Analyses Affected:		
VOA vial headspace < 6 mm?	YES NO N/A	Sample IDs and Containers Affected:		
Other Comments:		Deficiency Log Created: YES ☒ NO		

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

23 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J1489
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23J1489-01	Waste Water	10/12/2023 10:00	10/12/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
ML Matrix Spike recovery fell below the laboratory acceptance criteria; result may be biased low.
G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/23/2023 14:48

Lab Sample ID#: 23J1489-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 10/12/2023 10:00
Receipt Date: 10/12/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	5.25	mg/L			0.833	AW	10/19/23 09:14	10/19/23 09:14
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	0.517	mg/L		0.165	0.400	DAA	10/18/23 08:15	10/19/23 07:04
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	10/19/23 09:14	10/19/23 09:14
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	MM	10/17/23 19:01	10/18/23 14:35
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	5.25	mg/L	ML		0.208	AW	10/18/23 12:14	10/18/23 12:14
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	4.0	mg/L			1.0	JMS	10/19/23 14:39	10/19/23 14:39
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, G, SS		2.00	TW	10/13/23 11:59	10/18/23 08:34
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	10/12/23 15:06	10/13/23 11:48

SAMPLE REQUEST & CHAIN OF CUSTODY

FAX: (724) 465-4209



FAX: (724) 258-8376

FAX: (570) 321-1957



2311489

FOR INTERNAL LABORATORY USE ONLY

1-800-1-24-4655-4209

[illegible]

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

2. THE UNDERSIGNED PUBLIC ASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO AN ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes

Wastewater

Company/Name:

MONTICELLO SCHOOL DISTRICT

Order/Title

1

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
84

	1980	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	2107	2108	2109	2110	2111	2112	2113	2114	2115	2116	2117	2118	2119	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131	2132	2133	2134	2135	2136	2137	2138	2139	2140	2141	2142	2143	2144	2145	2146	2147	2148	2149	2150	2151	2152	2153	2154	2155	2156	2157	2158	2159	2160	2161	2162	2163	2164	2165	2166	2167	2168	2169	2170	2171	2172	2173	2174	2175	2176	2177	2178	2179	2180	2181	2182	2183	2184	2185	2186	2187	2188	2189	2190	2191	2192	2193	2194	2195	2196	2197	2198	2199	2200	2201	2202	2203	2204	2205	2206	2207	2208	2209	2210	2211	2212	2213	2214	2215	2216	2217	2218	2219	2220	2221	2222	2223	2224	2225	2226	2227	2228	2229	2230	2231	2232	2233	2234	2235	2236	2237	2238	2239	2240	2241	2242	2243	2244	2245	2246	2247	2248	2249	2250	2251	2252	2253	2254	2255	2256	2257	2258	2259	2260	2261	2262	2263	2264	2265	2266	2267	2268	2269	2270	2271	2272	2273	2274	2275	2276	2277	2278	2279	2280	2281	2282	2283	2284	2285	2286	2287	2288	2289	2290	2291	2292	2293	2294	2295	2296	2297	2298	2299	2300	2301	2302	2303	2304	2305	2306	2307	2308	2309	2310	2311	2312	2313	2314	2315	2316	2317	2318	2319	2320	2321	2322	2323	2324	2325	2326	2327	2328	2329	2330	2331	2332	2333	2334	2335	2336	2337	2338	2339	2340	2341	2342	2343	2344	2345	2346	2347	2348	2349	2350	2351	2352	2353	2354	2355	2356	2357	2358	2359	2360	2361	2362	2363	2364	2365	2366	2367	2368	2369	2370	2371	2372	2373	2374	2375	2376	2377	2378	2379	2380	2381	2382	2383	2384	2385	2386	2387	2388	2389	2390	2391	2392	2393	2394	2395	2396	2397	2398	2399	2400	2401	2402	2403	2404	2405	2406	2407	2408	2409	2410	2411	2412	2413	2414	2415	2416	2417	2418	2419	2420	2421	2422	2423	2424	2425	2426	2427	2428	2429	2430	2431	2432	2
--	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	---

Date/Time

Pharmaceuticals

7754 405 4405

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receivint' Temperatures



SAMPLE RECEIPT AND REVIEW FORM



23J1489

Client:

Monteau SD

(Label here)

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>AP / 00392</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>10 / 12 / 23 1350</u>	Date Sampled: <u>10 / 12 / 23</u>
Method of Delivery: FedEx UPS <u>Client Drop off</u> <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>12.6</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO			Comments:
COC form is properly signed in relinquished/received sections?	YES NO			Comments:
Sample containers intact and sealed?	YES NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO			Sample IDs and Containers Affected:
Samples received within holding time?	YES NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO			Analyses Affected:
VOA vial headspace < 6 mm?	YES NO N/A			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO₃+NO₂, Alkalinity, Total Phosphorus, and all Organics methods.

GP.25.A r2 Sample Receipt Log

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for October 2023

MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
2023	1	SUN	67.5	8,116,327	0.93	1.02	7.3	0.02	0	1.00	JEFFC	8:15 AM
	2	Mon	67.0	8,127,396	0.95	1.04	7.2	0.01	0	0.99	JEFFC	1:00 PM
	3	Tues	69.1	8,127,396	0.95	1.04	7.2	0.01	0	0.99	JEFFC	2:00 PM
	4	Wed	70.5	8,127,396	0.95	1.04	7.2	0.01	0	0.98	JEFFC	9:00 AM
	5	Thurs	68.0	8,140,915	1.05	1.10	7.2	0.01	0	1.01	JEFFC	1:00 PM
	6	Fri	61.5	11.37	8,150,812	0.58	0.63	0.03	0	2.28	JEFFC	3:30 PM
	7	SAT	60.7	10.77	8,150,812	0.58	0.63	0.02	0	2.21	JEFFC	8:00 AM
	8	SUN	61.5	9.16	8,150,812	0.58	0.62	0.02	0	2.27	JEFFC	8:30 AM
	9	Mon	61.2	11.57	8,161,742	0.70	0.75	0.03	0	1.27	JEFFC	8:00 AM
	10	Tues	61.4	9.52	8,161,742	0.63	0.67	0.01	0	1.27	JEFFC	11:30 AM
	11	Wed	59.0	10.10	8,172,888	0.61	0.67	0.02	0	1.68	JEFFC	2:00 PM
	12	Thurs	59.6	10.98	8,185,191	0.65	0.73	0.03	0	1.38	JEFFC	1:30 PM
	13	Fri	61.0	10.72	8,203,554	0.65	0.81	0.02	0	0.95	JEFFC	1:00 PM
	14	SAT	56.8	8.59	8,203,554	0.72	0.81	0.02	0	1.47	JEFFC	11:00 AM
	15	SUN	59.6	11.26	8,214,885	0.70	0.78	0.01	0	1.32	JEFFC	8:00 AM
	16	Mon	59.6	10.19	8,214,885	0.70	0.78	0.01	0	1.32	JEFFC	8:00 AM
	17	Tues	61.6	8.79	8,214,885	0.70	0.78	0.01	0	1.32	JEFFC	8:00 AM
	18	Wed	62.3	11.51	8,221,642	0.74	0.78	0.01	0	1.32	JEFFC	7:00 AM
	19	Thurs	62.0	9.18	8,221,642	0.74	0.78	0.01	0	1.31	JEFFC	5:00 AM
	20	Fri	59.9	11.33	8,236,341	0.74	0.79	0.03	0	1.52	JEFFC	11:00 AM

 WATER Samples
  Sewage Samples



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J0660
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23J0660-01	Drinking Water	10/05/2023 12:05	10/5/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1857
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/11/2023 16:46

Lab Sample ID#: 23J0660-01
Sample Type: Drinking Water
Sample Source:
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 10/05/2023 12:05
Receipt Date: 10/05/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.16	mg/L		0.200	PS	10/05/23 12:05	10/05/23 12:05
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	JP	10/05/23 14:53	10/06/23 16:00
E. Coli	Absent	per 100 mL		1	JP	10/05/23 14:53	10/06/23 16:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

 HEADQUARTER
803 Philadelphia St.
Middletown, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

 SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

 NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1857


2310660

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
CIRCLE ONE: 704-KITCHEN-MAIN SINK 802 ROOM 204 SINK	2310660			DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 1.16
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
Notes/Special Instructions: Drinking Water Monticau Jr/Sr - Monthly							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.02% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <i>[Signature]</i> Date/Time 10/5/23 10:55				Company/Name: MONTICAU SCHOOL DISTRICT Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: Phone Number: Cell Phone: 724-406-4426 Email Address: jcambell@monticau.org Billing Address: PWSID: 5100324			
Relinquished By: (Signature) <i>[Signature]</i> Date/Time 10/5/23 14:00				Received By: (Signature) <i>[Signature]</i> Date/Time 10-5-23 14:00			
Relinquished By: (Signature) Date/Time				Received By: (Signature) Date/Time			
Correct Preservations <i>[Signature]</i> / N / NA				Correct Containers <i>[Signature]</i> / N / NA			
Receipt Temperature 1.2 #11							

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.16	100523	802		100523	D	1205	32382	23J0660-01	BROWNKA_152
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1205	32382	23J0660-01	BROWNKA_153



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J1467
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23J1467-01	Drinking Water	10/12/2023 11:50	10/12/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-6002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/13/2023 13:42

Lab Sample ID#: 23J1467-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 10/12/2023 11:50
Receipt Date: 10/12/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.710	mg/L		0.200	PS	10/12/23 11:50	10/12/23 11:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 of 1

HEADQUARTER
803 Philadelphia St.
Adelphi, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 298-TEST
FAX: (724) 298-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2301967	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date/Time				
Distribution: 704	01	AD1823	1150	DW	Field	Field	Free Chlorine 0.71 mg/L

ROTATION

WK 1 - 704 Kitchen Sink

WK 2 - 802 Room 204 Sink

WK 3 - 803 Admin Sink

WK 4 - 804 400 Hall RR Sink

WK 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Monteau Jr/Sr - Weekly

Sampled By: (Signature) <i>[Signature]</i> Date/Time 10/18/23 11:50 Relinquished By: (Signature) <i>[Signature]</i> Date/Time 10/18/23 13:40 Relinquished By: (Signature) Date/Time Correct Preservations <i>(V) N / NA</i> Correct Containers <i>(V) N / NA</i> Receipt Temperature <i>6.9 °C</i>	Company/Name: MONTICAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@monticau.org Email Address: jcampbell@monticau.org Billing Address: 5100324 PWSID: 5100324
--	---

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	101223	704		101223	D	1150	32382	23J1467-01	BROWNK 805
5100324	1013	FREE CHLORINE	301	1.16	100523	802		100523	D	1205	32382	23J0660-01	BROWNK 152
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100623	D	1205	32382	23J0660-01	BROWNK 153



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

23 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J2240
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23J2240-01	Drinking Water	10/19/2023 11:57	10/19/23 13:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/23/2023 14:45

Lab Sample ID#: 23J2240-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 10/19/2023 11:57

Receipt Date: 10/19/2023 13:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.850	mg/L		0.200	PS	10/19/23 11:57	10/19/23 11:57

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

 SE 1 OF 1

 HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

 SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

 NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

 NORTHWEST DIVISION
950 Main Street
Shippensburg, PA 17
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL#

23J2240

Distribution: 803

01

Sample Type

Grab

Date

Time

Matrix

of Bottles

Container Type

Analysis Requested

Preservative

Field

Free Chlorine

mg/L

DWC

Field

Field

0.85

mg/L

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:.

Drinking Water Monteau Jr/Sr - Weekly

MONTEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcampbell@monteau.org

5100324

Sampled By: (Signature)

Date/ Time

10/19/03 08 1157

Relinquished By: (Signature)

Date/ Time

10/19/03 08 1347

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations

Correct Containers

Receipt Temperature

PWSID:

5100324

5100324: MONITEAU JR/SR HIGH SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	101223	704		101223	D	1150	32382	23J1467-01	BROWNKA_605
5100324	1013	FREE CHLORINE	301	1.16	100523	802		100523	D	1205	32382	23J0660-01	BROWNKA_152
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100623	D	1205	32382	23J0660-01	BROWNKA_153
5100324	1013	FREE CHLORINE	301	0.85	101923	803		101923	D	1157	32382	23J2240-01	BROWNKA_1156



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 November 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J2884
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23J2884-01	Drinking Water	10/26/2023 10:53	10/26/23 13:34	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 11/02/2023 10:46

Lab Sample ID#: 23J2884-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/26/2023 10:53
Receipt Date: 10/26/2023 13:34

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.760	mg/L		0.200	PS	10/26/23 10:53	10/26/23 10:53

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

 HEADQUARTER
803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

 SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

 NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

 NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date/Time				
Distribution: <u>804</u>	<u>7337854</u>		<u>10/26/03</u>	DW	Field	Field	Free Chlorine <u>0.76</u> mg/L
ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink							
 23J2884							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Notes/Special Instructions:						Drinking Water Monticau Jr/Sr - Weekly	
Sampled By: (Signature) <u>[Signature]</u> Date/Time <u>10/26/03 10:53</u>						Company/Name: MONTICAU SCHOOL DISTRICT	
Relinquished By: (Signature) <u>[Signature]</u> Date/Time <u>10/26/03 13:55</u>						Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL	
Relinquished By: (Signature) _____ Date/Time _____						Contact Person: _____ Phone Number: _____ Cell Phone: _____	
Relinquished By: (Signature) _____ Date/Time _____						Email Address: jcampbell@monticau.org Billing Address: _____ PWSID: 5100324	
Correct Preservations Y/N/NA <u>Y/N/NA</u>						Correct Containers Y/N/NA <u>Y/N/NA</u>	
Correct Temperature <u>—</u>						Receipt Temperature <u>—</u>	

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	101223	704		101223	D	1150	32382	23J1467-01	BROWNKA_605
5100324	1013	FREE CHLORINE	301	1.16	100523	802		100523	D	1205	32382	23J0660-01	BROWNKA_152
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1205	32382	23J0660-01	BROWNKA_153
5100324	1013	FREE CHLORINE	301	0.85	101923	803		101923	D	1157	32382	23J2240-01	BROWNKA_1156
5100324	1013	FREE CHLORINE	301	0.76	102623	804		102623	D	1053	32382	23J2884-01	BROWNKA_1743

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for October 2023

Dassa McKinney Elementary School Water Treatment Facility										
Month	Oct.	2023								
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sun									
2	Mon	8.7	0.02	0.72	0.80	2.54	14382000	Jeff R	3:30P	4300
3	Tues	8.7	0.06	0.72	0.78	2.53	14386300	Jeff R	3:30P	4300
4	Wed	8.7	0.03	0.73	0.83	2.69	14391100	Jeff R	3:30P	4800
5	Thurs	8.7	0.02	0.78	0.88	2.85	14395100	Jeff R	3:30P	4000
6	Fri	8.7	0.00	0.82	0.94	3.16	14399100	Jeff R	3:30P	4000
7	Sat									
8	Sun									
9	Mon	8.7	0.00	0.85	0.95	3.28	14400600	Jeff R	3:30P	1500
10	Tues	8.7	0.02	0.78	0.87	3.68	14404500	Jeff R	3:30P	3900
11	Wed	8.7	0.01	0.66	0.74	1.94	14408300	Jeff R	3:30P	3700
12	Thurs	8.7	0.02	0.69	0.77	2.12	14412400	Jeff R	3:30P	4100
13	Fri	8.7	0.00	0.75	0.85	2.24	14415900	Jeff R	3:30P	3500
14	Sat									
15	Sun									
16	Mon	8.7	0.00	0.63	0.75	2.52	14418800	Jeff R	1:30P	2900
17	Tues									
18	Wed	8.7	0.05	0.79	0.92	2.90	14426300	Jeff R	12:30P	7500
19	Thurs									
20	Fri	8.7	0.05	0.85	0.99	3.27	14433500	Jeff R	12:00P	7200
21	Sat									
22	Sun									
23	Mon	8.7	0.03	0.78	0.89	2.88	14439300	Jeff R	3:30P	5700
24	Tues	8.7	0.00	0.75	0.87	2.54	14443000	Jeff R	3:30P	3700
25	Wed	8.7	0.02	0.82	0.95	2.62	14446800	Jeff R	3:30P	3800
26	Thurs	8.7	0.02	0.78	0.88	2.75	14450700	Jeff R	3:30P	3900
27	Fri	8.7	0.04	0.78	0.89	2.82	14454000	Jeff R	3:30P	3300
28	Sat									
29	Sun									
30	Mon	8.7	0.02	0.69	0.77	2.44	14457800	Jeff R	3:30P	3800
31	Tues									

Meter Reading 9/29/23 - 14377,700



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J0664
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23J0664-01	Drinking Water	10/05/2023 11:40	10/5/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monroeville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/11/2023 16:46

Lab Sample ID#: 23J0664-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 10/05/2023 11:40
Receipt Date: 10/05/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	1.20	mg/L		0.200	PS	10/05/23 11:40	10/05/23 11:40
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	JP	10/05/23 14:53	10/06/23 16:00
E. Coli	Absent	per 100 mL		1	JP	10/05/23 14:53	10/06/23 16:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 of 1

QUARTER Philadelphia St. Philadelphia, PA 19101 (215) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15386 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montourville, PA 17754 (570) 321-8003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharsville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	--	---	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESI#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK	2310664			DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 1.20 mg/L
802 ROOM 617 SINK	01						

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

2310664

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) Date/ Time 10523 08 1200	Company/Name: Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: Phone Number: 724-406-4426 Email Address: jcampbell@monteau.org Billing Address: PWSID: 5100316
Relinquished By: (Signature) Date/ Time 10523 08 1200	Received By: (Signature) Date/ Time 10523 08 1200
Relinquished By: (Signature) Date/ Time	Received By: (Signature) Date/ Time
Relinquished By: (Signature) Date/ Time	Received By: (Signature) Date/ Time
Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature 1.2 #4	Correct Containers Y/N/NA Receipt Temperature 1.2 #4

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	1.2	100523	802		100523	D	1140	32382	23J0664-01	BROWNKA_150
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1140	32382	23J0664-01	BROWNKA_151



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 466-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J1463
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23J1463-01	Drinking Water	10/12/2023 11:37	10/12/23 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/13/2023 13:43

Lab Sample ID#: 23J1463-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 10/12/2023 11:37
Receipt Date: 10/12/2023 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.770	mg/L		0.200	PS	10/12/23 11:37	10/12/23 11:37

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

SEADQUARTER 803 Philadelphia St. Philadelphia, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376
---	--

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTH
950 Mai
Sharpsv
(724) 45
FAX: (724) 403-4205



2311463

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2301403	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: 801	61	10/28/23	11:57	DW	Field	Field	Free Chlorine 0.77 mg/L

[illegible]

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 605 Sink

Wk 4 - 804 Room 408 Sink

PK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW);

2 THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY
 ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)		10/28/23	09 1137
Date/Time		10/28/23	11 1340
Relinquished By: (Signature)			
Date/Time			
Relinquished By: (Signature)			
Date/Time			
Relinquished By: (Signature)			
Date/Time			
Correct Preservations		☒ Y / ☐ N / ☐ NA	Correct Containers
		☒ Y / ☐ N / ☐ NA	Receipt Temperature
			6.9 #41
Company/Name:			
Address:			
391 HOOKER ROAD			
WEST SUNBURY, PA 16061			
JEFFREY CAMPBELL			
Contact Person:			
Phone Number:			
774-406-4426			
Cell Phone:			
icampbell@monteau.org			
Email Address:			
Billing Address:			
PW/SID:			
5100316			

Department of Environmental Protection

E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.77	101223	801		101223	D	1137	32382	23J1483-01	BROWNKA 604
5100316	1013	FREE CHLORINE	301	1.2	100523	802		100523	D	1140	32382	23J0664-01	BROWNKA 150
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1140	32382	23J0664-01	BROWNKA 151



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

23 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J2239
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23J2239-01	Drinking Water	10/19/2023 11:43	10/19/23 13:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/23/2023 14:46

Lab Sample ID#: 23J2239-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 10/19/2023 11:43
Receipt Date: 10/19/2023 13:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.580	mg/L		0.200	PS	10/19/23 11:43	10/19/23 11:43

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

35 1 OF 1

HEADQUARTER
803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhies, PA 15366
(724) 258-TEST
FAX: (724) 258-8378

NORTHERN DIVISION
435 Broad Street
Montboursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
850 Main Street
Sharnsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2312239	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: 803	01	10/19/03	1143	DW	Field	Field	Free Chlorine 0.58 mg/L
 2312239							
ROTATION Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Notes/Special Instructions: Drinking Water Dasse McKinney - Weekly							
Company/Name: Address: Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID: MONTICAU SCHOOL DISTRICT 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcambell@monticau.org 5100316							
Sampled By: (Signature)	Date/Time	Received By: (Signature)	Date/Time	Received By: (Signature)	Date/Time	Received By: (Signature)	Date/Time
Relinquished By: (Signature)	Date/Time	Relinquished By: (Signature)	Date/Time	Relinquished By: (Signature)	Date/Time	Relinquished By: (Signature)	Date/Time
Correct Preservations (Y) N / NA	Correct Containers (Y) N / NA	Receipt Temperature					

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.77	101223	801		101223	D	1137	32382	23J1463-01	BROWNKA_604
5100316	1013	FREE CHLORINE	301	1.2	100523	802		100523	D	1140	32382	23J0664-01	BROWNKA_150
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1140	32382	23J0664-01	BROWNKA_151
5100316	1013	FREE CHLORINE	301	0.58	101923	803		101923	D	1143	32382	23J2239-01	BROWNKA_1155



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

23 October 2023

Monteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J2239
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23J2239-01	Drinking Water	10/19/2023 11:43	10/19/23 13:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/23/2023 14:46

Lab Sample ID#: 23J2239-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 10/19/2023 11:43
Receipt Date: 10/19/2023 13:55

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.580	mg/L		0.200	PS	10/19/23 11:43	10/19/23 11:43

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE ___ 1 ___ OF ___ 1 ___

HEADQUARTER 803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	☒	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	☐	NORTHERN DIVISION 435 Broad Street Monroeville, PA 17134 (570) 321-9003 FAX: (570) 321-1957	☐	NORTHWEST DIVISION 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209	☐
--	-------------------------------------	--	--------------------------	--	--------------------------	---	--------------------------

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: <u>803</u>	<u>23J2239</u>			DW	Field	Field	Free Chlorine <u>0.58</u> mg/L

ROTATION

WK 1 - 801 Kitchen Sink
 WK 2 - 802 Room 617 Sink
 WK 3 - 803 Room 606 Sink
 WK 4 - 804 Room 408 Sink
 WK 5 - 802 Room 617 Sink



23J2239

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (signature) <u>[Signature]</u> Date/Time <u>10/19/03</u> <u>8:14:43</u>	Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@monteau.org Billing Address: 5100316 PWSID:
Relinquished By: (signature) <u>[Signature]</u> Date/Time <u>10/19/03</u> <u>1347</u>	Received By: (signature) <u>[Signature]</u> Date/Time <u>10/19/03</u> <u>13:59</u>
Relinquished By: (signature) <u>[Signature]</u> Date/Time	Received By: (signature) <u>[Signature]</u> Date/Time
Relinquished By: (signature) <u>[Signature]</u> Date/Time	Received By: (signature) <u>[Signature]</u> Date/Time
Correct Preservations <u>(X) N / NA</u>	Correct Containers <u>(X) N / NA</u>
Receipt Temperature <u>41.2</u>	Receipt Temperature <u>41.2</u>

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.77	101223	801		101223	D	1137	32382	23J1463-01	BROWNKA_604
5100316	1013	FREE CHLORINE	301	1.2	100623	802		100523	D	1140	32382	23J0664-01	BROWNKA_150
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1140	32382	23J0664-01	BROWNKA_151
5100316	1013	FREE CHLORINE	301	0.58	101923	803		101923	D	1143	32382	23J2239-01	BROWNKA_1155



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 November 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23J2886
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23J2886-01	Drinking Water	10/26/2023 10:33	10/26/23 13:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 11/02/2023 10:46

Lab Sample ID#: 23J2886-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 10/26/2023 10:33
Receipt Date: 10/26/2023 13:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.710	mg/L		0.200	PS	10/26/23 10:33	10/26/23 10:33

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER 803 Philadelphia St. Malvern, PA 19351 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Vleet, PA 15386 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Mount Laurel, PA 17754 (570) 321-5003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209
--	--	---	---

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESI #	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 804	253886	10/26/03	1035	DW	Field	Field	Free Chlorine 0.71 mg/L

ROTATION

WK 1 - 801 Kitchen Sink
 WK 2 - 802 Room 617 Sink
 WK 3 - 803 Room 606 Sink
 WK 4 - 804 Room 408 Sink
 WK 5 - 802 Room 617 Sink



23J2886

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:.

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Company/Name:

MONTEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD

Contact Person:

WEST SUNBURY, PA 16061

Phone Number:

JEFFREY CAMPBELL

Cell Phone:

724-406-4426

Email Address:

jcampbell@monteau.org

Billing Address:

5100316

PWSID:

Correct Preservations Y/N (NA)

Correct Containers Y/N (NA)

Receipt Temperature

Sampled By: (Signature)

Date/ Time

10/26/03 1035

Relinquished By: (Signature)

Date/ Time

10/26/03 1035

Relinquished By: (Signature)

Date/ Time

10/26/03 1035

Relinquished By: (Signature)

Date/ Time

10/26/03 1035

Correct Preservations Y/N (NA)

Correct Containers Y/N (NA)

Receipt Temperature

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.77	101223	801		101223	D	1137	32382	23J1463-01	BROWNKA_604
5100316	1013	FREE CHLORINE	301	1.2	100523	802		100523	D	1140	32382	23J0664-01	BROWNKA_150
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100623	802		100523	D	1140	32382	23J0664-01	BROWNKA_151
5100316	1013	FREE CHLORINE	301	0.58	101923	803		101923	D	1143	32382	23J2239-01	BROWNKA_1155
5100316	1013	FREE CHLORINE	301	0.71	102623	804		102623	D	1033	32382	23J2886-01	BROWNKA_1742