

# Radon Testing Results - Pine Creek Elementary

## Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Pine Creek Elementary	School Building	Breezeway A	9545604	12/7/2020	Detector Kit	2.0
Pine Creek Elementary	School Building	Breezeway B	9545403	12/7/2020	Blank	0.3
Pine Creek Elementary	School Building	Classroom A	9545610	12/7/2020	Detector Kit	2.5
Pine Creek Elementary	School Building	Classroom D	9545333	12/7/2020	Duplicate	2.5
Pine Creek Elementary	School Building	Gym A	9545611	12/7/2020	Detector Kit	1.7
Pine Creek Elementary	School Building	Gym D	9545617	12/7/2020	Duplicate	1.7
Pine Creek Elementary	Teacherage	Office	9545634	12/7/2020	Detector Kit	2.2
Pine Creek Elementary	Teacherage	T Bedroom 1	9545317	12/7/2020	Detector Kit	0.6
Pine Creek Elementary	Teacherage	T Bedroom 1b	9545320	12/7/2020	Blank	0.3
Pine Creek Elementary	Teacherage	T Bedroom 2	9545309	12/7/2020	Detector Kit	1.1
Pine Creek Elementary	Teacherage	T Bedroom 3	9545618	12/7/2020	Detector Kit	0.3
Pine Creek Elementary	Teacherage	T Living Room A	9545334	12/7/2020	Detector Kit	0.6
Pine Creek Elementary	Teacherage	T Living Room D	9545305	12/7/2020	Duplicate	0.5
			9538303		Spike	30.9

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- [1 number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.