

Attachment I - Lead in Water Sample Results Summary 2021

School Name: Point Pleasant High School

| Outlet Code | Sample ID | Location/Description | Result (ppb) | Above AL? |
|-------------|---------------|-----------------------------------|--------------|-----------|
| 1-DW | 13-0805-HS-01 | Gym hall by boys locker room; WF | ND | No |
| 2-IM | 13-0805-HS-02 | Trainer's Room; ice machine | ND | No |
| 3-IM | 13-0805-HS-03 | Trainer's Room; ice machine | ND | No |
| 4-S | 13-0805-HS-04 | Main Office kitchenette; sink | ND | No |
| 6-DW | 13-0805-HS-05 | Girls locker room; WF (left) | 4.6 | No |
| 7-DW | 13-0805-HS-06 | Boys locker room; Water fountain | ND | No |
| 8-NS | 13-0805-HS-07 | Nurse's office; sink | ND | No |
| 9-DW | 13-0805-HS-08 | Cafeteria; water fountain (left) | ND | No |
| 10-DW | 13-0805-HS-09 | Cafeteria; water fountain (right) | ND | No |
| 11-S | 13-0805-HS-10 | Kitchen; cleaning sink | 1.14 | No |
| 12-S | 13-0805-HS-11 | Kitchen; sink (right) | ND | No |
| 13-DWR | 13-0805-HS-12 | Kitchen; dishwasher | 63 | Yes |
| 33-S | 13-0805-HS-13 | Home Ec Room A-10; sink | 1.58 | No |
| 15-S | 13-0805-HS-14 | Kitchen; diswashing sink | 1.73 | No |
| 16-DW | 13-0805-HS-15 | Hall by Guidance; water fountain | ND | No |
| 17-DW | 13-0805-HS-16 | Hall by Room A-13 | ND | No |
| 18-DW | 13-0805-HS-17 | Hall by Room 115; WF (left) | ND | No |
| 19-DW | 13-0805-HS-18 | Hall by Room 115; WF (right) | ND | No |
| 20-DW | 13-0805-HS-19 | Hall by Choral Room; WF | ND | No |
| 21-DW | 13-0805-HS-20 | Auditorium Lobby; water fountain | ND | No |

Action Level (AL) ≥15.5 parts per billion (ppb)

Attachment I - Lead in Water Sample Results Summary 2021

School Name: Point Pleasant High School

| Outlet Code | Sample ID | Location/Description | Result (ppb) | Above AL? |
|-------------|---------------|--|--------------|-----------|
| 22-DW | 13-0805-HS-21 | Hall by Room 108; water fountain | ND | No |
| 23-DW | 13-0805-HS-22 | Hall by Room 208; water fountain | ND | No |
| 24-S | 13-0805-HS-23 | Teacher's Lounge; sink | ND | No |
| 25-DW | 13-0805-HS-24 | Hall by Room 221; WF (left) | ND | No |
| 26-DW | 13-0805-HS-25 | Hall by Room 221; WF (right) | ND | No |
| 27-DW | 13-0805-HS-26 | Hall by Room 230; water fountain | ND | No |
| 28-TL | 13-0805-HS-27 | Teacher's Lounge by Room 230; sink | ND | No |
| 29-S | 13-0805-HS-28 | Home Ec Room A-10; sink | ND | No |
| 30-S | 13-0805-HS-29 | Home Ec Room A-10; sink | 1.37 | No |
| 31-S | 13-0805-HS-30 | Home Ec Room A-10; sink | ND | No |
| 32-S | 13-0805-HS-31 | Home Ec Room A-10; sink | 1.03 | No |
| 33-S | 13-0805-HS-32 | A-1 Special Needs | 1.01 | No |
| 34-IM | 13-0805-HS-33 | Kitchen ice machine; water line | ND | No |
| - | 13-0805-HS-34 | DI Blank | ND | No |
| 13-DWR | 13-0910-HS-01 | Kitchen; dishwasher sprayer (Re-Sample 9/10/2021) | 5.97 | No |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Action Level (AL) ≥ 15.5 parts per billion (ppb)