

Attachment I - Lead in Water Sample Results Summary 2021

School Name: Memorial Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1-S	13-0805-MS-01	Main office; sink	ND	No
2-NS	13-0805-MS-02	Nurse's office restroom; sink	1.06	No
3-NS	13-0805-MS-03	Nurse's office; sink	1.26	No
4-S	13-0805-MS-04	Guidance; sink	1.22	No
5-DW	13-0805-MS-05	Hall by Room 107; water fountain	20.5	Yes
6-DW	13-0805-MS-06	7th Grade by Room 107; WF (left)	ND	No
7-DW	13-0805-MS-07	7th Grade by Room 107; WF (right)	ND	No
8-IM	13-0805-MS-08	Ice machine by Aux. Boiler Room	ND	No
9-DW	13-0805-MS-09	Gym hall/girls side; water fountain	ND	No
10-DW	13-0805-MS-10	Gym hall/boys side; water fountain	ND	No
11-DW	13-0805-MS-11	Cafeteria; water fountain	ND	No
12-S	13-0805-MS-12	Kitchen; sink	7.05	No
13-S	13-0805-MS-13	Kitchen; sink	ND	No
14-S	13-0805-MS-14	Kitchen; handwashing sink	6.22	No
15-S	13-0805-MS-15	Kitchen; dishwashing sink	11.9	No
16-DW	13-0805-MS-16	Hall by Home Ec Room 17	1.3	No
17-S	13-0805-MS-17	Home Economics; sink	1.23	No
18-S	13-0805-MS-18	Home Economics; sink	2.19	No
19-S	13-0805-MS-19	Home Economics; sink	1.8	No
20-S	13-0805-MS-20	Home Economics; sink	2.5	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Attachment I - Lead in Water Sample Results Summary 2021

School Name: Memorial Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
21-S	13-0805-MS-21	Home Economics; sink	ND	No
22-DW	13-0805-MS-22	Cardio Room; water fountain	ND	No
23-DW	13-0805-MS-23	6th Grade/boys by Room 7; WF	ND	No
24-DW	13-0805-MS-24	6th Grade/girls by Room 7; WF	ND	No
25-DW	13-0805-MS-25	Hall by Rm 202; water fountain	ND	No
26-DW	13-0805-MS-26	Hall by Room 207; water fountain	ND	No
27-DW	13-0805-MS-27	Hall by Room 212; water fountain	ND	No
28-DW	13-0805-MS-28	Hall by Room 214 (left); WF	ND	No
29-DW	13-0805-MS-29	Hall by Room 214 (right); WF	ND	No
-	13-0805-MS-30	DI Blank	ND	No
5-DW	13-0910-MS-01	Hall by Room 107; water fountain (Re-Sample 9-10-2021)	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)