

## Attachment I - Lead in Water Sample Results Summary 2021

**School Name: Ocean Road Elementary School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
36-S	13-0805-OC-01	Kitchen; sink	21.1	Yes
37-S	13-0805-OC-02	Kitchen; sink	91.1	Yes
38-S	13-0805-OC-03	Kitchen; sink	5.03	No
35-S	13-0805-OC-22	Faculty Dining Room; sink	ND	No
33-DW	13-0805-OC-04	Hall by cafeteria (right)	ND	No
32-DW	13-0805-OC-05	Hall by cafeteria (center)	ND	No
31-DW	13-0805-OC-06	Hall by cafeteria (left)	1.07	No
30-DW	13-0805-OC-07	Hall by 138; water fountain	ND	No
21-S	13-0805-OC-08	Room 164; sink/water fountain	ND	No
19-S	13-0805-OC-09	Room 167; sink/water fountain	ND	No
17-S	13-0805-OC-10	Room 170; sink/ water fountain	ND	No
29-DW	13-0805-OC-11	Hall by Room 133; water fountain	ND	No
12-DW	13-0805-OC-12	Hall by Room 130	ND	No
1-DW	13-0805-OC-13	Lobby; water fountain #1 (right)	ND	No
2-DW	13-0805-OC-14	Lobby; water fountain #2 (center)	ND	No
3-DW	13-0805-OC-15	Lobby; water fountain #3 (left)	1.7	No
8-NS	13-0805-OC-16	Nurse's office; bathroom sink	ND	No
7-NS	13-0805-OC-17	Nurse's office; eyewash sink	ND	No
4-S	13-0805-OC-18	Main office; sink	ND	No
56-DW	13-0805-OC-19	Hall by Room 217; water fountain	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

School Name: Ocean Road Elementary School

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)