SECTION 281500 - ACCESS CONTROL HARDWARE DEVICES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Card readers, credential cards, and keypads
 - 2. Cables
 - 3. Transformers
- B. Related Requirements:
 - 1. Section 281300 "Access Control System Software and Database Management" for control and monitoring applications, workstations, and interfaces.

1.3 DEFINITIONS

- A. Credential: Data assigned to an entity and used to identify that entity.
- B. DTS: Digital Termination Service. A microwave-based, line-of-sight communication provided directly to the end user.
- C. Identifier: A credential card; keypad personal identification number; or code, biometric characteristic, or other unique identification entered as data into the entry-control database for the purpose of identifying an individual. Where this term is presented with an initial capital letter, this definition applies.
- D. Location: A Location on the network having a PC-to-controller communications link, with additional controllers at the Location connected to the PC-to-controller link with a TIA 485-A communications loop. Where this term is presented with an initial capital letter, this definition applies.
- E. PC: Personal computer. Applies to the central station, workstations, and file servers.
- F. RAS: Remote access services.
- G. RF: Radio frequency.
- H. ROM: Read-only memory. ROM data are maintained through losses of power.
- I. TCP/IP: Transport control protocol/Internet protocol.

- J. TWAIN: Technology without an Interesting Name. A programming interface that lets a graphics application, such as an image editing program or desktop publishing program, activate a scanner, frame grabber, or other image-capturing device.
- K. WMP: Windows media player.
- L. Wiegand: Patented magnetic principle that uses specially treated wires embedded in the credential card.
- M. WYSIWYG: What You See Is What You Get. Text and graphics appear on the screen the same as they will in print.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include rated capacities, operating characteristics, and furnished specialties and accessories. Reference each product to a location on Drawings. Test and evaluation data presented in Product Data shall comply with SIA BIO-01.
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
 - 1. Diagrams for cable management system.
 - 2. System labeling schedules, including electronic copy of labeling schedules that are part of the cable and asset identification system of the software specified in Parts 2 and 3.
 - 3. Wiring Diagrams. For power, signal, and control wiring. Show typical wiring schematics.
 - 4. Battery and charger calculations for central station, workstations, and controllers.

1.5 INFORMATIONAL SUBMITTALS

A. Field quality-control reports.

1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For security system to include in emergency, operation, and maintenance manuals. In addition to items specified in Section 017823 "Operation and Maintenance Data," include the following:
 - 1. Hard copies of manufacturer's specification sheets, operating specifications, design guides, user's guides for software and hardware, and PDF files on [**USB**] [cloud] media of the hard-copy submittal.
 - 2. System installation and setup guides with data forms to plan and record options and setup decisions.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers trained and approved by manufacturer.
 - 1. Cable installer must have on staff an RCDD certified by Building Industry Consulting Service International.
- B. Source Limitations: Obtain central station, workstations, controllers, Identifier readers, and all software through one source from single manufacturer.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Store in temperature- and humidity-controlled environment in original manufacturer's sealed containers. Maintain ambient temperature between 50 and 85 deg F (10 and 30 deg C), and not more than 80 percent relative humidity, noncondensing.
- B. Open each container; verify contents against packing list; and file copy of packing list, complete with container identification, for inclusion in operation and maintenance data.
- C. Mark packing list with the same designations assigned to materials and equipment for recording in the system labeling schedules that are generated by software specified in "Cable and Asset Management Software" Article.
- D. Save original manufacturer's containers and packing materials and deliver as directed under provisions covering extra materials.

PART 2 - PRODUCTS

2.1 OPERATION

- A. Security access system hardware shall use a single database for access-control and credentialcreation functions.
- 2.2 PERFORMANCE REQUIREMENTS
 - A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
 - B. Comply with NFPA 70, "National Electrical Code."
 - C. Comply with SIA DC-01 and SIA DC-03

2.3 CARD READERS, CREDENTIAL CARDS, AND KEYPADS

- A. Manufacturers:
 - 1. PDK ProdataKey
 - 2. Motorola Avigilon
- B. Card-Reader Power: Powered from its associated controller, including its standby power source, and shall not dissipate more than 5 W.
- C. Response Time: Card reader shall respond to passage requests by generating a signal that is sent to the controller. Response time shall be 800 ms or less, from the time the card reader finishes reading the credential card until a response signal is generated.
- D. Enclosure: Suitable for surface, semi-flush, pedestal, or weatherproof mounting. Mounting types shall additionally be suitable for installation in the following locations:
 - 1. Indoors, controlled environment.
 - 2. Indoors, uncontrolled environment.

- 3. Outdoors, with built-in heaters or other cold-weather equipment to extend the operating temperature range as needed for operation at the site.
- E. Display: Digital visual indicator shall provide visible status indications and user prompts. Indicate power on or off, whether user passage requests have been accepted or rejected, and whether the door is locked or unlocked.
- F. Proximity Readers:
 - 1. Passive-detection proximity card readers shall use a swept-frequency, RF field generator to read the resonant frequencies of tuned circuits laminated into compatible credential cards. The resonant frequencies read shall constitute a unique identification code number.
 - 2. The card reader shall read proximity cards in a range from direct contact to at least 6 inches from the reader.
- G. Keypads:
 - 1. Entry-control keypads shall use a unique combination of alphanumeric and other symbols as an Identifier.
 - 2. Keypads shall contain an integral alphanumeric/special symbols keyboard with symbols arranged in ascending ASCII-code ordinal sequence.
 - 3. Communication protocol shall be compatible with the local processor.
- H. Communication Protocol: Compatible with local processor.
- I. Touch-Plate and Contactless Card Reader: The reader shall have "flash" download capability to accommodate card format changes. The card reader shall have capability of transmitting data to security control panel and shall comply with ISO/IEC 7816.
- J. Credential Card Modification: Entry-control cards shall be able to be modified by lamination direct print process during the enrollment process without reduction of readability. The design of the credential cards shall allow for the addition of at least one slot or hole to accommodate the attachment of a clip for affixing the credential card to the badge holder used at the site.
- K. Card Size and Dimensional Stability: Credential cards shall be 2-1/8 by 3-3/8 inches (54 by 86 mm). The credential card material shall be dimensionally stable so that an undamaged card with deformations resulting from normal use shall be readable by the card reader.
- L. Card Material: Abrasion resistant, nonflammable, nontoxic, and impervious to solar radiation and effects of ultraviolet light.
- M. Card Construction:
 - 1. Core and laminate or monolithic construction.
 - 2. Lettering, logos, and other markings shall be hot stamped into the credential material or direct printed.
 - 3. Furnish equipment for on-site assembly and lamination of credential cards.
- N. Enclosures: Flush or surface mounting. Push buttons shall be suitable for flush mounting in the switch enclosures.
- O. Enclosures shall additionally be suitable for installation in the following locations:

- 1. Indoors, controlled environment.
- 2. Indoors, uncontrolled environment.
- 3. Outdoors.
- P. Power: Push-button switches shall be powered from their associated controller, using dc control.

2.4 CABLES

- A. General Cable Requirements: Comply with requirements as recommended by system manufacturer for integration requirement.
- B. PVC-Jacketed, TIA 232-F.
 - 1. Three, No. 22 AWG, stranded (7x30) tinned copper conductors.
 - 2. Polypropylene insulation.
 - 3. Aluminum foil-polyester tape shield with 100 percent shield coverage.
 - 4. PVC jacket.
 - 5. Conductors are cabled on common axis with No. 24 AWG, stranded (7x32) tinned copper drain wire.
 - 6. Flame Resistance: Comply with UL 1581.
- C. Plenum-Rated TIA 232-F Cables:
 - 1. Three, No. 22 AWG, stranded (7x30) tinned copper conductors.
 - 2. PE insulation.
 - 3. Aluminum foil-polyester tape shield with 100 percent shield coverage.
 - 4. Fluorinated ethylene propylene jacket.
 - 5. Conductors are cabled on common axis with No. 24 AWG, stranded (7x32) tinned copper drain wire.
 - 6. Flame Resistance: Comply with NFPA 262.
- D. PVC-Jacketed, TIA 485-A Cables:
 - 1. Paired, two pairs, twisted, No. 22 AWG, stranded (7x30) tinned copper conductors.
 - 2. PVC insulation.
 - 3. Unshielded.
 - 4. PVC jacket.
 - 5. NFPA 70 Type: Type CM.
 - 6. Flame Resistance: Comply with UL 1581.
- E. Plenum-Rated TIA 485-A Cables:
 - 1. Paired, two pairs, No. 22 AWG, stranded (7x30) tinned copper conductors.
 - 2. Fluorinated ethylene propylene insulation.
 - 3. Unshielded.
 - 4. Fluorinated ethylene propylene jacket.
 - 5. NFPA 70 Type: Type CMP
 - 6. Flame Resistance: NFPA 262, Flame Test.
- F. Multiconductor, PVC, Reader and Wiegand Keypad Cables:
 - 1. No. 22 AWG, paired and twisted multiple conductors, stranded (7x30) tinned copper conductors, semirigid PVC insulation, overall aluminum-foil/polyester-tape shield with 100

percent shield coverage, plus tinned copper braid shield with 65 percent shield coverage, and PVC jacket.

- 2. NFPA 70, Type CMG.
- 3. Flame Resistance: UL 1581 vertical tray.
- 4. For TIA 232-F applications.
- G. Paired, PVC, Reader and Wiegand Keypad Cables:
 - 1. Three pairs, twisted, No. 22 AWG, stranded (7x30) tinned copper conductors, polypropylene insulation, individual aluminum-foil/polyester-tape shielded pairs each with No. 22 AWG, stranded tinned copper drain wire, 100 percent shield coverage, and PVC jacket.
 - 2. NFPA 70, Type CM.
 - 3. Flame Resistance: UL 1581 vertical tray.
- H. Paired, PVC, Reader and Wiegand Keypad Cables:
 - 1. Three pairs, twisted, No. 20 AWG, stranded (7x28) tinned copper conductors, polyethylene (polyolefin) insulation, individual aluminum-foil/polyester-tape shielded pairs each with No. 22 AWG, stranded (19x34) tinned copper drain wire, 100 percent shield coverage, and PVC jacket.
 - 2. NFPA 70, Type CM.
 - 3. Flame Resistance: UL 1581 vertical tray.
- I. Paired, Plenum-Type, Reader and Wiegand Keypad Cables:
 - 1. Three pairs, No. 22 AWG, stranded (7x30) tinned copper conductors, plastic insulation, individual aluminum-foil/polypropylene-tape shielded pairs each with No. 22 AWG, stranded tinned copper drain wire, 100 percent shield coverage, and fluorinated-ethylene-propylene jacket.
 - 2. NFPA 70, Type CMP.
 - 3. Flame Resistance: NFPA 262 flame test.
- J. Multiconductor, Plenum-Type, Reader and Wiegand Keypad Cables:
 - 1. Six conductors, No. 20 AWG, stranded (7x28) tinned copper conductors, fluorinatedethylene-propylene insulation, overall aluminum-foil/polyester-tape shield with 100 percent shield coverage plus tinned copper braid shield with 85 percent shield coverage, and fluorinated-ethylene-propylene jacket.
 - 2. NFPA 70, Type CMP.
 - 3. Flame Resistance: NFPA 262 flame test.
- K. LAN Cabling:
 - 1. Comply with requirements in Section 271513 "Communications Copper Horizontal Cabling."
- 2.5 TRANSFORMERS
 - A. NFPA 70, Class II control transformers, NRTL listed. Transformers for security access-control system shall not be shared with any other system.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine pathway elements intended for cables. Check raceways, cable trays, and other elements for compliance with space allocations, installation tolerances, hazards to cable installation, and other conditions affecting installation.
- B. Examine roughing-in for LAN and control cable conduit systems to PCs, controllers, card readers, and other cable-connected devices to verify actual locations of conduit and back boxes before device installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Comply with recommendations in SIA CP-01.
- B. Comply with TIA 606-B, "Administration Standard for Commercial Telecommunications Infrastructure."
- C. Product Schedules: Obtain detailed product schedules from manufacturer of access-control system or develop product schedules to suit Project. Fill in all data available from Project plans and specifications and publish as Product Schedules for review and approval.
- D. In meetings with Architect and Owner, present Product Schedules and review, adjust, and prepare final setup documents. Use approved, final Product Schedules to set up system software.

3.3 CABLING

- A. Comply with NECA 1, "Good Workmanship in Electrical Construction."
- B. Install cables and wiring according to requirements in Section 270513 "Conductors and Cables for Communications Systems."
- C. Wiring Method: Install wiring in raceway and cable tray except within consoles, cabinets, desks, and counters. Conceal raceway and wiring except in unfinished spaces.
- D. Wiring Method: Install wiring in raceway and cable tray except within consoles, cabinets, desks, and counters and except in accessible ceiling spaces and in gypsum board partitions where unenclosed wiring method may be used. Use NRTL-listed plenum cable in environmental airspaces, including plenum ceilings. Conceal raceway and cables except in unfinished spaces.
- E. Install LAN cables using techniques, practices, and methods that are consistent with Category 6 rating of components and that ensure Category 6 performance of completed and linked signal paths, end to end.
- F. Boxes and enclosures containing security-system components or cabling, and which are easily accessible to employees or to the public, shall be provided with a lock. Boxes above ceiling level in occupied areas of the building shall not be considered accessible. Junction boxes and

small device enclosures below ceiling level and easily accessible to employees or the public shall be covered with a suitable cover plate and secured with tamperproof screws.

G. Install end-of-line resistors at the field device location and not at the controller or panel location.

3.4 CABLE APPLICATION

- A. Comply with TIA 569-D, "Commercial Building Standard for Telecommunications Pathways and Spaces."
- B. Cable application requirements are minimum requirements and shall be exceeded if recommended or required by manufacturer of system hardware.
- C. TIA 232-F Cabling: Install at a maximum distance of 50 ft. (15 m) between terminations.
- D. TIA 485-A Cabling: Install at a maximum distance of 4000 ft. (1220 m) between terminations.
- E. Card Readers:
 - 1. Install number of conductor pairs recommended by manufacturer for the functions specified.
 - 2. Unless manufacturer recommends larger conductors, install No. 22 AWG wire if maximum distance from controller to the reader is 250-feet, and install No. 20 AWG wire if maximum distance is 500-feet.
 - 3. For greater distances, install "extender" or "repeater" modules recommended by manufacturer of the controller.
 - 4. Install minimum No. 18 AWG shielded cable to readers that draw 50 mA or more.
- F. Install minimum No. 16 AWG cable from controller to electrically powered locks. Do not exceed 250-feet between terminations.
- G. Install minimum No. 18 AWG ac power wire from transformer to controller, with a maximum distance of 25-feet between terminations.

3.5 GROUNDING

- A. Comply with Section 270526 "Grounding and Bonding for Communications Systems."
- B. Comply with IEEE 1100, "Recommended Practice for Power and Grounding Electronic Equipment."
- C. Ground cable shields, drain conductors, and equipment to eliminate shock hazard and to minimize ground loops, common-mode returns, noise pickup, cross talk, and other impairments.
- D. Bond shields and drain conductors to ground at only one point in each circuit.
- E. Signal Ground:
 - 1. Terminal: Locate in each equipment room and wiring closet; isolate from power system and equipment grounding.
 - 2. Bus: Mount on wall of main equipment room with standoff insulators.
 - 3. Backbone Cable: Extend from signal ground bus to signal ground terminal in each equipment room and wiring closet.

3.6 INSTALLATION

A. Install card readers and components as shown on the Drawings.

3.7 IDENTIFICATION

- A. In addition to requirements in this article, comply with applicable requirements in Section 270553 "Identification for Communications Systems" and with TIA 606-B.
- B. Develop cable administration drawings for system identification, testing, and management. Use unique, alphanumeric designation for each cable, and label cable and jacks, connectors, and terminals to which it connects with the same designation. Use logical and systematic designations for facility's architectural arrangement.
- C. Label each terminal strip and screw terminal in each cabinet, rack, or panel.
 - 1. All wiring conductors connected to terminal strips shall be individually numbered, and each cable or wiring group being extended from a panel or cabinet to a building-mounted device shall be identified with the name and number of the particular device as shown.
 - 2. Each wire connected to building-mounted devices is not required to be numbered at the device if the color of the wire is consistent with the associated wire connected and numbered within the panel or cabinet.
- D. At completion, cable and asset management software shall reflect as-built conditions.

3.8 SYSTEM SOFTWARE AND HARDWARE

A. Develop, install, and test software and hardware, and perform database tests for the complete and proper operation of systems involved. Assign software license to Owner.

3.9 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
 - 1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
- B. Tests and Inspections:
 - LAN Cable Procedures: Inspect for physical damage and test each conductor signal path for continuity and shorts. Use tester approved for type and kind of installed cable. Test for faulty connectors, splices, and terminations. Test according to TIA 568-C.1, "Commercial Building Telecommunications Cabling Standards - Part 1: General Requirements." Link performance for balanced twisted-pair cables must comply with minimum criteria in TIA 568-C.1.
 - 2. Test each circuit and component of each system. Tests shall include, but are not limited to, measurements of power-supply output under maximum load, signal loop resistance, and leakage to ground where applicable. System components with battery backup shall be operated on battery power for a period of not less than 10 percent of the calculated battery operating time. Provide special equipment and software if testing requires special or dedicated equipment.

- 3. Operational Test: After installation of cables and connectors, demonstrate product capability and compliance with requirements. Test each signal path for end-to-end performance from each end of all pairs installed. Remove temporary connections when tests have been satisfactorily completed.
- C. Devices and circuits will be considered defective if they do not pass tests and inspections.
- D. Prepare test and inspection reports.

3.10 STARTUP SERVICE

- A. Engage a factory-authorized service representative to supervise and assist with startup service.
 - 1. Complete installation and startup checks according to approved procedures that were developed in "Preparation" Article and with manufacturer's written instructions.
 - 2. Enroll and prepare badges and access cards for Owner's operators, management, and security personnel.

3.11 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain security access system. See Section 017900 "Demonstration and Training."
- B. Develop separate training modules for the following:
 - 1. Computer system administration personnel to manage and repair the LAN and databases and to update and maintain software.
 - 2. Operators who prepare and input credentials to man the control station and workstations and to enroll personnel.
 - 3. Security personnel.
 - 4. Hardware maintenance personnel.
 - 5. Corporate management.

END OF SECTION 281500