

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for September 2023



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>

Fri, Oct 6, 2023 at 2:29 PM

To: jcampbell@moniteau.org, mcafoose92@hotmail.com

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 09/01/2023-09/30/2023

Report Due Date: 10/28/2023

Submitted By: Jeffrey Campbell

Submission Id: 417233

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST

ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

FACILITY: MONITEAU JR SR HIGH SCHOOL

LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	09	01	2023	09	30

FROM

PARAMETER	QUANTITY OR LOADING			QUANTITY OR CONCENT		
	VALUE	VALUE	UNITS	VALUE	VALUE	VAL
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		4.21	***	***
	PERMIT REQUIREMENT	***		4.0	***	***
pH (00400)	SAMPLE MEASUREMENT	***		Daily Min	***	8.6
	PERMIT REQUIREMENT	***		7.26	***	9.0
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		6.0	***	Daily
	PERMIT REQUIREMENT	***		Daily Min	5.5	11.
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		***	30.0	60.0
	PERMIT REQUIREMENT	***		***	Avg Mo	IMP
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	36.6	***
	PERMIT REQUIREMENT	***		***	Monitor & Report	***
Flow (50050)	SAMPLE MEASUREMENT	***		***	Avg Mo	***
	PERMIT REQUIREMENT	***		***	5.63	***
Fecal Coliform (74055)	SAMPLE MEASUREMENT	002986	MGD	***	Monitor & Report	***
	PERMIT REQUIREMENT	Monitor & Report		***	Avg Mo	***
	SAMPLE MEASUREMENT	***		***	***	***
	PERMIT REQUIREMENT	***		***	***	***
	SAMPLE MEASUREMENT	***		***	<1.0	<1.
	PERMIT REQUIREMENT	***		***	200	100

DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION		
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	<2.00	<2.00
	PERMIT REQUIREMENT	***	***		***	25.0 Avg Mo	50.0 IMAX
Facility Comments							

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER
----------	---------------	-------------------------------

SEPT 2023 MHS WASTEWATER

Flow	$89,580 \div 30 = 2986$ Daily Avg
------	-----------------------------------

UV $101.4 \div 18 = 5.63$ Daily Avg.

PH Low 7.26 BASIN #1 9/1

High	8.62	Basin #2	9/11
------	------	----------	------

DO Low 4.21 BASIN #1 9/11

High 8.31 Basin #2 9/6

[illegible]



1603 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Benileyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2310595
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2310595-01	Waste Water	09/07/2023 10:00	9/7/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

SS Seed Control did not meet reference method acceptance criteria.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Monitcau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/19/2023 17:01

Lab Sample ID#: 2310595-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 09/07/2023 10:00
Receipt Date: 09/07/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	4.00	mg/L			0.729	AW	09/12/23 09:26	09/12/23 09:26
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	09/12/23 09:02	09/12/23 09:02
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	0.681	mg/L			0.625	AW	09/12/23 09:26	09/12/23 09:26
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L			5	TLL	09/14/23 11:21	09/14/23 11:21
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	3.32	mg/L			0.104	AW	09/11/23 11:12	09/11/23 11:12
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	0.36	mg/L			0.20	JMS	09/12/23 17:00	09/12/23 17:00
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS		2.00	TW	09/08/23 10:45	09/13/23 08:34
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 ml.			1	JP	09/07/23 14:20	09/08/23 11:50



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work O  2310595
-------------------------	---

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN (N/A)	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JD /00382</u>	Samples Received on Ice? ☒ YES NO
Date/Time Received: <u>9/7/23 132</u>	Date Sampled: <u>9/7/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.6</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: ☒ PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES ☒ NO

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	☒ YES NO	Comments:
COC form is properly signed in relinquished/received sections?	☒ YES NO	Comments:
Sample containers intact and sealed?	☒ YES NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	☒ YES NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	☒ YES NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	☒ YES NO	Sample IDs and Containers Affected:
Samples received within holding time?	☒ YES NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	☒ YES NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	☒ YES NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	☒ YES NO	Analyses Affected:
VOA vial headspace < 6 mm?	YES NO ☒ N/A	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES ☒ NO

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO₃+NO₂, Alkalinity, Total Phosphorus, and all Organics methods.

GP.25.A r2 Sample Receipt Log



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

05 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2312257
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2312257-01	Waste Water	09/21/2023 10:00	9/21/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

LL Laboratory control sample below acceptance criteria, result may be biased low.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04860

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/05/2023 10:58

Lab Sample ID#: 2312257-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 09/21/2023 10:00
Receipt Date: 09/21/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry								
			Analytical Method: *** DEFAULT SPECIFIC METHOD			Prep Method: [CALC]		
Total Nitrogen	69.2	mg/L			2.70	AW	09/28/23 10:34	09/28/23 10:34
General Chemistry								
			Analytical Method: ASTM6919-17			Prep Method: No Prep - WetChem		
Ammonia as N	3.45	mg/L		0.165	0.400	DAA	09/28/23 18:33	09/30/23 20:08
General Chemistry								
			Analytical Method: EPA 351.2 2.0			Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	3.90	mg/L			0.625	AW	09/27/23 13:01	09/27/23 13:01
General Chemistry								
			Analytical Method: SM2540 D-15			Prep Method: No Prep - WetChem		
Total Suspended Solids	6	mg/L	L.L.		5	MM	09/25/23 07:48	09/25/23 13:53
General Chemistry								
			Analytical Method: SM4500-NO3 E-16 (discrete)			Prep Method: No Prep - WetChem		
Nitrate/Nitrite	65.3	mg/L			2.08	AW	09/28/23 10:34	09/28/23 10:34
General Chemistry								
			Analytical Method: SM4500-P E-11			Prep Method: SM 4500 P B		
Phosphorus	7.2	mg/L			2.0	JMS	09/26/23 17:56	09/26/23 17:56
General Chemistry								
			Analytical Method: SM5210 B-16			Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB		2.00	TW	09/22/23 11:44	09/27/23 08:27
Microbiology								
			Analytical Method: Colilert-18			Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	09/21/23 13:42	09/22/23 11:32

SAMPLE REQUEST & CHAIN OF CUSTODY

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

[illegible]

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) ON THE MAXIMUM ALLOWED BY LAW;
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY
ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes:

Wastewater

MONTEAU SCHOOL DISTRICT

Sampled by: (Signature)

Date/ Time

Hebraicus hed. B. (Signature)

Date/ Time

Received By: (Signature)

Notes/References

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Defining the

Helinquished By: (Signature)

Date/ Time

Received By: (Signature)

Notes/Time

Correct Preservations	Y / N / NA
1. The first page of the manuscript is blank.	Y
2. The second page of the manuscript is blank.	Y
3. The third page of the manuscript is blank.	Y
4. The fourth page of the manuscript is blank.	Y
5. The fifth page of the manuscript is blank.	Y
6. The sixth page of the manuscript is blank.	Y
7. The seventh page of the manuscript is blank.	Y
8. The eighth page of the manuscript is blank.	Y
9. The ninth page of the manuscript is blank.	Y
10. The tenth page of the manuscript is blank.	Y
11. The eleventh page of the manuscript is blank.	Y
12. The twelfth page of the manuscript is blank.	Y
13. The thirteenth page of the manuscript is blank.	Y
14. The fourteenth page of the manuscript is blank.	Y
15. The fifteenth page of the manuscript is blank.	Y
16. The sixteenth page of the manuscript is blank.	Y
17. The seventeenth page of the manuscript is blank.	Y
18. The eighteenth page of the manuscript is blank.	Y
19. The nineteenth page of the manuscript is blank.	Y
20. The twentieth page of the manuscript is blank.	Y
21. The twenty-first page of the manuscript is blank.	Y
22. The twenty-second page of the manuscript is blank.	Y
23. The twenty-third page of the manuscript is blank.	Y
24. The twenty-fourth page of the manuscript is blank.	Y
25. The twenty-fifth page of the manuscript is blank.	Y
26. The twenty-sixth page of the manuscript is blank.	Y
27. The twenty-seventh page of the manuscript is blank.	Y
28. The twenty-eighth page of the manuscript is blank.	Y
29. The twenty-ninth page of the manuscript is blank.	Y
30. The thirtieth page of the manuscript is blank.	Y
31. The thirty-first page of the manuscript is blank.	Y
32. The thirty-second page of the manuscript is blank.	Y
33. The thirty-third page of the manuscript is blank.	Y
34. The thirty-fourth page of the manuscript is blank.	Y
35. The thirty-fifth page of the manuscript is blank.	Y
36. The thirty-sixth page of the manuscript is blank.	Y
37. The thirty-seventh page of the manuscript is blank.	Y
38. The thirty-eighth page of the manuscript is blank.	Y
39. The thirty-ninth page of the manuscript is blank.	Y
40. The fortieth page of the manuscript is blank.	Y
41. The forty-first page of the manuscript is blank.	Y
42. The forty-second page of the manuscript is blank.	Y
43. The forty-third page of the manuscript is blank.	Y
44. The forty-fourth page of the manuscript is blank.	Y
45. The forty-fifth page of the manuscript is blank.	Y
46. The forty-sixth page of the manuscript is blank.	Y
47. The forty-seventh page of the manuscript is blank.	Y
48. The forty-eighth page of the manuscript is blank.	Y
49. The forty-ninth page of the manuscript is blank.	Y
50. The fiftieth page of the manuscript is blank.	Y
51. The fifty-first page of the manuscript is blank.	Y
52. The fifty-second page of the manuscript is blank.	Y
53. The fifty-third page of the manuscript is blank.	Y
54. The fifty-fourth page of the manuscript is blank.	Y
55. The fifty-fifth page of the manuscript is blank.	Y
56. The fifty-sixth page of the manuscript is blank.	Y
57. The fifty-seventh page of the manuscript is blank.	Y
58. The fifty-eighth page of the manuscript is blank.	Y
59. The fifty-ninth page of the manuscript is blank.	Y
60. The sixtieth page of the manuscript is blank.	Y
61. The sixty-first page of the manuscript is blank.	Y
62. The sixty-second page of the manuscript is blank.	Y
63. The sixty-third page of the manuscript is blank.	Y
64. The sixty-fourth page of the manuscript is blank.	Y
65. The sixty-fifth page of the manuscript is blank.	Y
66. The sixty-sixth page of the manuscript is blank.	Y
67. The sixty-seventh page of the manuscript is blank.	Y
68. The sixty-eighth page of the manuscript is blank.	Y
69. The sixty-ninth page of the manuscript is blank.	Y
70. The seventieth page of the manuscript is blank.	Y
71. The seventy-first page of the manuscript is blank.	Y
72. The seventy-second page of the manuscript is blank.	Y
73. The seventy-third page of the manuscript is blank.	Y
74. The seventy-fourth page of the manuscript is blank.	Y
75. The seventy-fifth page of the manuscript is blank.	Y
76. The seventy-sixth page of the manuscript is blank.	Y
77. The seventy-seventh page of the manuscript is blank.	Y
78. The seventy-eighth page of the manuscript is blank.	Y
79. The seventy-ninth page of the manuscript is blank.	Y
80. The eightieth page of the manuscript is blank.	Y
81. The eighty-first page of the manuscript is blank.	Y
82. The eighty-second page of the manuscript is blank.	Y
83. The eighty-third page of the manuscript is blank.	Y
84. The eighty-fourth page of the manuscript is blank.	Y
85. The eighty-fifth page of the manuscript is blank.	Y
86. The eighty-sixth page of the manuscript is blank.	Y
87. The eighty-seventh page of the manuscript is blank.	Y
88. The eighty-eighth page of the manuscript is blank.	Y
89. The eighty-ninth page of the manuscript is blank.	Y
90. The ninetieth page of the manuscript is blank.	Y
91. The ninety-first page of the manuscript is blank.	Y
92. The ninety-second page of the manuscript is blank.	Y
93. The ninety-third page of the manuscript is blank.	Y
94. The ninety-fourth page of the manuscript is blank.	Y
95. The ninety-fifth page of the manuscript is blank.	Y
96. The ninety-sixth page of the manuscript is blank.	Y
97. The ninety-seventh page of the manuscript is blank.	Y
98. The ninety-eighth page of the manuscript is blank.	Y
99. The ninety-ninth page of the manuscript is blank.	Y
100. The hundredth page of the manuscript is blank.	Y

Correct Containers Y / N / NA

Receivability: Temperature

Company/Name:

Contact Person:

Address:

Phone / Cell:

Email:

JEFFREY CAMPBELL

1810 WEST SUNBURY ROAD

724-406-4426

lcambbell@montiteau.org



SAMPLE RECEIPT AND REVIEW FORM

Client: Monteale

Work Ord

2312257

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other:	Received on Ice? YES NO
Sample Receipt Temperature: °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>9/21/23 1530</u>	Date Sampled: <u>9/21/2023</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other:	
Sample Receipt Temperature: <u>51</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other:	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO			Comments:
COC form is properly signed in relinquished/received sections?	YES NO			Comments:
Sample containers intact and sealed?	YES NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other:
Number of containers received matches number indicated on COC?	YES NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO			Sample IDs and Containers Affected:
Samples received within holding time?	YES NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO			Analyses Affected:
VOA vial headspace < 6 mm?	YES NO <u>N/A</u>			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO₃+NO₂, Alkalinity, Total Phosphorus, and all Organics methods.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 18150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

05 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2312257
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2312257-01	Waste Water	09/21/2023 10:00	9/21/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

LL Laboratory control sample below acceptance criteria, result may be biased low.
BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units
MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/05/2023 10:58

Lab Sample ID#: 23I2257-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 09/21/2023 10:00
Receipt Date: 09/21/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]		
Total Nitrogen	69.2	mg/L			2.70	AW	09/28/23 10:34	09/28/23 10:34
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem		
Ammonia as N	3.45	mg/L		0.165	0.400	DAA	09/28/23 18:33	09/30/23 20:08
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	3.90	mg/L			0.625	AW	09/27/23 13:01	09/27/23 13:01
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem		
Total Suspended Solids	6	mg/L	LL		5	MM	09/25/23 07:48	09/25/23 13:53
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem		
Nitrate/Nitrite	65.3	mg/L			2.08	AW	09/28/23 10:34	09/28/23 10:34
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B		
Phosphorus	7.2	mg/L			2.0	JMS	09/26/23 17:56	09/26/23 17:56
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB		2.00	TW	09/22/23 11:44	09/27/23 08:27
Microbiology	Analytical Method: Collert-18					Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL			1	JP	09/21/23 13:42	09/22/23 11:32

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentlyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL

NORTHERN DIVISION

2312257

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

Sample Identification		Sample Type				Matrix	# of Containers	Container Type Preservative	Analysis Requested
ESL #	ESL #	Composite	Date	Grab	Date				
Effluent Outfall 001	2802557					WW	1	Poly 1000mL Name	CBOD, TSS
						WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
						WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform
						WW	1		Ammonia

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (1 1/2% PER ANNUM ON THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Project Notes:

Wastewater

Company/Name:

MONTICELLO SCHOOL DISTRICT

Contact Person:

JEFFREY CAMPBELL

Address:

1810 WEST SUNBURY ROAD

WEST SUNBURY, PA 16061

724-406-4426

jcambell@monticello.org

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM

Received By: (Signature)

[Signature]

Date/Time

9/21/23 10:00 AM



SAMPLE RECEIPT AND REVIEW FORM



Client: <u>Montev</u>	Work Ord: <u>2312257</u>
-----------------------	--------------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: ____/____/____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>06382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>9/21/23</u>	Date Sampled: <u>9/21/2023</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>51</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO			Comments:
COC form is properly signed in relinquished/received sections?	YES NO			Comments:
Sample containers intact and sealed?	YES NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO			Sample IDs and Containers Affected:
Samples received within holding time?	YES NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO			Analyses Affected:
VOA vial headspace < 6 mm?	YES NO <u>N/A</u>			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.

GP.25.A r2 Sample Receipt Log

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for September 2023

[illegible]



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2310604
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	2310604-01	Drinking Water	09/07/2023 11:30	9/7/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/14/2023 12:41

Lab Sample ID#: 23I0604-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 09/07/2023 11:30
Receipt Date: 09/07/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	1.20	mg/L		0.200	PS	09/07/23 11:30	09/07/23 11:30
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	JP	09/07/23 13:45	09/08/23 14:05
E. Coli	Absent	per 100 mL		1	JP	09/07/23 13:45	09/08/23 14:05

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE ____ OF ____

 HEADQUARTER
803 Philadelphia St.
Adena, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

 SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-6376

 NORTHERN DIVISION
435 Broad Street
Pittsburgh, PA 15222
(724) 463-TEST

 WEST DIVISION
Street
PA 16150
TEST
(724) 465-4209

FOR INTERNAL LABO

2310604

Sample Identification

CIRCLE ONE:

 704 KITCHEN - MAIN SINK
802 ROOM 204 SINK

ESL#

730000

Date

9/18/13

Matrix

DW

of Bottles

1

Container Type

STERILE PLASTIC
PRESERVATIVE

Analysis Requested

TC / EC
Free Chlorine 1.20

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions:.

Drinking Water Monticau Jr/Sr - Monthly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM ON THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Sampled By: (Signature)

 9783 of 1130
Date/Time 9/18/13 1330

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Relinquished By: (Signature)

Date/Time

Received By: (Signature)

Date/Time

Correct Preservations Y/N / NA

Correct Containers Y/N / NA

Receipt Temperature 4.0 °C

Company/Name:

MONTICAU SCHOOL DISTRICT

Address:

1810 WEST SUNBURY ROAD

Contact Person:

JEFFREY CAMPBELL

Phone Number:

724-406-4426

Cell Phone:

jcampbell@monticau.org

Billing Address:

PWSID: 5100324

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.2	090723	704		090723	D	1130	32382	2310604-01	BROWNKA_108
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	704		090723	D	1130	32382	2310604-01	BROWNKA_109



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23I1480
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23I1480-01	Drinking Water	09/14/2023 11:05	9/14/23 13:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/21/2023 14:27

Lab Sample ID#: 23I1480-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 09/14/2023 11:05
Receipt Date: 09/14/2023 13:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.960	mg/L		0.200	PS	09/14/23 11:05	09/14/23 11:05

ENVIRONMENTAL SERVICE
LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15381
(724) 258-TEST
FAX: (724) 259-8376NORTHWEST DIVISION
950 Main Street
Shippensburg, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE

2311480

Sample Identification	EST#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date/Time				
Distribution: 700	2311480		01				
			9/14/03	DW	Field	Field	Free Chlorine 0.96 mg/L
ROTATION WK 1 - 704 Kitchen Sink WK 2 - 802 Room 204 Sink WK 3 - 803 Admin Sink WK 4 - 804 400 Hall RR Sink WK 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.							
Notes/Special Instructions: Drinking Water Monteau Jr/Sr - Weekly							
Sampled By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 05:11:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 10:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05				Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-405-4426 Cell Phone: 724-405-4426 Email Address: jcampbell@monteau.org Billing Address: 5100324 PWSID: 5100324			

Sample Identification	EST#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date/Time				
Distribution: 700	2311480		01				
			9/14/03	DW	Field	Field	Free Chlorine 0.96 mg/L
ROTATION WK 1 - 704 Kitchen Sink WK 2 - 802 Room 204 Sink WK 3 - 803 Admin Sink WK 4 - 804 400 Hall RR Sink WK 5 - 804 400 Hall RR Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.							
Notes/Special Instructions: Drinking Water Monteau Jr/Sr - Weekly							
Sampled By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 05:11:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 10:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05 Relinquished By: (Signature) <i>[Signature]</i> Date/Time: 9/14/03 13:05				Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-405-4426 Cell Phone: 724-405-4426 Email Address: jcampbell@monteau.org Billing Address: 5100324 PWSID: 5100324			

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.2	090723	704		090723	D	1130	32382	2310604-01	BROWNKA_108
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	704		090723	D	1130	32382	2310604-01	BROWNKA_109
5100324	1013	FREE CHLORINE	301	0.96	091423	802		091423	D	1105	32382	231480-01	BROWNKA_456



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23I2261
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23I2261-01	Drinking Water	09/21/2023 11:20	9/21/23 13:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/28/2023 16:06

Lab Sample ID#: 23I2261-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 09/21/2023 11:20
Receipt Date: 09/21/2023 13:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.930	mg/L		0.200	PS	09/21/23 11:20	09/21/23 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Vleet, PA 15386 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1857	NORTHWEST DIVISION 850 Main Street Shippensburg, PA 16 (724) 483-TEST FAX: (724) 465-4209
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	EST#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 803	2212261	01		DW	Field	Field	Free Chlorine 0.93 mg/L

ROTATION

- WK 1 - 704 Kitchen Sink
- WK 2 - 802 Room 204 Sink
- WK 3 - 803 Admin Sink
- WK 4 - 804 400 Hall RR Sink
- WK 5 - 804 400 Hall RR Sink

2312261

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDING COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Monteau Jr/Sr - Weekly

Sampled By: (Signature) Date/Time: 9/21/23 08:40	Company/Name: Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Phone Number: 724-406-4426 Email Address: jcambell@monteau.org Billing Address: 5100324 PWSID:
Relinquished By: (Signature) Date/Time: 9/21/23 13:25	Contact Person: Phone Number: 724-406-4426 Email Address: jcambell@monteau.org Billing Address: 5100324 PWSID:
Relinquished By: (Signature) Date/Time:	Contact Person: Phone Number: 724-406-4426 Email Address: jcambell@monteau.org Billing Address: 5100324 PWSID:
Relinquished By: (Signature) Date/Time:	Contact Person: Phone Number: 724-406-4426 Email Address: jcambell@monteau.org Billing Address: 5100324 PWSID:
Correct Preservations: Y/N/NA	Correct Containers: Y/N/NA
Receipt Temperature:	

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.2	090723	704		090723	D	1130	32382	2310604-01	BROWNKA_108
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	704		090723	D	1130	32382	2310604-01	BROWNKA_109
5100324	1013	FREE CHLORINE	301	0.96	091423	802		091423	D	1105	32382	2311480-01	BROWNKA_456
5100324	1013	FREE CHLORINE	301	0.93	092123	803		092123	D	1120	32382	2312261-01	BROWNKA_1260



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Monfoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

09 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2312850
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	2312850-01	Drinking Water	09/28/2023 10:25	9/28/23 12:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/09/2023 12:44

Lab Sample ID#: 23I2850-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 09/28/2023 10:25
Receipt Date: 09/28/2023 12:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.970	mg/L		0.200	PS	09/28/23 10:25	09/28/23 10:25

**H
1
CE
1**

100

Analysis Requested	
Free Chlorine	0.97 mg/L

--	--

Wk 2 - 802 Room 204 Sink

WK 3 - 803 Admin Sink

WK 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special instructions:..

Drinking Water Moniteau Jr/Sr - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1/2% PER MONTH (1% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW);
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEE PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name:

MONTEAU SCHOOL DISTRICT

Sampled By: (Signature)

Issue of
Date & Time

Address:

391 HOOKER ROAD

Belmont & Howard B.V. (Singapore)Date/Time _____Received By: (Signature) _____Date/ Time

Contact Person:

JEFFREY CAMPBELL

Gesellschaft BV (Signature)

Date/ TimeReceived By: (Signature)Date/ Time

Cell Phone:

724-406-4426

Bezeichnet durch: (Signature)

Date/TimeReceived By: (Signature)Date/Time

Billing Address:

Correct Preservations (Y/N/NA)

Correct Containers ☒ Y / ☐ N / ☐ NA

Receipt Temperature 1.8 21

[illegible]1

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.2	090723	704		090723	D	1130	32382	2310604-01	BROWNKA_108
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	704		090723	D	1130	32382	2310604-01	BROWNKA_109
5100324	1013	FREE CHLORINE	301	0.96	091423	802		091423	D	1105	32382	2311480-01	BROWNKA_456
5100324	1013	FREE CHLORINE	301	0.93	092123	803		092123	D	1120	32382	2312261-01	BROWNKA_1260
5100324	1013	FREE CHLORINE	301	0.97	092823	804		092823	D	1025	32382	2312850-01	BROWNKA_1870

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for September 2023

Dassa McKinney Elementary School Water Treatment Facility									
Month	Sept.	2023							
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time
1	Fri	8.7	0.02	0.74	0.82	2.31	14299700	Jeff R	3:30P
2	Sat								
3	Sun								
4	Mon								
5	Tues	8.7	0.05	0.66	0.78	1.64	14303800	Jeff R	3:30P
6	Wed	8.7	0.03	0.74	0.83	1.91	14307500	Jeff R	3:30P
7	Thurs	8.7	0.02	0.69	0.83	2.68	14311500	Jeff R	3:30P
8	Fri	8.7	0.02	0.74	0.83	2.71	14315600	Jeff R	3:30P
9	Sat								
10	Sun								
11	Mon	8.7	0.01	0.81	0.90	2.85	14319900	Jeff R	3:30P
12	Tues	8.7	0.00	0.82	0.92	3.18	14324200	Jeff R	3:30P
13	Wed	8.7	0.01	0.76	0.85	1.98	14328500	Jeff R	3:30P
14	Thurs	8.7	0.05	0.74	0.84	3.12	14332800	Jeff R	3:30P
15	Fri	8.7	0.03	0.71	0.80	3.25	14336700	Jeff R	3:30P
16	Sat								
17	Sun								
18	Mon	8.7	0.03	0.75	0.85	2.66	14340900	Jeff R	3:30P
19	Tues	8.7	0.03	0.74	0.83	2.98	14344700	Jeff R	3:30P
20	Wed	8.7	0.02	0.73	0.83	3.14	14348700	Jeff R	3:30P
21	Thurs	8.7	0.00	0.71	0.83	3.15	14353300	Jeff R	3:30P
22	Fri	8.7	0.01	0.71	0.82	3.18	14357500	Jeff R	3:30P
23	Sat								
24	Sun								
25	Mon	8.7	0.00	0.77	0.88	3.26	14361400	Jeff R	3:30P
26	Tues	8.7	0.02	0.68	0.75	2.66	14365400	Jeff R	3:30P
27	Wed	8.7	0.02	0.63	0.75	2.44	14369400	Jeff R	3:30P
28	Thurs	8.7	0.04	0.66	0.76	2.45	14373600	Jeff R	3:30P
29	Fri	8.7	0.02	0.67	0.74	2.89	14377700	Jeff R	3:30P
30	Sat								
31									

Meter Reading 8/31/23 - 14295700



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2310603
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	2310603-01	Drinking Water	09/07/2023 11:10	9/7/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1275 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 600
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/14/2023 12:41

Lab Sample ID#: 23T0603-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 09/07/2023 11:10
Receipt Date: 09/07/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.830	mg/L		0.200	PS	09/07/23 11:10	09/07/23 11:10
Microbiology							
Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	JP	09/07/23 13:45	09/08/23 14:05
E. Coli	Absent	per 100 mL		1	JP	09/07/23 13:45	09/08/23 14:05

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SALES

AW OF CUSTODY

3E 1 OF 1

HEADQUARTER
1903 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15386
(724) 258-TEST
FAX: (724) 258-6376

WEST DIVISION
1616 S. Street
Sharpsville, PA 16156
(724) 463-TEST
FAX: (724) 465-4208

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	2310603	9/7/23	11:00	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.83 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (ONE PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) 	Date: Time 9/7/23 08:11:00	Company Name: MONTEAU SCHOOL DISTRICT
Relinquished By: (Signature)	Date: Time 9/7/23 08:11:00	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Relinquished By: (Signature)	Date: Time 9/7/23 08:11:00	Contact Person: JEFFREY CAMPBELL
Relinquished By: (Signature)	Date: Time 9/7/23 08:11:00	Phone Number: 724-406-4426
Relinquished By: (Signature)	Date: Time 9/7/23 08:11:00	Cell Phone: 724-406-4426
Relinquished By: (Signature)	Date: Time 9/7/23 08:11:00	Email Address: jcampbell@monteau.org
Relinquished By: (Signature)	Date: Time 9/7/23 08:11:00	Billing Address: 5100316
Correct Preservations 3/1/NA	Correct Containers 3/1/NA	Receipt Temperature 4.0°C

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	090723	801		090723	D	1110	32382	2310603-01	BROWNKA_106
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	801		090723	D	1110	32382	2310603-01	BROWNKA_107



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2311479
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	2311479-01	Drinking Water	09/14/2023 10:40	9/14/23 13:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit


Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



ENVIRONMENTAL
SERVICE LABORATORIES, INC.

1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04834

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/21/2023 14:27

Lab Sample ID#: 23I1479-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 09/14/2023 10:40
Receipt Date: 09/14/2023 13:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.670	mg/L		0.200	PS	09/14/23 10:40	09/14/23 10:40

**ENVIRONMENTAL SERVICE
LABORATORIES, INC**

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 of 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15386 (724) 288-TEST FAX: (724) 288-8376	NORTHWEST DIVISION 650 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4208
---	--	---

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <i>Preservative</i>	Analysis Requested
		Grab	Time				
Distribution: <u>889</u>	<u>2371479</u>						
	<u>01</u>	<u>91405</u>	<u>1040</u>	DW	Field	Field	Free Chlorine <u>0.67</u> mg/L

ROTATION
Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 817 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 817 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special instructions:

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Sampled By: (Signature) <u>[Signature]</u>		Date/ Time <u>9-14-23 10:40</u>
Requisitioned By: (Signature) <u>[Signature]</u>		Date/ Time <u>9-14-23 10:55</u>
Requisitioned By: (Signature)		Date/ Time
Requisitioned By: (Signature)		Date/ Time
Requisitioned By: (Signature)		Date/ Time
Correct Preservations <u>Y/N/N/A</u>		Correct Containers <u>Y/N/N/A</u>
Receipt Temperature <u>3.4 °C</u>		

Company/Name:	MONTTEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061
Contact Person:	JEFFREY CAMPBELL
Phone Number:	
Cell Phone:	724-406-4426
Email Address:	jcambell@montiteau.org
Billing Address:	
PW/SID:	5100316

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	090723	801		090723	D	1110	32382	2310603-01	BROWNKA_106
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	801		090723	D	1110	32382	2310603-01	BROWNKA_107
5100316	1013	FREE CHLORINE	301	0.67	091423	802		091423	D	1040	32382	2311479-01	BROWNKA_455



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 September 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2312259
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	2312259-01	Drinking Water	09/21/2023 12:00	9/21/23 13:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 09/28/2023 16:06

Lab Sample ID#: 23I2259-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 09/21/2023 12:00
Receipt Date: 09/21/2023 13:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			
Chlorine, Free	0.400	mg/L		0.200	PS	09/21/23 12:00	09/21/23 12:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Vleet, PA 15306 (724) 258-TEST FAX: (724) 258-8078	NORTHERN DIVISION 405 Broad Street Montoursville, PA 17754 (570) 321-8003 FAX: (570) 321-1867	NORTHWEST DIVISION 950 Main Street Shippensburg, PA 17 (724) 463-TEST FAX: (724) 465-4208
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 863	2212259	9003	1100	DW	Field	Field	Free Chlorine 0.40 mg/L

ROTATION

WK 1 - 801 Kitchen Sink

WK 2 - 802 Room 617 Sink

WK 3 - 803 Room 606 Sink

WK 4 - 804 Room 408 Sink

WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (1 1/2% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTORNEY COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly



2312259

Sampled By: (Signature) *[Signature]* Date/Time *9/19/23 13:00*

Relinquished By: (Signature) *[Signature]* Date/Time *9/21/23 13:25 (L2300)*

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**

West Sunbury, PA 16061

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **724-406-4426**

Email Address: **jcambell@moniteau.org**

Billing Address: **51003316**

PWSID: **51003316**

Relinquished By: (Signature) _____ Date/Time _____

Received By: (Signature) _____ Date/Time _____

Relinquished By: (Signature) _____ Date/Time _____

Received By: (Signature) _____ Date/Time _____

Relinquished By: (Signature) _____ Date/Time _____

Received By: (Signature) _____ Date/Time _____

Correct Preservations *Y/N/NA* Correct Containers *Y/N/NA* Receipt Temperature *-*

Correct Preservations *Y/N/NA* Correct Containers *Y/N/NA* Receipt Temperature *-*



E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	090723	801		090723	D	1110	32382	2310603-01	BROWNKA_106
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	801		090723	D	1110	32382	2310603-01	BROWNKA_107
5100316	1013	FREE CHLORINE	301	0.67	091423	802		091423	D	1040	32382	2311479-01	BROWNKA_455
5100316	1013	FREE CHLORINE	301	0.4	092123	803		092123	D	1200	32382	2312259-01	BROWNKA_1259



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

09 October 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23I2853
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23I2853-01	Drinking Water	09/28/2023 10:07	9/28/23 12:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/09/2023 12:44

Lab Sample ID#: 2312853-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 09/28/2023 10:07
Receipt Date: 09/28/2023 12:45

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Analytical Method: SM4500-Cl G-II				Prep Method: No Prep - Field			
Chlorine, Free	0.540	mg/L		0.200	PS	09/28/23 10:07	09/28/23 10:07

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
303 Philadelphia St.
Philadelphia, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vleet, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



2312853

WEST DIVISION
Street
e, PA 16
TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2312853	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: 804	01	Date: 9/28/23	Time: 1667	DW	Field	Field	Free Chlorine 0.54 mg/L
ROTATION WK 1 - 801 Kitchen Sink WK 2 - 802 Room 617 Sink WK 3 - 803 Room 606 Sink WK 4 - 804 Room 408 Sink WK 5 - 802 Room 617 Sink							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <i>[Signature]</i> Date/ Time 9-28-23 08:10:07 Relinquished By: (Signature) <i>[Signature]</i> Date/ Time Relinquished By: (Signature) Date/ Time Relinquished By: (Signature) Date/ Time Correct Preservations ☒ Y / N / NA Correct Containers ☒ Y / N / NA Receipt Temperature 1.8 #4				Received By: (Signature) <i>[Signature]</i> Date/ Time 9-28-23 12:45 00477 Received By: (Signature) Date/ Time Received By: (Signature) Date/ Time Received By: (Signature) Date/ Time			
Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: 724-406-4426 jcampbell@monteau.org Phone Number: 5100316 Cell Phone: Email Address: Billing Address: PW/SID:				Notes/Special Instructions: <i>Drinking Water Dassa McKinney - Weekly</i>			

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	090723	801		090723	D	1110	32382	2310603-01	BROWNKA_106
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090823	801		090723	D	1110	32382	2310603-01	BROWNKA_107
5100316	1013	FREE CHLORINE	301	0.67	091423	802		091423	D	1040	32382	2311479-01	BROWNKA_455
5100316	1013	FREE CHLORINE	301	0.4	092123	803		092123	D	1200	32382	2312259-01	BROWNKA_1259
5100316	1013	FREE CHLORINE	301	0.54	092823	804		092823	D	1007	32382	2312853-01	BROWNKA_1869