


Water Testing Results - Washington Elementary School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID#	Test Date	Test Result
WELLNESS ROOM SINK/NURSE'S SINK	22070300-001NS	3/1/2023	ND
WELLNESS RESTROOM SINK	22070300-002BF	3/1/2023	ND
STAFF BREAKROOM SINK	22070300-003SF	3/1/2023	ND
STAFF RESTROOM SINK-NORTH	22070300-004BF	3/1/2023	ND
STAFF RESTROOM SINK-SOUTH	22070300-005BF	3/1/2023	ND
KITCHEN SINK-BACK COUNTER	22070300-006KF	3/1/2023	4.0
KITCHEN STAFF RESTROOM SINK	22070300-007BF	3/1/2023	1.9
CAFETERIA WATER BOTTLE FILLER	22070300-008WB	3/1/2023	ND
MUSIC ROOM DRINKING FOUNTAIN	22070300-009DW	3/1/2023	ND
MUSIC ROOM CLASSROOM SINK	22070300-010CF	3/1/2023	ND
RESTROOM SINK - MAIN HALL - North	22070300-011BF	3/1/2023	ND
RESTROOM SINK - MAIN HALL - North Middle	22070300-012BF	3/1/2023	ND
RESTROOM SINK - MAIN HALL - South Middle	22070300-013BF	3/1/2023	ND
RESTROOM SINK - MAIN HALL - South	22070300-014BF	3/1/2023	ND
MAIN HALL HANDICAP RESTROOM SINK	22070300-015BF	3/1/2023	ND
GYM WATER BOTTLE FILLER	22070300-016WB	3/1/2023	ND
CLASSROOM #157 DRINKING FOUNTAIN	22070300-017DW	3/1/2023	ND
CLASSROOM #157 CLASSROOM SINK	22070300-018CF	3/1/2023	ND
2ND/3RD GRADE HALLWAY DRINKING FOUNTAIN	22070300-019DW	3/1/2023	ND
2ND/3RD GRADE HALLWAY CLASSROOM SINK	22070300-020CF	3/1/2023	ND
CLASSROOM #156 DRINKING FOUNTAIN	22070300-021DW	3/1/2023	ND
CLASSROOM #156 CLASSROOM SINK	22070300-022CF	3/1/2023	ND
CLASSROOM #155 CLASSROOM SINK	22070300-023CF	3/1/2023	ND
CLASSROOM #155 DRINKING FOUNTAIN	22070300-024DW	3/1/2023	ND
CLASSROOM #154 DRINKING FOUNTAIN	22070300-025DW	3/1/2023	ND
CLASSROOM #154 CLASSROOM SINK	22070300-026CF	3/1/2023	ND
CLASSROOM #153 CLASSROOM SINK	22070300-027CF	3/1/2023	ND
CLASSROOM #153 DRINKING FOUNTAIN	22070300-028DW	3/1/2023	ND
CLASSROOM #150 DRINKING FOUNTAIN	22070300-029DW	3/1/2023	ND
CLASSROOM #150 CLASSROOM SINK	22070300-030CF	3/1/2023	ND
CLASSROOM #149 DRINKING FOUNTAIN	22070300-031DW	3/1/2023	ND
CLASSROOM #149 CLASSROOM SINK	22070300-032CF	3/1/2023	ND
CLASSROOM #148 CLASSROOM SINK	22070300-033CF	3/1/2023	ND
CLASSROOM #148 DRINKING FOUNTAIN	22070300-034DW	3/1/2023	ND
CLASSROOM #147 RESTROOM SINK	22070300-035BF	3/1/2023	ND
CLASSROOM #147 DRINKING FOUNTAIN	22070300-036DW	3/1/2023	ND
CLASSROOM #147 CLASSROOM SINK	22070300-037CF	3/1/2023	ND
STAFF RESTROOM SINK 2ND/3RD HALL	22070300-038BF	3/1/2023	ND
RESTROOMS SINK - 2ND/3RD GRADE HALL NORTH 1	22070300-039BF	3/1/2023	ND
RESTROOMS SINK - 2ND/3RD GRADE HALL - NORTH 2	22070300-040BF	3/1/2023	ND
RESTROOMS SINK - 2ND/3RD GRADE HALL - MIDDLE	22070300-041BF	3/1/2023	ND
RESTROOMS SINK - 2ND/3RD GRADE HALL - SOUTH 1	22070300-042BF	3/1/2023	ND
RESTROOMS SINK - 2ND/3RD GRADE HALL - SOUTH 2	22070300-043BF	3/1/2023	ND
CLASSROOM #139 RESTROOM SINK	22070300-044BF	3/1/2023	ND
CLASSROOM #139 DRINKING FOUNTAIN	22070300-045DW	3/1/2023	ND
CLASSROOM #139 CLASSROOM SINK	22070300-046CF	3/1/2023	ND
ELL CLASSROOM #134 DRINKING FOUNTAIN	22070300-047DW	3/1/2023	ND
ELL CLASSROOM #134 CLASSROOM SINK	22070300-048CF	3/1/2023	ND
CLASSROOM #130 CLASSROOM SINK	22070300-049CF	3/1/2023	ND
CLASSROOM #130 DRINKING FOUNTAIN	22070300-050DW	3/1/2023	ND
CLASSROOM #129 DRINKING FOUNTAIN	22070300-051DW	3/1/2023	ND
CLASSROOM #129 CLASSROOM SINK	22070300-052CF	3/1/2023	ND
CLASSROOM #128 CLASSROOM SINK	22070300-053CF	3/1/2023	ND
CLASSROOM #128 DRINKING FOUNTAIN	22070300-054DW	3/1/2023	ND
1ST GRADE ALCOVE WATER BOTTLE FILLER	22070300-055WB	3/1/2023	ND
CLASSROOM #126 DRINKING FOUNTAIN	22070300-056DW	3/1/2023	ND

CLASSROOM #126 CLASSROOM SINK	22070300-057CF	3/1/2023	ND
CLASSROOM #125 CLASSROOM SINK	22070300-058CF	3/1/2023	ND
CLASSROOM #125 DRINKING FOUNTAIN	22070300-059DW	3/1/2023	ND
1ST GRADE HALLWAY CLASSROOM SINK	22070300-060CF	3/1/2023	ND
1ST GRADE HALLWAY DRINKING FOUNTAIN	22070300-061DW	3/1/2023	ND
BOYS RESTROOM SINK - 1st GRADE HALL - WEST	22070300-062BF	3/1/2023	ND
BOYS RESTROOM SINK - 1st GRADE HALL - EAST	22070300-063BF	3/1/2023	ND
GIRLS RESTROOM SINK - 1st GRADE HALL - NORTH	22070300-064BF	3/1/2023	ND
GIRLS RESTROOM SINK - 1st GRADE HALL - SOUTH	22070300-065BF	3/1/2023	ND
CLASSROOM #120A DRINKING FOUNTAIN	22070300-066DW	3/1/2023	ND
CLASSROOM #120A CLASSROOM SINK	22070300-067CF	3/1/2023	ND
2ND/3RD GRADE HALLWAY WATER BOTTLE FILLER	22070300-068WB	3/1/2023	ND
CLASSROOM #224 DRINKING FOUNTAIN	22070300-069DW	3/1/2023	ND
CLASSROOM #224 CLASSROOM SINK	22070300-070CF	3/1/2023	ND
4TH/5TH GRADE HALL WATER BOTTLE FILLER	22070300-071WB	3/1/2023	ND
4TH/5TH GRADE HALL CLASSROOM SINK	22070300-072CF	3/1/2023	ND
4TH/5TH GRADE HALL DRINKING FOUNTAIN	22070300-073DW	3/1/2023	ND
CLASSROOM #223 DRINKING FOUNTAIN	22070300-074DW	3/1/2023	ND
CLASSROOM #223 CLASSROOM SINK	22070300-075CF	3/1/2023	ND
CLASSROOM #222 CLASSROOM SINK	22070300-076CF	3/1/2023	ND
CLASSROOM #222 DRINKING FOUNTAIN	22070300-077DW	3/1/2023	ND
CLASSROOM #221 DRINKING FOUNTAIN	22070300-078DW	3/1/2023	ND
CLASSROOM #221 CLASSROOM SINK	22070300-079CF	3/1/2023	ND
CLASSROOM #220 CLASSROOM SINK	22070300-080CF	3/1/2023	ND
CLASSROOM #220 DRINKING FOUNTAIN	22070300-081DW	3/1/2023	ND
CLASSROOM #218 DRINKING FOUNTAIN	22070300-082DW	3/1/2023	ND
CLASSROOM #218 CLASSROOM SINK	22070300-083CF	3/1/2023	ND
CLASSROOM #217 DRINKING FOUNTAIN	22070300-084DW	3/1/2023	ND
CLASSROOM #217 CLASSROOM SINK	22070300-085CF	3/1/2023	ND
CLASSROOM #216 CLASSROOM SINK	22070300-086CF	3/1/2023	ND
CLASSROOM #216 DRINKING FOUNTAIN	22070300-087DW	3/1/2023	ND
CLASSROOM #215 RESTROOM	22070300-088BF	3/1/2023	1.0
CLASSROOM #215 DRINKING FOUNTAIN	22070300-089DW	3/1/2023	ND
CLASSROOM #215 CLASSROOM SINK	22070300-090CF	3/1/2023	ND
STAFF RESTROOM SINK 4TH/5TH HALL	22070300-091BF	3/1/2023	ND
RESTROOM SINK - 4TH/5TH GRADE HALL - NORTH 1	22070300-092BF	3/1/2023	ND
RESTROOM SINK - 4TH/5TH GRADE HALL - NORTH 2	22070300-093BF	3/1/2023	1.0
RESTROOM SINK - 4TH/5TH GRADE HALL - MIDDLE	22070300-094BF	3/1/2023	ND
RESTROOM SINK - 4TH/5TH GRADE HALL - SOUTH 1	22070300-095BF	3/1/2023	ND
RESTROOM SINK - 4TH/5TH GRADE HALL - SOUTH 2	22070300-096BF	3/1/2023	ND
PLAYGROUND-TALL GREEN DRINKING FOUNTAIN	22070300-097DW	TBD - MAY 2023	
PLAYGROUND-TALL GREEN DRINKING FOUNTAIN	22070300-098DW	TBD - MAY 2023	
PLAYGROUND-GREEN WATER BOTTLE FILLER	22070300-099WB	TBD - MAY 2023	
OUTSIDE DRINKING FOUNTAIN	22070300-100DW	Not tested	Damaged Fixture
Any fixture testing at or above the action level of 15 ppb is immediately removed from service			
RETESTS			
ND = Non Detect - Lead level is below the set detection limits		of 1 ppb	



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Pendleton School District	Project: General	Date Reported: 04/04/23
107 NW 10th Street	Project #: Washington Lead Testing	Date Received: 03/10/23 09:30
Pendleton, OR 97801	Client Contact: Michelle Jones	Sampled By: Thad Baum
	-	

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031604-01	Sample Location: 22070300-001NS/Wellness Room Sink-Nurse's Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:18	03/28/23	DST	
3031604-02	Sample Location: 22070300-002BF/Wellness Restroom Sink-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:18	03/28/23	DST	
3031604-03	Sample Location: 22070300-003SF/Staff Breakroom-Breakroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:21	03/28/23	DST	
3031604-04	Sample Location: 22070300-004BF/Staff Restroom North-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:20	03/28/23	DST	
3031604-05	Sample Location: 22070300-005BF/Staff Restroom South-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:19	03/28/23	DST	
3031604-06	Sample Location: 22070300-006KF/Kitchen Back Counter-Kitchen Sink									
Lead (±)		1030	4.0	ppb	1.0	15	03/01/23 06:24	03/28/23	DST	
3031604-07	Sample Location: 22070300-007BF/Kitchen Staff Restroom-Restroom Sink									
Lead (±)		1030	1.9	ppb	1.0	15	03/01/23 06:24	03/28/23	DST	
3031604-08	Sample Location: 22070300-008WB/Cafeteria-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:26	03/28/23	DST	
3031604-09	Sample Location: 22070300-009DW/Music Room-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:27	03/28/23	DST	
3031604-10	Sample Location: 22070300-010CF/Music Room-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:27	03/28/23	DST	
3031604-11	Sample Location: 22070300-011BF/Restroom Main Hall North-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:29	03/28/23	DST	
3031604-12	Sample Location: 22070300-012BF/Restroom Main Hall North Middle-Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:29	03/28/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031604-13	Sample Location: 22070300-013BF/Restroom Main Hall South Middle-Restroom Sink 3									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:30	03/28/23	DST	
3031604-14	Sample Location: 22070300-014BF/Restroom Main Hall South-Restroom Sink 4									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:31	03/28/23	DST	
3031604-15	Sample Location: 22070300-015BF/Main Hall Handicap Restroom-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:32	03/28/23	DST	
3031604-16	Sample Location: 22070300-016WB/Gym-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:34	03/28/23	DST	
3031604-17	Sample Location: 22070300-017DW/Classroom #157-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:36	03/28/23	DST	
3031604-18	Sample Location: 22070300-018CF/Classroom #157-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:36	03/28/23	DST	
3031604-19	Sample Location: 22070300-019DW/2nd,3rd Grade Hallway-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:48	03/28/23	DST	
3031604-20	Sample Location: 22070300-020CF/2nd,3rd Grade Hallway-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:48	03/28/23	DST	
3031604-21	Sample Location: 22070300-021DW/Classroom #156-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:49	03/28/23	DST	
3031604-22	Sample Location: 22070300-022CF/Classroom #156-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:49	03/28/23	DST	
3031604-23	Sample Location: 22070300-023CF/Classroom #155-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:51	03/28/23	DST	
3031604-24	Sample Location: 22070300-024DW/Classroom #155-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:51	03/28/23	DST	
3031604-25	Sample Location: 22070300-025DW/Classroom #154-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:53	03/28/23	DST	
3031604-26	Sample Location: 22070300-026CF/Classroom #154-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:53	03/28/23	DST	
3031604-27	Sample Location: 22070300-027CF/Classroom #153-Classroom Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:55	03/28/23	DST	
3031604-28	Sample Location: 22070300-028DW/Classroom #153-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:55	03/28/23	DST	
3031604-29	Sample Location: 22070300-029DW/Classroom #150-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:56	03/28/23	DST	
3031604-30	Sample Location: 22070300-030CF/Classroom #150-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:58	03/28/23	DST	
3031604-31	Sample Location: 22070300-031DW/Classroom #149-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:00	03/28/23	DST	
3031604-32	Sample Location: 22070300-032CF/Classroom #149-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:00	03/28/23	DST	
3031604-33	Sample Location: 22070300-033CF/Classroom #148-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:02	03/28/23	DST	
3031604-34	Sample Location: 22070300-034DW/Classroom #148-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:02	03/28/23	DST	
3031604-35	Sample Location: 22070300-035BF/Classroom #147 Restroom-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:06	03/28/23	DST	
3031604-36	Sample Location: 22070300-036DW/Classroom #147-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:05	03/28/23	DST	
3031604-37	Sample Location: 22070300-037CF/Classroom #147-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:04	03/28/23	DST	
3031604-38	Sample Location: 22070300-038BF/ Staff Restroom 2nd,3rd Hall-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:07	03/28/23	DST	
3031604-39	Sample Location: 22070300-039BF/Restrooms-2nd,3rd Grade Hall North 1-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:56	03/28/23	DST	
3031604-40	Sample Location: 22070300-040BF/Restrooms-2nd,3rd Grade Hall North 2-Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:57	03/28/23	DST	
3031604-41	Sample Location: 22070300-041BF/Restrooms-2nd,3rd Grade Hall Middle-Restroom Sink 3									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:57	03/28/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031604-42	Sample Location: 22070300-042BF/Restrooms-2nd,3rd Grade Hall South 1-Restroom Sink 4									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:58	03/28/23	DST	
3031604-43	Sample Location: 22070300-043BF/Restrooms-2nd,3rd Grade Hall South 2-Restroom Sink 5									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:58	03/28/23	DST	
3031604-44	Sample Location: 22070300-044BF/Classroom #139 Restroom-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:51	03/28/23	DST	
3031604-45	Sample Location: 22070300-045DW/Classroom #139-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:49	03/28/23	DST	
3031604-46	Sample Location: 22070300-046CF/Classroom #139-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:49	03/28/23	DST	
3031604-47	Sample Location: 22070300-047DW/Ell Classroom #134-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:18	03/28/23	DST	
3031604-48	Sample Location: 22070300-048CF/Ell Classroom #134-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:18	03/28/23	DST	
3031604-49	Sample Location: 22070300-049CF/Classroom #130-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:21	03/28/23	DST	
3031604-50	Sample Location: 22070300-050DW/Classroom #130-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:21	03/28/23	DST	
3031604-51	Sample Location: 22070300-051DW/Classroom #129-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:24	03/28/23	DST	
3031604-52	Sample Location: 22070300-052CF/Classroom #129-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:24	03/28/23	DST	
3031604-53	Sample Location: 22070300-053CF/Classroom #128-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:27	03/28/23	DST	
3031604-54	Sample Location: 22070300-054DW/Classroom #128-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:27	03/28/23	DST	
3031604-55	Sample Location: 22070300-055WB/1st Grade Alcove-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:33	03/28/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031604-56	Sample Location: 22070300-056DW/Classroom #126-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:30	03/28/23	DST	
3031604-57	Sample Location: 22070300-057CF/Classroom #126-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:30	03/28/23	DST	
3031604-58	Sample Location: 22070300-058CF/Classroom #125-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:34	03/28/23	DST	
3031604-59	Sample Location: 22070300-059DW/Classroom #125-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:34	03/28/23	DST	
3031604-60	Sample Location: 22070300-060CF/1st Grade Hallway-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:37	03/28/23	DST	
3031604-61	Sample Location: 22070300-061DW/1st Grade Hallway-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:37	03/28/23	DST	
3031604-62	Sample Location: 22070300-062BF/Boys Restroom 1st Grade Hall West-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:42	03/28/23	DST	
3031604-63	Sample Location: 22070300-063BF/Boys Restroom 1st Grade Hall East-Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:42	03/28/23	DST	
3031604-64	Sample Location: 22070300-064BF/Girls Restroom 1st Grade Hall North-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:37	03/28/23	DST	
3031604-65	Sample Location: 22070300-065BF/Girls Restroom 1st Grade Hall South Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:39	03/28/23	DST	
3031604-66	Sample Location: 22070300-066DW/Classroom #120A-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:45	03/28/23	DST	
3031604-67	Sample Location: 22070300-067CF/Classroom #120A-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:45	03/28/23	DST	
3031604-68	Sample Location: 22070300-068WB/2nd,3rd Grade Hallway-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 06:54	03/28/23	DST	
3031604-69	Sample Location: 22070300-069DW/Classroom #224-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:28	03/28/23	DST	
3031604-70	Sample Location: 22070300-070CF/Classroom #224-Classroom Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:28	03/28/23	DST	
3031604-71	Sample Location: 22070300-071WB/4th, 5th Grade Hall-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:29	03/28/23	DST	
3031604-72	Sample Location: 22070300-072CF/4th, 5th Grade Hall-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:27	03/28/23	DST	
3031604-73	Sample Location: 22070300-073DW/4th, 5th Grade Hall-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:27	03/28/23	DST	
3031604-74	Sample Location: 22070300-074DW/Classroom #223-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:25	03/29/23	DST	
3031604-75	Sample Location: 22070300-075CF/Classroom #223-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:25	03/29/23	DST	
3031604-76	Sample Location: 22070300-076CF/Classroom #222-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:23	03/29/23	DST	
3031604-77	Sample Location: 22070300-077DW/Classroom #222-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:23	03/29/23	DST	
3031604-78	Sample Location: 22070300-078DW/Classroom #221-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:22	03/29/23	DST	
3031604-79	Sample Location: 22070300-079CF/Classroom #221-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:22	03/29/23	DST	
3031604-80	Sample Location: 22070300-080CF/Classroom #220-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:18	03/29/23	DST	
3031604-81	Sample Location: 22070300-081DW/Classroom #220-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:18	03/29/23	DST	
3031604-82	Sample Location: 22070300-082DW/Classroom #218-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:16	03/29/23	DST	
3031604-83	Sample Location: 22070300-083CF/Classroom #218-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:16	03/29/23	DST	
3031604-84	Sample Location: 22070300-084DW/Classroom #217-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:14	03/29/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031604-85	Sample Location: 22070300-085CF/Classroom #217-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:14	03/29/23	DST	
3031604-86	Sample Location: 22070300-086CF/Classroom #216-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:12	03/29/23	DST	
3031604-87	Sample Location: 22070300-087DW/Classroom #216-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:12	03/29/23	DST	
3031604-88	Sample Location: 22070300-088BF/Classroom #215 Restroom-Restroom Sink									
Lead (±)		1030	1.0	ppb	1.0	15	03/01/23 07:20	03/29/23	DST	
3031604-89	Sample Location: 22070300-089DW/Classroom #215-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:08	03/29/23	DST	
3031604-90	Sample Location: 22070300-090CF/Classroom #215-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:08	03/29/23	DST	
3031604-91	Sample Location: 22070300-091BF/Staff Restroom 4th,5th Hall-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:19	03/29/23	DST	
3031604-92	Sample Location: 22070300-092BF/Restroom 4th,5th Grade Hall North 1-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:01	03/29/23	DST	
3031604-93	Sample Location: 22070300-093BF/Restroom 4th,5th Grade Hall North 2-Restroom Sink 2									
Lead (±)		1030	1.0	ppb	1.0	15	03/01/23 07:01	03/29/23	DST	
3031604-94	Sample Location: 22070300-094BF/Restroom 4th,5th Grade Hall Middle-Restroom Sink 3									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:04	03/29/23	DST	
3031604-95	Sample Location: 22070300-095BF/Restroom 4th,5th Grade Hall South 1-Restroom Sink 4									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:05	03/29/23	DST	
3031604-96	Sample Location: 22070300-096BF/Restroom 4th,5th Grade Hall South 2-Restroom Sink 5									
Lead (±)		1030	ND	ppb	1.0	15	03/01/23 07:05	03/29/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3031604

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager